



COMPONENT CODE	
CB1	CIRCUIT BREAKER #1
CB2	CIRCUIT BREAKER #2
CC	COMPRESSOR CONTACTOR
COMP	COMPRESSOR
DFC	DEFROST CONTROL
EHR	EMERGENCY HEAT RELAY
GND	EQUIPMENT GROUND
H1	HEAT STRIP #1
H2	HEAT STRIP #2
HC1	HEATER CONTACTOR #1
HC2	HEATER CONTACTOR #2
HPC	HIGH PRESSURE CONTROL
IBC	INDOOR BLOWER CAPACITOR
IBM	INDOOR BLOWER MOTOR
IBR	INDOOR BLOWER RELAY
LAB	LOW AMBIENT BYPASS
LAC	LOW AMBIENT CONTROL
LPB	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL
LS	LIMIT SWITCH
DOT	OUTDOOR THERMOSTAT
DFC	OUTDOOR FAN CAPACITOR
DFM	OUTDOOR FAN MOTOR
DMT	OUTDOOR MOTOR THERMOSTAT
PL1	PLUG #1
PM	PHASE MONITOR
RV	REV. VALVE SOLINOID
T	TRANSFORMER
TB, TB2	TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK
TCD	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

LABELED WIRES CONNECT IF NO OPTIONS USED.			MOVE RED WIRE TO 208V TAP FOR 208V OPERATION			RED (LOW) BLACK (HIGH) BLUE (MED) WHERE APPLICABLE			REMOVE JUMPER FOR OUTDOOR THERMOSTAT		
HIGH VOLTAGE ——— ——— ——— LOW VOLTAGE ——— ——— ——— ACCESSORY - - - - -			FACTORY STD.	FIELD	OPTIONAL	COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN	BARD MFG. CO. 4096-218 D			
BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK				
R	RED	BL	BLUE	GY	GRAY	L	LAVENDER				
O	ORANGE	W	WHITE	(S)	SLATE						