



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

Labeled wires connect if no options used.		Move red wire to 208V tap for 208V operation.		Red (low) black (high) were applicable.	
	FACTORY STD.	FIELD	OPTIONAL	COLOR CODE	
HIGH VOLTAGE	—————	- - - - -	- - - - -	BK	BLACK
LOW VOLTAGE	—————	- - - - -	- - - - -	BR	BROWN
ACCESSORY	—————	- - - - -	- - - - -	R	RED
				O	ORANGE
				Y	YELLOW
				G	GREEN
				BL	BLUE
				W	WHITE
				V	VIOLET
				(PR)	PURPLE
				GY	GRAY
				(S)	SLATE
				T	TAN
				PK	PINK
				L	LAVENDER
BARD MFG. CO.					
4096-219 A					

COMPONENT CODE	
CB1	CIRCUIT BREAKER #1
CB2	CIRCUIT BREAKER #2
CC	COMPRESSOR CONTACTOR
COMP	COMPRESSOR
DFC	DEFROST CONTROL
EHR	EMERGENCY HEAT RELAY
GND	EQUIPMENT GROUND
H1	HEAT STRIP #1
H2	HEAT STRIP #2
HC1	HEATER CONTACTOR #1
HC2	HEATER CONTACTOR #2
HPC	HIGH PRESSURE CONTROL
IBC	INDOOR BLOWER CAPACITOR
IBM	INDOOR BLOWER MOTOR
IBR	INDOOR BLOWER RELAY
LAB	LOW AMBIENT BYPASS CONTROL
LAC	LOW AMBIENT CONTROL
LPB	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL
LS	LIMIT SWITCH
OFC	OUTDOOR FAN CAPACITOR
OFM	OUTDOOR FAN MOTOR
OFR	OUTDOOR FAN RELAY
PL1	PLUG #1
RV	REV. VALVE SOLINOID
T	TRANSFORMER
TB	TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK
TCO	THERMAL CUTOFF