



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	ERV	ENERGY RECOVERY VENTILATOR
CB2	CIRCUIT BREAKER #2	FT	FREEZE T-STAT
CC	COMPRESSOR CONTACTOR	GND	EQUIPMENT GROUND
CCH	COMPRESSOR CRANKCASE HEATER	H1	HEAT STRIP #1
COMP	COMPRESSOR	H2	HEAT STRIP #2
CR1	CONTROL RELAY #1	HC1	HEATER CONTACTOR #1
CR2	CONTROL RELAY #2	HC2	HEATER CONTACTOR #2
CR3	CONTROL RELAY #3	HPC	HIGH PRESSURE CONTROL
CR4	CONTROL RELAY #4	IBC	INDOOR BLOWER CAPACITOR
CR5	CONTROL RELAY #5	IBM	INDOOR BLOWER MOTOR
CR6	CONTROL RELAY #6	IBR	INDOOR BLOWER RELAY
DFC	DEFROST CONTROL	LAB	LOW AMBIENT BYPASS CONTROL
EMR	EMERGENCY HEAT RELAY	LAC	LOW AMBIENT CONTROL
		LPB	LOW PRESSURE BYPASS
		LPC	LOW PRESSURE CONTROL
		LS	LIMIT SWITCH
		OFC	OUTDOOR FAN CAPACITOR
		OFM	OUTDOOR FAN MOTOR
		PL1	PLUG #1
		RAT	RETURN AIR THERMOSTAT
		RV	REV. VALVE SOLENOID
		T	TRANSFORMER
		TB	TERMINAL BLOCK
		TBL	LOW VOLTAGE TERMINAL BLOCK
		TCO	THERMAL CUTOFF
		TWV	THREE WAY VALVE
		TDR	TIME DELAY RELAY

A, B LABELED WIRES CONNECT IF NO OPTIONS USED.    
 C MOVE RED WIRE TO 208V TAP FOR 208V OPERATION    
 D RED (LOW) BLACK (HIGH) WHERE APPLICABLE

HIGH VOLTAGE	FACTORY STD.	FIELD	OPTIONAL	COLOR CODE														
				BK	BR	R	O	Y	G	BL	W	V	(PR)	GY	(S)	T	PK	L
	————	-----	-----	BLACK	BROWN	RED	ORANGE	YELLOW	GREEN	BLUE	WHITE	VIOLET	PURPLE	GRAY	SLATE	TAN	PINK	LAVENDER

BARD MFG. CO.

4096-220 E