



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	FT	FREEZE T-STAT
CB2	CIRCUIT BREAKER #2	GND	EQUIPMENT GROUND
CC	COMPRESSOR CONTACTOR	H1	HEAT STRIP #1
COMP	COMPRESSOR	H2	HEAT STRIP #2
CR1	CONTROL RELAY #1	HC1	HEATER CONTACTOR #1
CR2	CONTROL RELAY #2	HC2	HEATER CONTACTOR #2
CR3	CONTROL RELAY #3	HPC	HIGH PRESSURE CONTROL
CR4	CONTROL RELAY #4	IBC	INDOOR BLOWER CAPACITOR
CR5	CONTROL RELAY #5	IBM	INDOOR BLOWER MOTOR
CR6	CONTROL RELAY #6	IBR	INDOOR BLOWER RELAY
DFC	DEFROST CONTROL	LAB	LOW AMBIENT BYPASS CONTROL
EMR	EMERGENCY HEAT RELAY	LAC	LOW AMBIENT CONTROL
ERV	ENERGY RECOVERY VENTILATOR	LPB	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL	LS	LIMIT SWITCH
OFM	OUTDOOR FAN MOTOR	OFC	OUTDOOR FAN CAPACITOR
PM	PHASE MONITOR	RV	REV. VALVE SOLENOID
PL1	PLUG #1	T	TRANSFORMER
RAT	RETURN AIR THERMOSTAT	TB	TERMINAL BLOCK
RV	REV. VALVE SOLENOID	TBL	LOW VOLTAGE TERMINAL BLOCK
T	TRANSFORMER	TCO	THERMAL CUTOFF
TB	TERMINAL BLOCK	TWV	THREE WAY VALVE
TBL	LOW VOLTAGE TERMINAL BLOCK	TDR	TIME DELAY RELAY
TCO	THERMAL CUTOFF		
TWV	THREE WAY VALVE		
TDR	TIME DELAY RELAY		

A, B LABELED WIRES CONNECT IF NO OPTIONS USED.
 C MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 D RED (LOW) BLACK (HIGH) WHERE APPLICABLE

HIGH VOLTAGE		LOW VOLTAGE		ACCESSORY		COLOR CODE														
FACTORY STD.	FIELD	OPTIONAL	FACTORY STD.	FIELD	OPTIONAL	BK	BR	R	O	Y	G	BL	W	V	(PR)	GY	(S)	T	PK	L
—	---	- - -	—	---	- - -	BLACK	BROWN	RED	ORANGE	YELLOW	GREEN	BLUE	WHITE	VIOLET	PURPLE	GRAY	SLATE	TAN	PINK	LAVENDER

BARD MFG. CO.

4096-222 E