



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE

CB1	CIRCUIT BREAKER #1	HC2	HEATER CONTACTOR #2	RLB	RELAY LOGIC BOARD
CB2	CIRCUIT BREAKER #2	HPC	HIGH PRESSURE CONTROL	RV	REV. VALVE SOLENOID
CC	COMPRESSOR CONTACTOR	IBC	INDOOR BLOWER CAPACITOR	SK	START KIT
COMP	COMPRESSOR	IBM	INDOOR BLOWER MOTOR	T	TRANSFORMER
DCC	DUAL CAN CAPACITOR	IBR	INDOOR BLOWER RELAY	TB	TERMINAL BLOCK
DFC	DEFROST CONTROL	LAB	LOW AMBIENT BYPASS CONTROL	TBL	LOW VOLTAGE TERMINAL BLOCK
EMR	EMERGENCY HEAT RELAY	LAC	LOW AMBIENT CONTROL	TCO	THERMAL CUTOFF
ERV	ENERGY RECOVERY VENTILATOR	LPB	LOW PRESSURE BYPASS	TWV	THREE WAY VALVE
FT	FREEZE T-STAT	LPC	LOW PRESSURE CONTROL		
GND	EQUIPMENT GROUND	LS	LIMIT SWITCH		
H1	HEAT STRIP #1	OFM	OUTDOOR FAN MOTOR		
H2	HEAT STRIP #2	PL1	PLUG #1		
HC1	HEATER CONTACTOR #1	RAT	RETURN AIR THERMOSTAT		

A, B LABELED WIRES CONNECT IF NO OPTIONS USED.
 A MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 A RED (LOW) BLACK (HIGH) BLUE (MEDIUM) WHERE APPLICABLE

		COLOR CODE															
FACTORY STD.	FIELD	OPTIONAL	BK	BR	R	O	Y	G	BL	W	V	(PR)	GY	(S)	T	PK	L
HIGH VOLTAGE	————	-----	BLACK	BROWN	RED	ORANGE	YELLOW	GREEN	BLUE	WHITE	VIOLET	PURPLE	GRAY	SLATE	TAN	PINK	LAVENDER
LOW VOLTAGE	————	-----															
ACCESSORY	————	-----															

BARD MFG. CO.

4096-228 B