



COMPONENT CODE

CB1	CIRCUIT BREAKER #1	LAB	LOW AMBIENT BYPASS
CB2	CIRCUIT BREAKER #2	LAC	LOW AMBIENT CONTROL
CC	COMPRESSOR CONTACTOR	LPB	LOW PRESSURE BYPASS
COMP	COMPRESSOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LS	LIMIT SWITCH
EHR	EMERGENCY HEAT RELAY	DOT	OUTDOOR THERMOSTAT
GND	EQUIPMENT GROUND	DFC	OUTDOOR FAN CAPACITOR
H1	HEAT STRIP #1	DFM	OUTDOOR FAN MOTOR
H2	HEAT STRIP #2	DMT	OUTDOOR MOTOR THERMOSTAT
HC1	HEATER CONTACTOR #1	PL1	PLUG #1
HC2	HEATER CONTACTOR #2	PM	PHASE MONITOR
HPC	HIGH PRESSURE CONTROL	RV	REV. VALVE SOLINOID
IBC	INDOOR BLOWER CAPACITOR	T	TRANSFORMER
IBM	INDOOR BLOWER MOTOR	TB, TB2	TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TBL	LOW VOLTAGE TERMINAL BLOCK
		TCD	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

<p>▲, ▲, ▲ LABELED WIRES CONNECT IF NO OPTIONS USED.</p>			<p>▲ MOVE RED WIRE TO 208V TAP FOR 208V OPERATION</p>			<p>▲ (LOW) BLACK (HIGH) BLUE (MED) WHERE APPLICABLE</p>			<p>▲ REMOVE JUMPER FOR OUTDOOR THERMOSTAT</p>		
<p>FACTORY STD. FIELD OPTIONAL</p>			<p>COLOR CODE</p>								
HIGH VOLTAGE	---	---	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN	<p>BARD MFG. CO. 4096-235</p>
LOW VOLTAGE	---	---	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK	
ACCESSORY	---	---	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER	
	---	---	O	ORANGE	W	WHITE	(S)	SLATE			