



Remove Jumper Between "Y" and "Y1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, or 20 KW Heater Package is used.

<p><b>A</b> Wires Connect if Option Not Used</p> <p>High Voltage</p> <p>Low Voltage</p>	<p><b>99</b> Wire Identification numbers for Bard use only.</p>		
	Factory	Field	Optional

**WARNING**  
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

**DANGER**  
ELECTRICAL SHOCK HAZARD DISCONNECT POWER BEFORE SERVICING.

