



For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

230/208-60-3
Per Nameplate

Ground Lug (13)

Hi Voltage Field Connection

L1
L2
L3

Black
Black
3-Way Valve

Yellow
Black
Red
Compressor

Brown
Yellow
Black
Outdoor Fan Motor

Low Ambient Control (opt.)

Black
Red
Red
Hi Press. Control
Defrost Sensor

Blue
Blue
Low Press. Control
Reversing Valve

Black
Yellow
Yellow
Outdoor Temp Switch (Opt.)
Condenser Section

WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE SERVICING.

	Factory	Field	Optional
High Voltage			
Low Voltage			

Wire Identification numbers for Bard (99) use only.
4096-275 B

A → A
Same Letter Designated Wires Connect if Option Not Used

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED