



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

△, △ Labeled wires connect if no options used.

△ FOR LOW SPEED CONNECT BLACK AND ORANGE WIRES TOGETHER AND INSULATE. CONNECT RED WIRE TO TERMINAL 1 OF IBR.

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	-----	-----
LOW VOLTAGE	————	-----	-----
ACCESSORY	————	-----	-----

COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET
BR	BROWN	G	GREEN	(PR)	PURPLE
R	RED	BL	BLUE	GY	GRAY
O	ORANGE	W	WHITE	(S)	SLATE
				T	TAN
				PK	PINK
				L	LAVENDER

**BARD MFG. CO.**  
4096-310 E

COMPONENT CODE

CC	COMPRESSOR CONTACTOR	LAB	LOW AMBIENT BYPASS
CCH	COMPRESSOR CRANKCASE HEATER	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LBP	LOW PRESSURE BYPASS
DCC	DUAL CAN CAPACITOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LS	LIMIT SWITCH
EHR	EMERGENCY HEAT RELAY	OFM	OUTDOOR FAN MOTOR
GND	GROUND	OFR	OUTDOOR FAN RELAY
H1	HEAT STRIP #1	PL1	PLUG #1
H2	HEAT STRIP #2	PD	PULL DISCONNECT
HC1	HEATER CONTACTOR #1	RV	REV. VALVE SOLINOID
HC2	HEATER CONTACTOR #2	SK	START KIT
HPC	HIGH PRESSURE CONTROL	T	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TCO	THERMAL CUTOFF