



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

A, **B** LABELED WIRES CONNECT IF NO OPTIONS USED.

A FOR LOW SPEED CONNECT BLACK AND ORANGE WIRES TOGETHER AND INSULATE. CONNECT RED WIRE TO TERMINAL 1 OF IBR

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	-----	-----
LOW VOLTAGE	————	-----	-----
ACCESSORY	————	-----	-----

COLOR CODE			
BK	BLACK	Y	YELLOW
BR	BROWN	G	GREEN
R	RED	BL	BLUE
O	ORANGE	W	WHITE
		V	VIOLET
		(PR)	PURPLE
		GY	GRAY
		(S)	SLATE
		T	TAN
		PK	PINK
		L	LAVENDER

BARD MFG. CO.

4096-314 B

COMPONENT CODE			
CC	COMPRESSOR CONTACTOR	LBP	LOW PRESSURE BYPASS
CCH	COMPRESSOR CRANKCASE HEATER	LPC	LOW PRESSURE CONTROL
COMP	COMPRESSOR	LS	LIMIT SWITCH
DCC	DUAL CAN CAPACITOR	ODT	OUTDOOR THERMOSTAT
DFC	DEFROST CONTROL	OFM	OUTDOOR FAN MOTOR
EHR	EMERGENCY HEAT RELAY	OFR	OUTDOOR FAN RELAY
GND	GROUND	PL1	PLUG #1
H1	HEAT STRIP #1	PD	PULL DISCONNECT
H2	HEAT STRIP #2	RV	REV. VALVE SOLINOID
HC1	HEATER CONTACTOR #1	SR	STAGING RELAY
HC2	HEATER CONTACTOR #2	SK	START KIT
HPC	HIGH PRESSURE CONTROL	T	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TCO	THERMAL CUTOFF