



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

△, △ LABELED WIRES CONNECT IF NO OPTIONS USED.

△ FOR LOW SPEED CONNECT BLACK AND ORANGE WIRES TOGETHER AND INSULATE. CONNECT RED WIRE TO TERMINAL 1 OF IBR

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	- - - -	-----
LOW VOLTAGE	————	- - - -	-----
ACCESSORY	————	- - - -	-----

COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET
BR	BROWN	G	GREEN	(PR)	PURPLE
R	RED	BL	BLUE	GY	GRAY
O	ORANGE	W	WHITE	(S)	SLATE
		T	TAN	PK	PINK
		L	LAVENDER		

BARD MFG. CO.
4096-315 D

COMPONENT CODE			
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
COH	COMPRESSOR CRANKCASE HEATER	LBP	LOW PRESSURE BYPASS
COMP	COMPRESSOR	LPC	LOW PRESSURE CONTROL
DCC	DUAL CAN CAPACITOR	LS	LIMIT SWITCH
DFC	DEFROST CONTROL	OFM	OUTDOOR FAN MOTOR
DFR	EMERGENCY HEAT RELAY	OFR	OUTDOOR FAN RELAY
GND	GROUND	PL1	PLUG #1
H1	HEAT STRIP #1	PD	PULL DISCONNECT
H2	HEAT STRIP #2	PM	PHASE MONITOR
HC1	HEATER CONTACTOR #1	RV	REV. VALVE SOL.INOID
HC2	HEATER CONTACTOR #2	SK	START KIT
HPC	HIGH PRESSURE CONTROL	T	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TCO	THERMAL CUTOFF
LAB	LOW AMBIENT BYPASS		