



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

▲ ▲ ▲ LABELED WIRES CONNECT IF NO OPTIONS USED. ▲ FOR LOW & MEDIUM SPEEDS CONNECT ORANGE TO BLACK. RED (LOW) OR BLUE (MEDIUM) TO T1 OF IBR. FOR HIGH SPEED TAPE ORANGE, RED, BLUE LEADS SEPARATELY. CONNECT BLACK TO T1 OF IBR.

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	----	----
LOW VOLTAGE	————	----	----
ACCESSORY	————	----	----

COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET
BR	BROWN	G	GREEN	(PR)	PURPLE
R	RED	BL	BLUE	GY	GRAY
O	ORANGE	W	WHITE	(S)	SLATE
		T	TAN	PK	PINK
		L	LAVENDER		

**BARD MFG. CO.**  
4096-317 C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	LPB	LOW PRESSURE BYPASS
CB2	CIRCUIT BREAKER #2	LPC	LOW PRESSURE CONTROL
CC	COMPRESSOR CONTACTOR	LS	LIMIT SWITCH
CCH	CRANKCASE HEATER	MSR	MOTOR SPEED RELAY
COMP	COMPRESSOR	DFC	OUTDOOR FAN CAPACITOR
DFC	DEFROST CONTROL	DFM	OUTDOOR FAN MOTOR
EHR	EMERGENCY HEAT RELAY	DFR	OUTDOOR FAN RELAY
GND	EQUIPMENT GROUND	DMT	OUTDOOR MOTOR THERMOSTAT
HI	HEAT STRIP #1	PL1	PLUG #1
HC1	HEATER CONTACTOR #1	PM	PHASE MONITOR
HPC	HIGH PRESSURE CONTROL	RV	REV. VALVE SOLINOID
IBC	INDOOR BLOWER CAPACITOR	T	TRANSFORMER
IBM	INDOOR BLOWER MOTOR	TB, TB2	TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TBL	LOW VOLTAGE TERMINAL BLOCK
LAB	LOW AMBIENT BYPASS	TCO	THERMAL CUTOFF
LAC	LOW AMBIENT CONTROL		