



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

FOR LOW SPEED CONNECT BLACK AND ORANGE WIRES TOGETHER  
AND INSULATE. CONNECT RED WIRE TO TERMINAL 1 OF ITR

△, ▽ LABELED WIRES CONNECT IF NO OPTIONS USED.

COMPONENT CODE	COMPONENT CODE	COMPONENT CODE	
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
CH	COMPRESSOR CRANKCASE HEATER	LBP	LOW PRESSURE BYPASS
CMF	COMPRESSOR	LFC	LOW PRESSURE CONTROL
DCC	DUAL CAN CAPACITOR	LS	LIMIT SWITCH
DFC	DEFROST CONTROL	DFM	OUTDOOR FAN MOTOR
ERF	EMERGENCY HEAT RELAY	DFR	OUTDOOR FAN RELAY
GND	GROUND	PLJ	PLUG #1
H1	HEAT STRIP #1	PO	PULL DISCONNECT
H2	HEAT STRIP #2	PN	PHASE MONITOR
HCL	HEATER CONTACTOR #1	RV	REV. VALVE SOLINOID
H2	HEATER CONTACTOR #2	SK	START KIT
HPC	HIGH PRESSURE CONTROL	TRN	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TOO	THERMAL CUTOFF
LAB	LOW AMBIENT BYPASS		

FACTORY STD.	FIELD	OPTIONAL
—————	-----	-----
-----	-----	-----
-----	-----	-----
-----	-----	-----

BLACK	BROWN	RED	ORANGE	WHITE	SLATE	VIOLET	PURPLE	GRAY	PINK	TAN
BK	BR	R	O	W	S	V	P	G	PK	T
Y	G	BL	OR	W	S	V	P	G	PK	T
Y	G	BL	OR	W	S	V	P	G	PK	T

COMPONENT CODE	COMPONENT CODE	COMPONENT CODE	
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
CH	COMPRESSOR CRANKCASE HEATER	LBP	LOW PRESSURE BYPASS
CMF	COMPRESSOR	LFC	LOW PRESSURE CONTROL
DCC	DUAL CAN CAPACITOR	LS	LIMIT SWITCH
DFC	DEFROST CONTROL	DFM	OUTDOOR FAN MOTOR
ERF	EMERGENCY HEAT RELAY	DFR	OUTDOOR FAN RELAY
GND	GROUND	PLJ	PLUG #1
H1	HEAT STRIP #1	PO	PULL DISCONNECT
H2	HEAT STRIP #2	PN	PHASE MONITOR
HCL	HEATER CONTACTOR #1	RV	REV. VALVE SOLINOID
H2	HEATER CONTACTOR #2	SK	START KIT
HPC	HIGH PRESSURE CONTROL	TRN	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TOO	THERMAL CUTOFF
LAB	LOW AMBIENT BYPASS		

BAIRD MFG. CO.  
4096-319