



COMPONENT CODE	
CC	COMPRESSOR CONTACTOR
CCH	COMPRESSOR CRANKCASE HEATER
COMP	COMPRESSOR
DFC	DEFROST CONTROL
EHR	EMERGENCY HEAT RELAY
GND	GROUND
H1	HEAT STRIP #1
H2	HEAT STRIP #2
HC1	HEATER CONTACTOR #1
HC2	HEATER CONTACTOR #2
HPC	HIGH PRESSURE CONTROL
IBC	INDOOR BLOWER CAPACITOR
IBM	INDOOR BLOWER MOTOR
IBR	INDOOR BLOWER RELAY
LAB	LOW AMBIENT BYPASS
LAC	LOW AMBIENT CONTROL
LBP	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL
LS	LIMIT SWITCH
OFC	OUTDOOR FAN CAPACITOR
OFM	OUTDOOR FAN MOTOR
OFR	OUTDOOR FAN RELAY
PL1	PLUG #1
PD	PULL DISCONNECT
PM	PHASE MONITOR
RV	REV. VALVE SOLINOID
SK	START KIT
T	TRANSFORMER
TB	TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK
TCO	THERMAL CUTOFF

LAC	LOW AMBIENT CONTROL
LBP	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL
LS	LIMIT SWITCH
OFC	OUTDOOR FAN CAPACITOR
OFM	OUTDOOR FAN MOTOR
OFR	OUTDOOR FAN RELAY
PL1	PLUG #1
PD	PULL DISCONNECT
PM	PHASE MONITOR
RV	REV. VALVE SOLINOID
SK	START KIT
T	TRANSFORMER
TB	TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK
TCO	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

⚠, ⚠ Labeled wires connect if no options used. ⚠ For low & medium speeds connect orange to black. Red (low) or blue (medium) to T1 of IBR. For high speed tape orange, red, blue leads separately. Connect black to T1 of IBR.

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	<u>————</u>	<u>-----</u>	<u>-----</u>
LOW VOLTAGE	<u>————</u>	<u>-----</u>	<u>-----</u>
ACCESSORY	<u>————</u>	<u>-----</u>	<u>-----</u>

COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET
BR	BROWN	G	GREEN	(PR)	PURPLE
R	RED	BL	BLUE	GY	GRAY
O	ORANGE	W	WHITE	(S)	SLATE
		T	TAN	PK	PINK
		L	LAVENDER		

BARD MFG. CO.
4096-327