



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	HC2	HEATER CONTACTOR #2
CB2	CIRCUIT BREAKER #2	HPC	HIGH PRESSURE CONTROL
CC	COMPRESSOR CONTACTOR	IBM	INDOOR BLOWER MOTOR
COMP	COMPRESSOR	IBR	INDOOR BLOWER RELAY
DCC	DUAL CAN CAPACITOR	LAB	LOW AMBIENT BYPASS CONTROL
DFC	DEFROST CONTROL	LAC	LOW AMBIENT CONTROL
EMR	EMERGENCY HEAT RELAY	LPC	LOW PRESSURE CONTROL
ERV	ENERGY RECOVERY VENTILATOR	LS	LIMIT SWITCH
FT	FREEZE T-STAT	OFM	OUTDOOR FAN MOTOR
GND	EQUIPMENT GROUND	PL1	PLUG #1
H1	HEAT STRIP #1	RAT	RETURN AIR THERMISTAT
H2	HEAT STRIP #2		
HC1	HEATER CONTACTOR #1		
RLB	RELAY LOGIC BOARD	RV	REV. VALVE SOLENOID
RV	REV. VALVE SOLENOID	SK	START KIT
SK	START KIT	T	TRANSFORMER
T	TRANSFORMER	TB	TERMINAL BLOCK
TB	TERMINAL BLOCK	TBL	LOW VOLTAGE TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK	TCO	THERMAL CUTOFF
TCO	THERMAL CUTOFF	TWV	THREE WAY VALVE
TWV	THREE WAY VALVE		

A B LABELED WIRES CONNECT IF NO OPTIONS USED.

A FOR LOW & MEDIUM SPEEDS CONNECT ORANGE TO BLACK. RED (LOW) OR BLUE (MEDIUM) TO T1 OF IBR. FOR HIGH SPEED TAPE ORANGE, RED, BLUE LEADS SEPARATELY. CONNECT BLACK TO T1 OF IBR.

FACTORY STD.		FIELD		OPTIONAL		COLOR CODE							
HIGH VOLTAGE	————	----	----	----	----	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	----	----	----	----	BR	BROWN	BL	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	----	----	----	----	R	RED	GB	BLUE	GY	GRAY	L	LAVENDER
						O	ORANGE	W	WHITE	(S)	SLATE		

BARD MFG. CO.
4096-330 A