



Remove Jumper Between "Y" and "Y1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, 20 KW Heater Package is used.

<p><b>A</b></p> <p>Wires Connect if Option Not Used</p>	<p>99 Wire Identification numbers for Bard use only.</p>		
	Factory	Field	Optional
High Voltage			
Low Voltage			

**WARNING**  
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

**DANGER**  
ELECTRICAL SHOCK HAZARD DISCONNECT POWER BEFORE SERVICING.



Bard Mfg. Co.  
Bryan, Ohio  
4096-339 A