



Remove Jumper Between "Y" and "O1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, 20 KW Heater Package is used.

<p>A Wires Connect if Option Not Used</p>	Factory	Field	Optional
	High Voltage		
Low Voltage			

WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD DISCONNECT POWER BEFORE SERVICING.



Bard Mfg. Co.
Bryan, Ohio
4096-339