



Remove Jumper Between "Y" and "Y1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, 20 KW Heater Package is used.

A Wires Connect if Option Not Used

High Voltage	Low Voltage

B For low speed connect black and orange wires together and insulate. Connect red wire to terminal 1 of IBR.

99 Wire Identification numbers for Bard use only.

Factory	Field	Optional

WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE SERVICING.



Bard Mfg. Co.
Bryan, Ohio

4096-341 B