



Remove Jumper Between "Y" and "Y1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, 20 KW Heater Package is used.

<p>A Wires Connect if Option Not Used</p>	<p>B For low speed connect black and orange wires together and insulate. Connect red wire to terminal 1 of IBR.</p>		
	<p>99 Wire Identification numbers for Bard use only.</p>		
High Voltage	Factory	Field	Optional
Low Voltage			

WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD DISCONNECT POWER BEFORE SERVICING.



Bard Mfg. Co.
Bryan, Ohio

4096-353 A