



Remove Jumper Between "Y" and "Y1" if Outdoor Thermostat is used.

Move wire from W2 to DH if 15, 18, 20 KW Heater Package is used.

Warnings and Notes:

- A** Wires Connect if Option Not Used
- B** For low speed connect black and orange wires together and insulate. Connect red wire to terminal 1 of IBR.
- 99** Wire Identification numbers for Bard use only.
- WARNING** USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.
- DANGER** ELECTRICAL SHOCK HAZARD DISCONNECT POWER BEFORE SERVICING.

	Factory	Field	Optional
High Voltage			
Low Voltage			

Bard
SINCE 1914
Bard Mfg. Co.
Bryan, Ohio
4096-353