


For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

460-603
Per Nameplate

L1 L2 L3
---Hi Voltage Field Connection
---Hi Voltage Field Connection
---Hi Voltage Field Connection




WARNING
USE COPPER CONDUCTORS
ONLY SUITABLE FOR AT LEAST
75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE
SERVICING.

High Voltage	Factory	Field	Optional
Low Voltage			

Wire Identification numbers for Bard (99) use only.
4096-374



NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED

NOTE: ONLY USED WHEN LAC INSTALLED

Evaporator Section

