



- ⚠ FOR ANTIFREEZE LOOP APPLICATIONS, CHANGE LOW PRESSURE SWITCH TO YELLOW LEADS ON YELLOW WIRES COMING OFF OF COMPRESSOR CONTROL MODULE "LPC" TERMINALS
- ⚠ FOR 208 VOLT OPERATION, MOVE THIS RED WIRE TO 208 VOLT TRANSFORMER TAP
- ⚠ REMOVE JUMPER WHEN CS2000 ENERGY MONITOR IS INSTALLED
- ⚠ REMOVE WIRE FROM TERMINAL Y2 AND TAPE OFF WHEN LOWER FULL LOAD CFM DESIRED

**CAPACITOR CHART**

MODEL	CAPACITOR
OW2S	35/370
OW3S	40/370
OW4S	45/370
OW5S	80/370

**⚠ DANGER**  
ELECTRICAL SHOCK HAZARD  
DISCONNECT POWER BEFORE  
SERVICING.

Wire Identification numbers for Bard use only.

	Factory	Field	Optional
High Voltage			
Low Voltage			

**WARNING**  
USE COPPER CONDUCTORS  
ONLY SUITABLE FOR AT LEAST  
75° C.

**Bard**  
Bard Mfg. Co.  
Bryan, Ohio  
4113C201 B

**COMPOSITE WIRING DIAGRAM**  
208/230-60-3