



Damper Motor
See Chart Below

230/208-60-1
Per Name Plate
Hi Voltage
Field Connections

Modbus

Unit Fail Alarm Opt

Remove jumpers
to connect unit
shutdown relay

T
H
E
F
T

FIELD BUS 2

USED TO
BE C2

- EEV ELECTRONIC EXPANSION VALVE
- LT LIQUID TEMPERATURE
- AFS AIR FLOW SWITCH
- DFS DIRTY FILTER SWITCH
- OATH OUTDOOR TEMP. AND HUMID. SENSOR
- SP SUCTION PRESSURE TRANSDUCER
- LP LIQUID PRESSURE TRANSDUCER
- SAT SUPPLY AIR TEMPERATURE
- RAT RETURN AIR TEMPERATURE
- ST SUCTION TEMPERATURE
- BS BLADE SWITCH
- DFL DIRTY FILTER LIGHT
- TB TERMINAL BLOCK
- HPS HIGH PRESSURE SWITCH
- CCH CRANKCASE HEATER

DAMPER MOTOR					
Belimo			Honeywell Motor		
Wire color	Terminal Number	Symbol	Wire color	Terminal Number	Symbol
BK/W	1	-	BK/W	2	GND
R/W	2	+	R/W	1	24 V AC
BR/W	3	Y	BR/W	3	2-10 V DC

	Factory	Field	Optional
High Voltage		---	---
Low Voltage		---	---
D-10VDC	---		