



For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

230/208-60-3
Per Nameplate

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO RDS OPTION IS INSTALLED

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED

WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE SERVICING.

Same Letter Designated Wires Connect if Option Not Used
"A" No Control Option
"B" & "C" Only LAC Option

| | | | |
|--------------|---------|-------|----------|
| High Voltage | Factory | Field | Optional |
| Low Voltage | | | |

Wire Identification numbers for Bard (99) use only.
4096-299