



DUAL FUEL ADD-ON HEAT PUMP GUIDE
FOR OPERATIONAL COST SAVINGS

REGION 2



BARD MANUFACTURING CO. • BRYAN, OHIO 43506
Dependable quality equipment...since 1914



This map is reasonably accurate for most parts of the United States but is necessarily highly generalized and consequently not too accurate in mountainous regions, particularly in the Rockies.

TABLE OF CONTENTS

General Description				i
How To Use				ii
Heat Pump Outdoor Model	Heat Pump Indoor Model	Furnace Fuel	Furnace AFUE Efficiency Rating	Page
WQS30/WQSD30	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	1 2 3 4
WQS36/WQSD36	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	5 6 7 8
24HPQ2	H24QS1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	9 10 11 12
30HPQ4	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	13 14 15 16
36HPQ4	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	17 18 19 20
42HPQ	H5AQ	Electric Natural Gas Oil Propane	100% 65% 65% 65%	21 22 23 24
48HPQ2	H5AQ	Electric Natural Gas Oil Propane	100% 65% 65% 65%	25 26 27 28

GENERAL DESCRIPTION

WHAT DOES THIS GUIDE SHOW?

This operational cost savings guide has been prepared to show theoretical cost savings for Bard dual fuel "add-on" heat pumps when used with either existing or new furnaces. It covers add-on applications for electric, oil, propane gas and natural gas type forced air furnaces. It includes both air source heat pumps and ground water source heat pumps at many combinations of gas, oil and electrical rates. It enables the user not only to make a theoretical operating cost comparison at today's fuel costs but also at future estimated higher energy costs.

It is important to understand that this is a theoretical comparison between fuels. Actual operation costs can vary depending on many difficult to predict variables such as the actual design heating or cooling load, air infiltration, and wind effects, solar effect, efficiency of existing furnace, severity of weather for a given heating or cooling season and also individual usage pattern.

SPECIAL FEATURE - FSM-1 FUEL SAVER MODULE

These estimates utilize the Bard FSM-1 Fuel Saver Module which permit the heat pump to operate below the balance point to maximize the energy savings. For each application an analysis should be made to determine the economic balance point which is the outdoor temperature at which it becomes more cost effective to shut the heat pump down with an outdoor thermostat. This temperature varies with each combination of fuel cost and furnace and heat pump efficiency level. Refer to tables included in the instructions with the FSM-1 module.

FURNACE EFFICIENCY

For purposes of these cost estimates, furnace efficiency levels of 100% AFUE for electric, 65% AFUE for natural and propane gas and 65% AFUE for oil was chosen. We recognize that any variation in efficiency from these values will change the operating cost somewhat. These values were chosen to best represent typical efficiency levels of most equipment in the field today. Bard standing pilot gas furnaces without flue dampers range from 60.6% to 67.9% AFUE with a 65.1% average. New Bard oil furnaces which utilize high speed flame retention head power burners range from 72% to 83.5% AFUE with the average at 78.5%. In order to represent the typical efficiency level of oil-fired furnaces currently installed in the field, it is necessary to recognize the fact that many older less efficient designs are still in use and that the efficiency level of any oil heating system will be reduced by improper adjustment or a lack of adequate maintenance and servicing on a regular basis. An oil-fired system typically requires more frequent and complex maintenance to prevent degradation of its efficiency level, hence, a 65% AFUE was chosen for these calculations. The AFUE efficiency varies, depending on the design of the specific piece of equipment and its maintenance and condition.

HOW TO USE DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

1. Determine the heating Btuh loss and cooling Btuh gain for structure using a Bard "Whole-House Heat Loss and Gain Work Sheet," Form B008, or ACCA "Load Calculation," Manual J.
 - a. Heating house Btuh loss is _____.
 - b. Cooling house Btuh gain is _____.
2. Determine the type of fuel available at structure (what type of [fuel] heating system is already there).
 - a. Electricity
 - b. Natural Gas
 - c. Propane Gas
 - d. Fuel Oil
 - e. Good water supply and disposal
3. Call local utilities and determine area energy costs.
 - a. Electricity _____ \$/Kilowatt-hour
 - b. Natural Gas _____ \$/Therm
 - c. Propane Gas _____ \$/Gallon
 - d. Fuel Oil _____ \$/Gallon
4. Tentatively select an add-on heat pump system using Bard Manual 2100-057, "Heat Pump Sizing" as a guide, and a Bard equipment catalog.
 - a. Air to air heat pump

Model _____	Indoor Coil _____
Btuh _____	Heat Btuh _____ Cool _____
 - b. Water to air

Model _____	Indoor Coil _____
Btuh _____	Heat Btuh _____ Cool _____
5. Determine heating region where the structure is located. To do this, find the geographic location of house on regional heating load hours map. A map is located inside the front cover of this guide.
 - a. Region structure is located _____.
6. Select the "Dual Fuel Add-On Heat Pump Guide" for the region the structure is located. (See step 5 above)

7. Locate the add-on heat pump model or models you tentatively selected (Step 4) in the "Guide." Refer to Table of Contents.

EXAMPLE: 36HPQ4 w/H3AQ Indoor Coil

**BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS**

REGION 4	HEAT PUMP MODEL: OUTDOOR 36HPQ4	INDOOR H3AQ/H3AQ1
ARI RATED COOLING CAP.: BTUH (95) 36600, SEER 7.50		
ARI RATED HEATING CAP.: BTUH (47) 40500, COP(47) 2.65, HSPF 6.40 MIN.DHR		
BTUH (17) 24800, COP(17) 1.95		

8. Now locate the furnace type by fuel used (Step 2).

EXAMPLE: A fuel oil furnace with AFUE of 65%.

FURNACE TYPE FUEL OIL	FURNACE EFFICIENCY 65.00% AFUE
-----------------------	--------------------------------

9. You now have located the page or pages that will help you determine annual operating cost. See example - Figure 1.

- a. Locate the closest structure loss in Btuh column on left side of page (step 1).

EXAMPLE: 70,000 Btuh Heat Loss

- b. Locate the heating cost per unit at top of page (step 3).

EXAMPLE: \$1.40 per gallon fuel oil.

- c. Now read down the fuel cost column until directly across from structure heat loss in Btuh. This will be the theoretical annual heating cost using only the furnace.

EXAMPLE: 70,000 Btuh heat loss @ \$1.40 per gallon fuel oil, the annual cost will be \$1,878.

- d. Next locate the electric cost \$/Kw under Heat Loss Btuh for structure (step 3).

EXAMPLE: \$.06 Kw rate

- e. Now once again read down the fuel cost column until directly across from electric cost \$/Kw. You now have located the annual heating cost for the house using an add-on heat pump with the furnace.

EXAMPLE: 70,000 Btuh structure heat loss, with \$.06 Kw cost and \$1.40 per gallon fuel oil. The annual cost using a 36HPQ4 Bard heat pump with the oil furnace would be \$1173 for an annual savings of \$705 (\$1878 minus \$1173).

Now repeat steps 8 through 9 for each type fuel and/or heat pump selected. This will enable you to select the best combination of furnace and heat pump to use for a structure.

10. The balance point (the outdoor temperature at which the heat pump is running 100% of the time and just meeting structure heat loss requirements) is located on right side of page.

EXAMPLE: For a structure with a 70,000 Btu/h with a 36HPQ4 heat pump has a balance point of 31 Deg. F. Below this theoretical balance point, the heating load is automatically transferred between the heat pump and the furnace by the wall thermostat to maintain the desired temperature. This is accomplished with the FSM-1 Fuel Saver Module.

70,000	\$ 1342	1478	1613	1743	1878	2014	2149	2285	2423	2595	2955	3227	<-- THEORETICAL HEATING COST & FURNACE ONLY
.03	\$ 663	698	716	739	767	795	818	846	868	925	976	1026	
.04	\$ 795	821	852	874	902	931	953	981	1004	1060	1111	1143	
.05	\$ 931	959	982	1010	1036	1055	1079	1104	1130	1160	1247	1247	
.06	\$ 1066	1094	1122	1150	1178	1207	1236	1264	1292	1275	1337	1233	
.07	\$ 1201	1230	1259	1288	1317	1337	1367	1397	1427	1413	1467	1568	
.08	\$ 1331	1362	1393	1424	1456	1484	1514	1545	1573	1546	1602	1653	
.09	\$ 1467	1495	1523	1550	1574	1602	1625	1653	1675	1732	1793	1833	
.10	\$ 1602	1630	1658	1681	1709	1737	1760	1788	1811	1867	1919	1969	
.12	\$ 1873	1901	1929	1952	1980	2008	2031	2059	2092	2138	2189	2240	

THEORETICAL HEATING COST & FURNACE ONLY
S PER YEAR

BALANCE POINT 31 DEG.F. 10

11. To find annual cooling cost of heat pump, look at the bottom of page under annual air conditioning cost. Directly under the electric rate \$/Kw (step 3) line, is located the annual cooling cost.

EXAMPLE: At .06 \$/Kw rate for electricity, the cooling cost would be \$234.00 annually.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.												
	⁰³	⁰⁴	⁰⁵	⁰⁶	⁰⁷	⁰⁸	⁰⁹	¹⁰	¹¹	¹²	¹³	¹⁴
	\$ 117	136	156	175	234	273	312	351	390	468		

<-- ELECTRIC RATE \$/KWH
<-- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

NOTE. The accuracy of the "Dual Fuel-Add-On Heat Pump Guide to Energy Cost Savings," is directly affected by how accurately you estimate the structure's heat loss and heat gain in step 1. Because of uncontrollable variables, Bard Manufacturing Company is not responsible for any variation in actual operating costs from these theoretical estimates.

HEAT LOSS BTUH	ELEC COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
B <--THEORETICAL HEATING COST = FURNACE ONLY													
40,000	\$ 767	340	919	998	1072	1151	1224	1373	1382	1534	1587	1839	
.03	\$ 332	338	338	344	347	355	355	361	366	372	379	389	
.04	\$ 423	434	434	440	445	451	451	457	452	468	473	485	THEORETICAL HEATING COST = FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 524	530	530	536	541	547	547	552	558	564	569	581	
.06	\$ 626	631	631	637	643	649	649	655	660	665	671	682	
.07	\$ 727	727	732	737	744	744	750	756	761	767	773		
.08	\$ 829	833	833	839	845	849	849	854	859	864	871	879	
.09	\$ 1015	1023	1023	1026	1027	1039	1039	1043	1055	1059	1072		
.10	\$ 1207	1213	1213	1218	1224	1230	1230	1235	1241	1247	1252	1263	BALANCE POINT 16 DEG.F.
50,000	\$ 959	1055	1151	1247	1262	1438	1534	1630	1725	1918	2110	2302	<--THEORETICAL HEATING COST = FURNACE ONLY
.03	\$ 428	440	445	457	462	473	485	490	502	519	536	552	
.04	\$ 541	552	558	569	575	586	586	593	603	615	628	648	THEORETICAL HEATING COST = FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 654	665	671	682	689	699	710	716	727	744	761	778	
.06	\$ 767	778	784	795	801	812	823	829	842	852	874	891	
.07	\$ 870	880	887	898	904	914	925	935	942	953	970	987	1004
.08	\$ 993	1024	1020	1021	1026	1026	1026	1026	1026	1026	1026	1026	
.09	\$ 1055	1117	1122	1134	1142	1152	1162	1168	1179	1195	1213	1231	
.10	\$ 1218	1230	1235	1257	1262	1263	1263	1263	1263	1263	1263	1263	
.12	\$ 1444	1455	1461	1472	1476	1489	1500	1506	1517	1534	1561	1583	BALANCE POINT 23 DEG.F.
60,000	\$ 1151	1253	1382	1495	1513	1725	1839	1957	2070	2302	2533	2744	<--THEORETICAL HEATING COST = FURNACE ONLY
.03	\$ 541	558	575	592	599	626	643	650	677	705	739	773	
.04	\$ 662	682	693	716	731	750	757	784	805	829	851	871	THEORETICAL HEATING COST = FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 789	805	823	842	857	874	891	908	925	939	957	981	
.06	\$ 914	932	952	972	987	1001	1016	1026	1026	1026	1026	1026	
.07	\$ 1038	1059	1072	1082	1091	1121	1139	1150	1162	1173	1201	1225	1269
.08	\$ 1162	1179	1195	1203	1203	1207	1253	1280	1297	1325	1339	1393	
.09	\$ 1292	1309	1326	1342	1359	1375	1393	1410	1427	1455	1487	1523	
.10	\$ 1415	1433	1450	1477	1494	1503	1517	1551	1579	1613	1647		
.12	\$ 1664	1681	1693	1715	1715	1749	1756	1783	1800	1823	1862	1895	BALANCE POINT 27 DEG.F.
70,000	\$ 1342	1473	1613	1763	1774	2014	2169	2295	2420	2685	2956	3227	<--THEORETICAL HEATING COST = FURNACE ONLY
.03	\$ 662	686	715	739	757	795	819	846	868	925	976	1026	
.04	\$ 795	823	852	874	891	911	931	953	973	1026	1182		THEORETICAL HEATING COST = FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 931	952	981	1001	1021	1050	1075	1095	1117	1147	1227	1282	
.06	\$ 1061	1081	1102	1122	1142	1172	1192	1212	1232	1252	1322	1383	
.07	\$ 1261	1270	1273	1282	1291	1337	1352	1392	1412	1463	1517	1548	
.08	\$ 1337	1363	1373	1416	1427	1472	1495	1523	1546	1592	1633	1734	
.09	\$ 1467	1475	1623	1586	1576	1577	1625	1633	1675	1732	1783	1833	
.10	\$ 1502	1630	1653	1691	1709	1737	1760	1768	1811	1867	1919	1959	
.12	\$ 1873	1931	1929	1952	1950	2008	2031	2054	2032	2130	2189	2260	BALANCE POINT 31 DEG.F.
80,000	\$ 1534	1697	1839	1997	2149	2302	2454	2612	2754	3059	3379	3684	<--THEORETICAL HEATING COST = FURNACE ONLY
.03	\$ 812	852	891	931	973	1013	1049	1087	1120	1207	1286	1365	
.04	\$ 953	942	1022	1072	1111	1151	1190	1233	1253	1343	1421	1505	THEORETICAL HEATING COST = FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 1094	1132	1123	1133	1154	1226	1231	1231	1231	1420	1429	1528	
.06	\$ 1235	1245	1254	1254	1254	1254	1254	1254	1254	1630	1709	1784	
.07	\$ 1376	1416	1455	1495	1534	1574	1613	1653	1692	1711	1852	1939	
.08	\$ 1517	1557	1593	1636	1675	1715	1754	1794	1833	1912	1951	2070	
.09	\$ 1653	1692	1732	1771	1811	1850	1890	1929	1969	2048	2127	2206	
.10	\$ 1794	1833	1873	1912	1952	1991	2031	2070	2110	2189	2264	2347	
.12	\$ 2076	2115	2155	2194	2234	2273	2313	2352	2392	2471	2550	2629	BALANCE POINT 34 DEG.F.
ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.													
	\$.03	.04	.05	.06	.07	.08	.09	.10	.12				<--ELECTRIC RATE \$/KWH
	\$ 117	156	195	234	273	312	351	390	468				<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

Figure 1.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION HQ530/HQ530 INDOOR-H3A0/H3A01----
COOLING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP.: 31000 BTUH, 13.2 EER
HEATING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP.: 31000 BTUH, 3.8 COP
FURNACE TYPE ELECTRIC

HEAT LOSS
BTUH ELEC.
COST
\$/KWH

20•000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 56	166
.04	\$ 75	223
.05	\$ 97	280
.06	\$ 116	336
.07	\$ 135	393
.08	\$ 154	450
.09	\$ 173	506
.10	\$ 192	563
.12	\$ 229	676

BALANCE POINT -16 DEG.F.

25•000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 72	210
.04	\$ 94	280
.05	\$ 119	349
.06	\$ 141	421
.07	\$ 166	491
.08	\$ 188	563
.09	\$ 214	632
.10	\$ 236	701
.12	\$ 286	843

BALANCE POINT 0 DEG.F.

30•000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 84	251
.04	\$ 113	336
.05	\$ 141	421
.06	\$ 169	506
.07	\$ 198	591
.08	\$ 226	676
.09	\$ 254	758
.10	\$ 283	843
.12	\$ 336	1013

BALANCE POINT 10 DEG.F.

35•000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 97	295
.04	\$ 129	393
.05	\$ 163	491
.06	\$ 195	591
.07	\$ 226	689
.08	\$ 261	786
.09	\$ 292	887
.10	\$ 324	985
.12	\$ 390	1183

BALANCE POINT 18 DEG.F.

40•000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 110	336
.04	\$ 151	450
.05	\$ 185	563
.06	\$ 223	676
.07	\$ 261	786
.08	\$ 295	900
.09	\$ 333	1013
.10	\$ 371	1126
.12	\$ 446	1353

BALANCE POINT 24 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

 .03 .04 .05 .06 .07 .08 .09 .10 .12
 \$ 150 201 251 301 351 402 452 502 603

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION HQS30/HQSD30 INDOOR_H3AO/H3AO1
COOLING CAPACITY AT -68 DEG.F. ENTERING WATER TEMP. -31000 BTUH +14.40 PER
HEATING CAPACITY AT -68 DEG.F. ENTERING WATER TEMP. -31000 BTUH +14.70 COP
FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY -62.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
20,000	\$ 100	116	132	147	160	176	192	204	220	236	264	295	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	56	56	56	56	56	56	56	56	56	56	56	
	\$.04	75	75	75	75	75	75	75	75	75	75	75	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	97	97	97	97	97	97	97	97	97	97	97	
	\$.06	116	116	116	116	116	116	116	116	116	116	116	
	\$.07	135	135	135	135	135	135	135	135	135	135	135	
	\$.08	154	154	154	154	154	154	154	154	154	154	154	
	\$.09	173	173	173	173	173	173	173	173	173	173	173	
	\$.10	192	192	192	192	192	192	192	192	192	192	192	BALANCE POINT -16 DEG.F.
	\$.12	229	229	229	229	229	229	229	229	229	229	229	
25,000	\$ 129	147	163	182	201	220	239	258	277	295	330	368	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	72	72	72	72	72	72	72	72	72	72	72	
	\$.04	94	94	94	94	94	94	94	94	94	94	94	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	119	119	119	119	119	119	119	119	119	119	119	
	\$.06	141	141	141	141	141	141	141	141	141	141	141	
	\$.07	166	166	166	166	166	166	166	166	166	166	166	
	\$.08	188	188	188	188	188	188	188	188	188	188	188	
	\$.09	214	214	214	214	214	214	214	214	214	214	214	
	\$.10	236	236	236	236	236	236	236	236	236	236	236	BALANCE POINT 0 DEG.F.
	\$.12	286	286	286	286	286	286	286	286	286	286	286	
30,000	\$ 154	176	198	220	242	264	286	308	330	352	399	443	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	84	84	84	84	84	84	84	84	84	84	84	
	\$.04	113	113	113	113	113	113	113	113	113	113	113	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	141	141	141	141	141	141	141	141	141	141	141	
	\$.06	169	169	169	169	169	169	169	169	169	169	169	
	\$.07	198	198	198	198	198	198	198	198	198	198	198	
	\$.08	226	226	226	226	226	226	226	226	226	226	226	
	\$.09	254	254	254	254	254	254	254	254	254	254	254	
	\$.10	283	283	283	283	283	283	283	283	283	283	283	BALANCE POINT 10 DEG.F.
	\$.12	336	336	336	336	336	336	336	336	336	336	336	
35,000	\$ 179	204	232	258	283	308	336	361	387	412	465	516	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	97	97	97	97	97	97	97	97	97	97	97	
	\$.04	129	129	129	129	129	129	129	129	129	129	129	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	163	163	163	163	163	163	163	163	163	163	163	
	\$.06	195	195	195	195	195	195	195	195	195	195	195	
	\$.07	226	226	226	226	226	226	226	226	226	226	226	
	\$.08	261	261	261	261	261	261	261	261	261	261	261	
	\$.09	292	292	292	292	292	292	292	292	292	292	292	BALANCE POINT 18 DEG.F.
	\$.10	324	324	324	324	324	324	324	324	324	324	324	
	\$.12	390	390	390	390	390	390	390	390	390	390	390	
40,000	\$ 204	236	264	295	324	352	384	412	443	472	531	591	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	110	110	110	110	110	110	113	113	113	113	113	
	\$.04	147	147	147	147	147	147	151	151	151	151	151	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	182	182	182	182	182	182	185	185	185	185	185	
	\$.06	220	220	220	220	220	220	223	223	223	223	223	
	\$.07	258	258	258	258	258	258	261	261	261	261	261	
	\$.08	292	292	292	292	292	292	295	295	295	295	295	
	\$.09	330	330	330	330	330	330	333	333	333	333	333	
	\$.10	365	365	365	365	365	365	368	368	368	368	368	
	\$.12	440	440	440	440	440	440	443	443	443	443	443	BALANCE POINT 24 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12 \$ 150 201 251 301 351 402 452 502 603

<--ELECTRIC RATE \$/KWH <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 8
HEAT PUMP MODEL: COMPRESSOR SECTION_HQS30/HQS30 INDOOR_H2AO/H2AO
COOLING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP.: 31000 BTUH, 12.50 EER
HEATING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP.: 31000 BTUH, 1.70 COP
FURNACE TYPE FUEL_OIL FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
20,000	\$ 210	232	254	277	295	317	339	361	384	424	469	509	<--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 56	56	56	56	56	56	56	56	56	56	56	56	
.04	\$ 75	75	75	75	75	75	75	75	75	75	75	75	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 97	97	97	97	97	97	97	97	97	97	97	97	
.06	\$ 116	116	116	116	116	116	116	116	116	116	116	116	
.07	\$ 135	135	135	135	135	135	135	135	135	135	135	135	
.08	\$ 154	154	154	154	154	154	154	154	154	154	154	154	
.09	\$ 173	173	173	173	173	173	173	173	173	173	173	173	
.10	\$ 192	192	192	192	192	192	192	192	192	192	192	192	BALANCE POINT 16 DEG.F.
.12	\$ 229	229	229	229	229	229	229	229	229	229	229	229	
25,000	\$ 264	292	317	346	371	394	424	453	478	531	585	639	<--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 72	72	72	72	72	72	72	72	72	72	72	72	
.04	\$ 94	94	94	94	94	94	94	94	94	94	94	94	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 119	119	119	119	119	119	119	119	119	119	119	119	
.06	\$ 141	141	141	141	141	141	141	141	141	141	141	141	
.07	\$ 166	166	166	166	166	166	166	166	166	166	166	166	
.08	\$ 188	188	188	188	188	188	188	188	188	188	188	188	
.09	\$ 214	214	214	214	214	214	214	214	214	214	214	214	
.10	\$ 236	236	236	236	236	236	236	236	236	236	236	236	BALANCE POINT 0 DEG.F.
.12	\$ 286	286	286	286	286	286	286	286	286	286	286	286	
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	<--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 84	84	84	84	84	84	84	84	84	84	84	84	
.04	\$ 113	113	113	113	113	113	113	113	113	113	113	113	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 141	141	141	141	141	141	141	141	141	141	141	141	
.06	\$ 169	169	169	169	169	169	169	169	169	169	169	169	
.07	\$ 198	198	198	198	198	198	198	198	198	198	198	198	
.08	\$ 226	226	226	226	226	226	226	226	226	226	226	226	
.09	\$ 254	254	254	254	254	254	254	254	254	254	254	254	
.10	\$ 283	283	283	283	283	283	283	283	283	283	283	283	BALANCE POINT 10 DEG.F.
.12	\$ 336	336	336	336	336	336	336	336	336	336	336	336	
35,000	\$ 371	409	446	484	522	560	594	632	670	746	821	893	<--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 97	97	97	97	97	97	97	97	97	97	97	97	
.04	\$ 129	129	129	129	129	129	129	129	129	129	129	129	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 163	163	163	163	163	163	163	163	163	163	163	163	
.06	\$ 195	195	195	195	195	195	195	195	195	195	195	195	
.07	\$ 226	226	226	226	226	226	226	226	226	226	226	226	
.08	\$ 261	261	261	261	261	261	261	261	261	261	261	261	
.09	\$ 292	292	292	292	292	292	292	292	292	292	292	292	
.10	\$ 324	324	324	324	324	324	324	324	324	324	324	324	
.12	\$ 390	390	390	390	390	390	390	390	390	390	390	390	BALANCE POINT 18 DEG.F.
40,000	\$ 424	469	509	554	594	638	683	723	768	853	938	1023	<--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 113	113	113	113	113	113	113	113	113	113	113	113	
.04	\$ 151	151	151	151	151	151	151	151	151	151	151	151	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 185	185	185	185	185	185	185	185	185	185	185	185	
.06	\$ 223	223	223	223	223	223	223	223	223	223	223	223	
.07	\$ 261	261	261	261	261	261	261	261	261	261	261	261	
.08	\$ 295	295	295	295	295	295	295	295	295	295	295	295	
.09	\$ 333	333	333	333	333	333	333	333	333	333	333	333	
.10	\$ 368	368	368	368	368	368	368	368	368	368	368	368	
.12	\$ 443	443	443	443	443	443	443	443	443	443	443	443	BALANCE POINT 24 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

.03	.04	.05	.06	.07	.08	.09	.10	.12	--ELECTRIC RATE \$/KWH
\$ 150	201	251	301	351	402	452	502	603	--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION HQS30/HQS010 INDOOR_H3A0/H2A01
COOLING CAPACITY AT -68 DEG.F. ENTERING WATER TEMP: -31000 BTUH +16.40 EER
HEATING CAPACITY AT -92 DEG.F. ENTERING WATER TEMP: -31000 BTUH +16.40 COP
FURNACE TYPE PROPANE_GAS FURNACE EFFICIENCY 86.00% AFUE

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

--ELECTRIC RATE \$/KWH
--MOTORETICULAR AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION HQS36/HQS36 INDOOR H340/H340
COOLING CAPACITY AT -68 DEG.F. ENTERING WATER TEMP.: 36000 BTUH 14.50 EER
HEATING CAPACITY AT -68 DEG.F. ENTERING WATER TEMP.: 20400 BTUH 14.50 COP
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS
BTUH ELEC.
COST
\$/KWH

25,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 72	210
.04	\$ 97	280
.05	\$ 122	349
.06	\$ 147	421
.07	\$ 169	491
.08	\$ 195	563
.09	\$ 220	632
.10	\$ 245	701
.12	\$ 292	843

BALANCE POINT -15 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 88	251
.04	\$ 116	336
.05	\$ 144	421
.06	\$ 176	506
.07	\$ 204	591
.08	\$ 232	676
.09	\$ 261	758
.10	\$ 292	843
.12	\$ 349	1013

BALANCE POINT -2 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 100	295
.04	\$ 135	393
.05	\$ 169	491
.06	\$ 201	591
.07	\$ 236	689
.08	\$ 270	786
.09	\$ 302	887
.10	\$ 336	985
.12	\$ 402	1183

BALANCE POINT 7 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 113	336
.04	\$ 151	450
.05	\$ 192	563
.06	\$ 229	676
.07	\$ 267	786
.08	\$ 305	900
.09	\$ 343	1013
.10	\$ 380	1126
.12	\$ 456	1353

BALANCE POINT 15 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 141	421
.04	\$ 188	563
.05	\$ 236	701
.06	\$ 283	843
.07	\$ 333	985
.08	\$ 380	1126
.09	\$ 424	1268
.10	\$ 472	1407
.12	\$ 569	1690

BALANCE POINT 24 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

--ELECTRIC RATE \$/KWH

--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

PARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

.03 .04 .05 .06 .07 .08 .09 .10 .11 .12
 187 262 311 376 424 488 541 593 729

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION HQS36/HQSD36 INDOOR H3A2/H3A01
COOLING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP: -36000 BTUH. 11.40 COP
HEATING CAPACITY AT 20 DEG.F. ENTERING WATER TEMP: -20000 BTUH. 11.50 COP
FURNACE TYPE FUEL OIL --- FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
25,000	\$.264	292	317	346	371	399	424	453	478	531	585	639	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$.72	72	72	72	72	72	72	72	72	72	72	72	
.04	\$.97	97	97	97	97	97	97	97	97	97	97	97	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 1.22	122	122	122	122	122	122	122	122	122	122	122	
.06	\$ 1.47	147	147	147	147	147	147	147	147	147	147	147	
.07	\$ 1.69	169	169	169	169	169	169	169	169	169	169	169	
.08	\$ 1.95	195	195	195	195	195	195	195	195	195	195	195	
.09	\$ 2.20	220	220	220	220	220	220	220	220	220	220	220	
.10	\$ 2.45	245	245	245	245	245	245	245	245	245	245	245	
.12	\$ 2.92	292	292	292	292	292	292	292	292	292	292	292	BALANCE POINT -15 DEG.F.
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$.88	88	88	88	88	88	88	88	88	88	88	88	
.04	\$ 1.16	116	116	116	116	116	116	116	116	116	116	116	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 1.44	144	144	144	144	144	144	144	144	144	144	144	
.06	\$ 1.76	176	176	176	176	176	176	176	176	176	176	176	
.07	\$ 2.04	204	204	204	204	204	204	204	204	204	204	204	
.08	\$ 2.32	232	232	232	232	232	232	232	232	232	232	232	
.09	\$ 2.61	261	261	261	261	261	261	261	261	261	261	261	
.10	\$ 2.92	292	292	292	292	292	292	292	292	292	292	292	BALANCE POINT -2 DEG.F.
.12	\$ 349	349	349	349	349	349	349	349	349	349	349	349	
35,000	\$ 371	409	446	484	522	560	594	632	670	746	821	893	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 100	100	100	100	100	100	100	100	100	100	100	100	
.04	\$ 135	135	135	135	135	135	135	135	135	135	135	135	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 169	169	169	169	169	169	169	169	169	169	169	169	
.06	\$ 201	201	201	201	201	201	201	201	201	201	201	201	
.07	\$ 236	236	236	236	236	236	236	236	236	236	236	236	
.08	\$ 270	270	270	270	270	270	270	270	270	270	270	270	
.09	\$ 302	302	302	302	302	302	302	302	302	302	302	302	
.10	\$ 336	336	336	336	336	336	336	336	336	336	336	336	BALANCE POINT 7 DEG.F.
.12	\$ 402	402	402	402	402	402	402	402	402	402	402	402	
40,000	\$ 424	469	509	554	594	638	683	723	768	853	938	1023	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 113	113	113	113	113	113	113	113	113	113	113	113	
.04	\$ 151	151	151	151	151	151	151	151	151	151	151	151	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 192	192	192	192	192	192	192	192	192	192	192	192	
.06	\$ 229	229	229	229	229	229	229	229	229	229	229	229	
.07	\$ 267	267	267	267	267	267	267	267	267	267	267	267	
.08	\$ 305	305	305	305	305	305	305	305	305	305	305	305	
.09	\$ 343	343	343	343	343	343	343	343	343	343	343	343	
.10	\$ 380	380	380	380	380	380	380	380	380	380	380	380	BALANCE POINT 15 DEG.F.
.12	\$ 456	456	456	456	456	456	456	456	456	456	456	456	
50,000	\$ 531	585	638	692	746	799	853	906	960	1067	1174	1277	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 141	141	141	141	141	141	141	141	144	144	144	144	
.04	\$ 188	188	188	188	188	188	188	188	192	192	192	192	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 236	236	236	236	236	236	236	236	239	239	239	239	
.06	\$ 283	283	283	283	283	283	283	283	286	286	286	286	
.07	\$ 330	330	330	330	330	330	330	330	333	333	333	333	
.08	\$ 377	377	377	377	377	377	377	377	380	380	380	380	
.09	\$ 421	421	421	421	421	421	421	421	424	424	424	424	
.10	\$ 469	469	469	469	469	469	469	469	472	472	472	472	
.12	\$ 563	563	563	563	563	563	563	563	566	566	566	566	BALANCE POINT 24 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03	\$.04	\$.05	\$.06	\$.07	\$.08	\$.09	\$.10	\$.12					--ELECTRIC RATE \$/KWH
\$ 187	\$ 249	\$ 311	\$ 374	\$ 436	\$ 498	\$ 561	\$ 623	\$ 748					--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: COMPRESSOR SECTION 22536/425D36 INDOOR-H3A2/H3A21
COOLING CAPACITY AT 68 DEG.F. ENTERING WATER TEMP: -35200 BTU/H 14.4 COP
HEATING CAPACITY AT 20 DEG.F. ENTERING WATER TEMP: -42200 BTU/H 14.5 COP
FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 85% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
25,000													
.03	\$ 242	264	283	302	324	343	365	384	406	446	487	487	--THEORETICAL HEATING COST + FURNACE ONLY
.04	\$ 292	314	339	365	390	412	437	462	487	535	585	585	--THEORETICAL HEATING COST + FURNACE ONLY
.05	\$ 322	322	322	322	322	322	322	322	322	322	322	322	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 347	347	347	347	347	347	347	347	347	347	347	347	
.07	\$ 169	169	169	169	169	169	169	169	169	169	169	169	
.08	\$ 195	195	195	195	195	195	195	195	195	195	195	195	
.09	\$ 220	220	220	220	220	220	220	220	220	220	220	220	
.10	\$ 245	245	245	245	245	245	245	245	245	245	245	245	BALANCE POINT -15 DEG.F.
.12	\$ 292	292	292	292	292	292	292	292	292	292	292	292	
30,000													
.03	\$ 88	88	88	88	88	88	88	88	88	88	88	88	--THEORETICAL HEATING COST + FURNACE ONLY
.04	\$ 116	116	116	116	116	116	116	116	116	116	116	116	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 144	144	144	144	144	144	144	144	144	144	144	144	
.06	\$ 176	176	176	176	176	176	176	176	176	176	176	176	
.07	\$ 204	204	204	204	204	204	204	204	204	204	204	204	
.08	\$ 232	232	232	232	232	232	232	232	232	232	232	232	
.09	\$ 261	261	261	261	261	261	261	261	261	261	261	261	
.10	\$ 292	292	292	292	292	292	292	292	292	292	292	292	BALANCE POINT -2 DEG.F.
.12	\$ 349	349	349	349	349	349	349	349	349	349	349	349	
35,000													
.03	\$ 100	100	100	100	100	100	100	100	100	100	100	100	--THEORETICAL HEATING COST + FURNACE ONLY
.04	\$ 135	135	135	135	135	135	135	135	135	135	135	135	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 169	169	169	169	169	169	169	169	169	169	169	169	
.06	\$ 201	201	201	201	201	201	201	201	201	201	201	201	
.07	\$ 236	236	236	236	236	236	236	236	236	236	236	236	
.08	\$ 270	270	270	270	270	270	270	270	270	270	270	270	
.09	\$ 302	302	302	302	302	302	302	302	302	302	302	302	
.10	\$ 336	336	336	336	336	336	336	336	336	336	336	336	BALANCE POINT 7 DEG.F.
.12	\$ 402	402	402	402	402	402	402	402	402	402	402	402	
40,000													
.03	\$ 113	113	113	113	113	113	113	113	113	113	113	113	--THEORETICAL HEATING COST + FURNACE ONLY
.04	\$ 151	151	151	151	151	151	151	151	151	151	151	151	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 192	192	192	192	192	192	192	192	192	192	192	192	
.06	\$ 229	229	229	229	229	229	229	229	229	229	229	229	
.07	\$ 267	267	267	267	267	267	267	267	267	267	267	267	
.08	\$ 305	305	305	305	305	305	305	305	305	305	305	305	
.09	\$ 343	343	343	343	343	343	343	343	343	343	343	343	
.10	\$ 380	380	380	380	380	380	380	380	380	380	380	380	BALANCE POINT 15 DEG.F.
.12	\$ 456	456	456	456	456	456	456	456	456	456	456	456	
50,000													
.03	\$ 141	141	141	141	141	141	141	141	141	141	144	144	--THEORETICAL HEATING COST + FURNACE ONLY
.04	\$ 188	188	188	188	188	188	188	188	188	188	192	192	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 236	236	236	236	236	236	236	236	236	236	239	239	
.06	\$ 283	283	283	283	283	283	283	283	283	283	286	286	
.07	\$ 330	330	330	330	330	330	330	330	330	330	333	333	
.08	\$ 377	377	377	377	377	377	377	377	377	377	380	380	
.09	\$ 421	421	421	421	421	421	421	421	421	421	424	424	
.10	\$ 469	469	469	469	469	469	469	469	469	469	472	472	
.12	\$ 563	563	563	563	563	563	563	563	563	563	566	566	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .11 .12

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR 24HPQZ INDOOR H24QSL
 ARI RATED COOLING CAP.: BTUH 7851 - 33400 SEER 7.89
 ARI RATED HEATING CAP.: BTUH 1471 - 52000 COP 1.71 2.70+ HSPF 6.35 MIN.DHR REG IV
 BTUH (17) 14200 COP(17) 1.1.95 FURNACE EFFICIENCY 100.00% AFUE
 FURNACE TYPE ELECTRIC

HEAT LOSS
BTUH

ELEC.
COST
\$/KWH

15,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 62	125
.04	\$ 81	166
.05	\$ 103	210
.06	\$ 125	251
.07	\$ 144	295
.08	\$ 168	336
.09	\$ 189	377
.10	\$ 207	421
.12	\$ 248	506

BALANCE POINT 17 DEG.F.

20,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 78	166
.04	\$ 107	223
.05	\$ 132	280
.06	\$ 160	336
.07	\$ 188	393
.08	\$ 217	450
.09	\$ 242	506
.10	\$ 270	563
.12	\$ 324	676

BALANCE POINT 25 DEG.F.

25,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 100	210
.04	\$ 135	280
.05	\$ 166	349
.06	\$ 201	421
.07	\$ 232	491
.08	\$ 264	563
.09	\$ 302	632
.10	\$ 333	701
.12	\$ 399	843

BALANCE POINT 31 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 122	251
.04	\$ 160	336
.05	\$ 201	421
.06	\$ 245	506
.07	\$ 283	591
.08	\$ 324	676
.09	\$ 361	758
.10	\$ 406	843
.12	\$ 484	1013

BALANCE POINT 35 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 3
HEAT PUMP MODEL: OUTDOOR 24H002 INDOOR_H249S1
ARI RATED COOLING CAP.: BTUH 795 T-~~3200~~ SEER 7.89
ARI RATED HEATING CAP.: BTUH (47 T-~~3200~~) COP(47 T-~~10~~) HSPF_6.32 MIN.DHR REG IV
BTUH (17)-~~14200~~ COP(17)-~~1.45~~
FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY .65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	
15,000	\$ 75	88	97	110	119	132	141	154	163	176	198	220
												--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 62	62	62	62	62	62	62	62	62	62	62	
.04	\$ 81	81	81	81	81	81	81	81	81	81	81	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 103	103	103	103	103	103	103	103	103	103	103	
.06	\$ 122	122	122	122	122	122	122	122	122	122	122	
.07	\$ 144	144	144	144	144	144	144	144	144	144	144	
.08	\$ 163	163	163	163	163	163	163	163	163	163	163	
.09	\$ 185	185	185	185	185	185	185	185	185	185	185	
.10	\$ 207	207	207	207	207	207	207	207	207	207	207	
.12	\$ 248	248	248	248	248	248	248	248	248	248	248	BALANCE POINT 17 DEG.F.
20,000	\$ 100	116	132	147	160	176	192	204	220	236	264	295
												--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 81	81	81	81	84	84	84	84	84	84	88	
.04	\$ 107	107	107	107	110	110	110	110	110	110	113	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 132	132	132	132	135	135	135	135	135	135	138	
.06	\$ 160	160	160	160	163	163	163	163	163	163	166	
.07	\$ 185	185	185	185	188	188	188	188	188	188	192	
.08	\$ 210	210	210	210	214	214	214	214	214	214	217	
.09	\$ 236	236	236	236	239	239	239	239	239	239	242	
.10	\$ 264	264	264	264	267	267	267	267	267	267	270	
.12	\$ 314	314	314	314	317	317	317	317	317	317	321	BALANCE POINT 25 DEG.F.
25,000	\$ 129	147	163	182	201	220	239	258	277	295	330	368
												--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 100	100	103	103	107	107	110	110	113	113	116	122
.04	\$ 132	132	135	135	138	138	141	141	144	144	147	154
.05	\$ 160	160	163	163	166	166	169	169	173	173	176	182
.06	\$ 188	188	192	192	195	195	198	198	201	201	204	210
.07	\$ 220	220	223	223	226	226	229	229	232	232	236	242
.08	\$ 248	248	251	251	254	254	258	258	261	261	264	270
.09	\$ 280	280	283	283	286	286	289	289	292	292	295	302
.10	\$ 308	308	311	311	314	314	317	317	321	321	324	330
.12	\$ 368	368	371	371	374	374	377	377	380	380	384	390
30,000	\$ 154	176	198	220	242	264	286	308	330	352	399	443
												--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 119	125	129	135	138	144	147	154	157	163	173	182
.04	\$ 151	157	160	166	169	176	179	185	188	195	204	214
.05	\$ 179	185	188	195	198	204	207	214	217	223	232	242
.06	\$ 210	217	220	226	229	236	239	245	248	254	264	273
.07	\$ 239	245	248	254	258	264	267	273	277	283	292	302
.08	\$ 270	277	280	286	289	295	299	305	308	314	324	333
.09	\$ 299	305	308	314	317	324	327	333	336	343	352	361
.10	\$ 330	336	339	346	349	355	358	365	368	374	384	393
.12	\$ 390	396	399	406	409	415	418	424	428	434	443	453

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12
160 213 266 320 373 428 480 533 640

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 24HP02 INDOOR_H24Q51
ARI RATED COOLING CAP.: BTUH 795 7-23500 SEER 7.89
ARI RATED HEATING CAP.: BTUH (47) 24000, COP(47) 2.70, HSPF 6.35 MIN.DHR REG IV
BTUH (17) 1-14200, COP(17) 1.92
FURNACE TYPE FUEL_OIL FURNACE EFFICIENCY 85.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
15,000	\$ 157	173	192	207	223	239	254	270	286	317	349	384	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 62	62	62	62	62	62	62	62	62	62	62	62	
.04	\$ 81	81	81	81	81	81	81	81	81	81	81	81	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 103	103	103	103	103	103	103	103	103	103	103	103	
.06	\$ 125	125	125	125	125	125	125	125	125	125	125	125	
.07	\$ 144	144	144	144	144	144	144	144	144	144	144	144	
.08	\$ 166	166	166	166	166	166	166	166	166	166	166	166	
.09	\$ 185	185	185	185	185	185	185	185	185	185	185	185	
.10	\$ 207	207	207	207	207	207	207	207	207	207	207	207	BALANCE POINT 17 DEG.F.
.12	\$ 248	248	248	248	248	248	248	248	248	248	248	248	
20,000	\$ 210	232	254	277	295	317	339	361	384	424	469	509	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 81	81	81	81	81	81	81	81	81	81	81	81	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 110	110	110	110	110	110	110	110	110	110	110	110	
.05	\$ 135	135	135	135	135	135	135	135	135	135	135	135	
.06	\$ 163	163	163	163	163	163	163	163	163	163	163	163	
.07	\$ 188	188	188	188	188	188	188	188	188	188	188	188	
.08	\$ 217	217	217	217	217	217	217	217	217	217	217	217	
.09	\$ 242	242	242	242	242	242	242	242	242	242	242	242	
.10	\$ 270	270	270	270	270	270	270	270	270	270	270	270	BALANCE POINT 25 DEG.F.
.12	\$ 321	321	321	321	321	321	321	321	321	321	321	321	
25,000	\$ 264	292	317	346	371	399	424	453	478	531	585	639	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 103	103	103	103	107	107	107	107	110	110	113	113	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 135	135	135	135	138	138	138	138	141	141	144	144	
.05	\$ 166	166	166	166	169	169	169	169	173	173	176	176	
.06	\$ 198	198	198	198	201	201	201	201	204	204	207	207	
.07	\$ 229	229	229	229	232	232	232	232	236	236	239	239	
.08	\$ 261	261	261	261	264	264	264	264	267	267	270	270	
.09	\$ 292	292	292	292	295	295	295	295	299	299	302	302	
.10	\$ 324	324	324	324	327	327	327	327	330	330	333	333	BALANCE POINT 31 DEG.F.
.12	\$ 390	390	390	390	393	393	393	393	396	396	399	399	
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 129	132	132	135	138	141	141	144	147	151	154	160	
.04	\$ 163	166	166	169	173	176	176	178	182	185	188	195	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 201	204	204	207	210	214	214	217	220	223	226	232	
.06	\$ 236	239	239	242	245	248	248	251	254	258	261	267	
.07	\$ 270	273	273	277	280	283	283	286	289	292	295	302	
.08	\$ 305	308	308	311	314	317	317	321	324	327	330	336	
.09	\$ 343	346	346	349	352	355	355	358	361	365	368	374	
.10	\$ 377	380	380	384	387	390	390	393	396	399	402	409	BALANCE POINT 35 DEG.F.
.12	\$ 450	453	453	456	459	462	462	465	469	472	475	481	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

• 03	• 04	• 05	• 06	• 07	• 08	• 09	• 10	• 12	--ELECTRIC RATE \$/KWH
* 160	* 213	* 266	* 320	* 373	* 427	* 480	* 533	* 640	--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
15,000	\$ 144	157	169	182	195	204	217	229	242	267	292	292	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	62	62	62	62	62	62	62	62	62	62	62	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	81	81	81	81	81	81	81	81	81	81	81	
	+.05	103	103	103	103	103	103	103	103	103	103	103	
	+.06	125	125	125	125	125	125	125	125	125	125	125	
	+.07	144	144	144	144	144	144	144	144	144	144	144	
	+.08	166	166	166	166	166	166	166	166	166	166	166	
	+.09	185	185	185	185	185	185	185	185	185	185	185	
	+.10	207	207	207	207	207	207	207	207	207	207	207	BALANCE POINT 17 DEG.F.
	+.12	248	248	248	248	248	248	248	248	248	248	248	
20,000	\$ 195	210	226	242	258	273	292	308	324	355	390	390	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	81	81	81	81	81	81	81	81	81	81	81	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	110	110	110	110	110	110	110	110	110	110	110	
	+.05	135	135	135	135	135	135	135	135	135	135	135	
	+.06	163	163	163	163	163	163	163	163	163	163	163	
	+.07	188	188	188	188	188	188	188	188	188	188	188	
	+.08	217	217	217	217	217	217	217	217	217	217	217	
	+.09	242	242	242	242	242	242	242	242	242	242	242	
	+.10	270	270	270	270	270	270	270	270	270	270	270	BALANCE POINT 25 DEG.F.
	+.12	321	321	321	321	321	321	321	321	321	321	321	
25,000	\$ 242	264	283	302	324	343	365	384	406	446	487	487	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	100	100	103	103	103	103	107	107	107	110	110	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	132	132	135	135	135	135	138	138	138	141	141	
	+.05	163	163	166	166	166	166	169	169	169	173	173	
	+.06	195	195	198	198	198	198	201	201	201	204	204	
	+.07	226	226	229	229	229	229	232	232	232	236	236	
	+.08	258	258	261	261	261	261	264	264	264	267	267	
	+.09	289	289	292	292	292	292	295	295	295	299	299	
	+.10	321	321	324	324	324	324	327	327	327	330	330	BALANCE POINT 31 DEG.F.
	+.12	387	387	390	390	390	390	393	393	393	396	396	
30,000	\$ 292	314	339	365	390	412	437	462	487	535	585	585	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	125	129	132	132	135	135	138	141	144	147	147	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	160	163	166	166	169	169	173	173	176	179	182	
	+.05	198	201	204	204	207	207	210	214	217	220	220	
	+.06	232	236	239	239	242	242	245	245	248	251	254	
	+.07	267	270	273	273	277	277	280	280	283	286	289	
	+.08	302	305	308	308	311	311	314	314	317	321	324	
	+.09	339	343	346	346	349	349	352	352	355	358	361	
	+.10	374	377	380	380	384	384	387	387	390	393	396	
	+.12	446	450	453	453	456	456	459	459	462	465	469	BALANCE POINT 35 DEG.F.
		+.03	213	266	320	373	427	480	533	640			--ELECTRIC RATE \$/KWH --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 30HPQ4 INDOOR_H3AQ_QB_H3AQ1
ARI RATED COOLING CAP.: BTUH 75400 SEER 8.30
ARI RATED HEATING CAP.: BTUH (47) 20200 COP(17) 2.12 HSPF 6.20 MIN.DHR REG IV
BTUH (17) 20200 COP(17) 1.90 FURNACE EFFICIENCY 100.00% AFUE
FURNACE TYPE ELECTRIC

HEAT LOSS
BTUH ELEC.
COST
\$/KWH

20,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	78	166
.04	\$	107	223
.05	\$	132	280
.06	\$	160	336
.07	\$	185	393
.08	\$	214	450
.09	\$	239	506
.10	\$	267	563
.12	\$	321	676

BALANCE POINT 16 DEG.F.

25,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	97	210
.04	\$	129	280
.05	\$	163	349
.06	\$	195	421
.07	\$	226	491
.08	\$	261	563
.09	\$	292	632
.10	\$	324	701
.12	\$	390	843

BALANCE POINT 22 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	116	251
.04	\$	154	336
.05	\$	192	421
.06	\$	229	506
.07	\$	267	591
.08	\$	305	676
.09	\$	346	758
.10	\$	384	843
.12	\$	459	1013

BALANCE POINT 27 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	135	295
.04	\$	176	393
.05	\$	223	491
.06	\$	267	591
.07	\$	311	689
.08	\$	358	786
.09	\$	399	887
.10	\$	446	985
.12	\$	535	1183

BALANCE POINT 31 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	154	336
.04	\$	207	450
.05	\$	258	563
.06	\$	308	676
.07	\$	361	786
.08	\$	412	900
.09	\$	465	1013
.10	\$	516	1126
.12	\$	620	1353

BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12
191 255 318 382 446 510 573 637 765

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR_30HP04 INDOOR_H3402H340L
 ARI RATED COOLING CAP.: BTUH T95 29400 SEER 8.30
 ARI RATED HEATING CAP.: BTUH (17) 32000 COP(17) 2.75, HSPF 6.50 MIN.DHR REG IV
 BTUH 117 20200 COP(17) 1.90
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 85.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	
20,000	\$ 100	116	132	147	160	176	192	204	220	236	264	295
	•03	\$ 78	78	78	78	78	78	78	78	78	78	78
	•04	\$ 107	107	107	107	107	107	107	107	107	107	107
	•05	\$ 132	132	132	132	132	132	132	132	132	132	132
	•06	\$ 160	160	160	160	160	160	160	160	160	160	160
	•07	\$ 185	185	185	185	185	185	185	185	185	185	185
	•08	\$ 214	214	214	214	214	214	214	214	214	214	214
	•09	\$ 239	239	239	239	239	239	239	239	239	239	239
	•10	\$ 267	267	267	267	267	267	267	267	267	267	267
	•12	\$ 321	321	321	321	321	321	321	321	321	321	321
25,000	\$ 129	147	163	182	201	220	239	258	277	295	330	368
	•03	\$ 97	97	100	100	100	100	100	103	103	103	103
	•04	\$ 129	129	132	132	132	132	132	135	135	135	135
	•05	\$ 160	160	163	163	163	163	163	166	166	166	166
	•06	\$ 192	192	195	195	195	195	195	198	198	198	198
	•07	\$ 223	223	226	226	226	226	226	229	229	229	229
	•08	\$ 254	254	258	258	258	258	258	261	261	261	261
	•09	\$ 286	286	289	289	289	289	289	292	292	292	292
	•10	\$ 317	317	321	321	321	321	321	324	324	324	324
	•12	\$ 380	380	384	384	384	384	384	387	387	387	387
30,000	\$ 154	176	198	220	242	264	286	308	330	352	399	443
	•03	\$ 116	119	122	122	125	129	129	132	132	135	138
	•04	\$ 151	154	157	157	160	163	163	166	166	169	173
	•05	\$ 185	188	192	192	195	198	198	201	201	204	207
	•06	\$ 220	223	226	226	229	232	232	236	236	239	242
	•07	\$ 254	258	261	261	264	267	267	270	270	273	277
	•08	\$ 289	292	295	295	299	302	302	305	305	308	311
	•09	\$ 324	327	330	330	333	336	336	339	339	343	346
	•10	\$ 358	361	365	365	368	371	371	374	374	377	380
	•12	\$ 428	431	434	434	437	440	440	443	446	450	456
35,000	\$ 179	204	232	258	283	308	336	361	387	412	465	516
	•03	\$ 135	138	141	141	144	147	151	151	154	157	160
	•04	\$ 173	176	179	179	182	185	188	188	192	195	198
	•05	\$ 214	217	220	220	223	226	229	229	232	236	239
	•06	\$ 255	258	261	261	264	267	267	270	270	273	277
	•07	\$ 292	295	299	299	303	305	308	308	311	314	317
	•08	\$ 330	333	336	336	339	343	346	346	349	352	355
	•09	\$ 371	374	377	377	380	384	387	387	390	393	396
	•10	\$ 409	412	415	415	418	421	424	424	428	431	440
	•12	\$ 487	491	494	494	497	500	503	503	506	509	519
40,000	\$ 204	236	264	295	324	352	384	412	443	472	531	591
	•03	\$ 157	163	169	176	182	188	195	201	207	214	226
	•04	\$ 195	201	207	214	220	226	232	239	245	251	264
	•05	\$ 236	242	248	254	261	267	273	280	286	292	305
	•06	\$ 273	280	286	292	299	305	311	317	324	330	343
	•07	\$ 311	317	324	330	336	343	349	355	361	368	380
	•08	\$ 349	355	361	368	374	380	387	393	399	406	418
	•09	\$ 387	393	399	406	412	418	424	431	437	443	456
	•10	\$ 424	431	437	443	450	456	462	469	475	481	494
	•12	\$ 500	506	513	519	525	531	538	544	550	557	569

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03	\$.04	\$.05	\$.06	\$.07	\$.08	\$.09	\$.10	\$.11	<--ELECTRIC RATE \$/KWH		
\$ 191	255	318	382	446	510	573	637	765	<--THEORETICAL AIR CONDITIONING COST		

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 30HP04 INDOOR_H3AQ/H3AQ1
ARI RATED COOLING CAP.: BTUH 785 7-22000+ SEER 8-10
ARI RATED HEATING CAP.: BTUH (47) 1-2000+ COP(47) 2-125+ HSPF 6-50 MIN.DHR REG IV
BTUH (17) 1-20200+ COP(17) 1-90 FURNACE EFFICIENCY 65.00% AFUE
FURNACE TYPE FUEL_OIL

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
20,000													
.03	\$ 78	78	78	78	78	78	78	78	78	78	78	78	78
.04	\$ 107	107	107	107	107	107	107	107	107	107	107	107	107
.05	\$ 132	132	132	132	132	132	132	132	132	132	132	132	132
.06	\$ 160	160	160	160	160	160	160	160	160	160	160	160	160
.07	\$ 185	185	185	185	185	185	185	185	185	185	185	185	185
.08	\$ 214	214	214	214	214	214	214	214	214	214	214	214	214
.09	\$ 239	239	239	239	239	239	239	239	239	239	239	239	239
.10	\$ 267	267	267	267	267	267	267	267	267	267	267	267	267
.12	\$ 321	321	321	321	321	321	321	321	321	321	321	321	321
THEORETICAL HEATING COST + FURNACE ONLY													
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR													
25,000													
.03	\$ 97	97	97	97	97	97	97	97	97	97	97	97	100
.04	\$ 129	129	129	129	129	129	129	129	129	129	129	129	132
.05	\$ 163	163	163	163	163	163	163	163	163	163	163	163	166
.06	\$ 195	195	195	195	195	195	195	195	195	195	195	195	198
.07	\$ 226	226	226	226	226	226	226	226	226	226	226	226	229
.08	\$ 258	258	258	258	258	258	258	258	258	258	258	258	261
.09	\$ 292	292	292	292	292	292	292	292	292	292	292	292	295
.10	\$ 324	324	324	324	324	324	324	324	324	324	324	324	327
.12	\$ 390	390	390	390	390	390	390	390	390	390	390	390	393
THEORETICAL HEATING COST + FURNACE ONLY													
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR													
30,000													
.03	\$ 116	116	116	116	116	116	116	116	116	116	116	116	122
.04	\$ 154	154	154	154	154	154	154	154	154	154	154	154	160
.05	\$ 192	192	192	192	192	192	192	192	192	192	192	192	198
.06	\$ 229	229	229	229	229	229	229	229	229	229	229	229	236
.07	\$ 267	267	267	267	267	267	267	267	267	267	267	267	273
.08	\$ 305	305	305	305	305	305	305	305	305	305	305	305	311
.09	\$ 343	343	343	343	343	343	343	343	343	343	343	343	349
.10	\$ 380	380	380	380	380	380	380	380	380	380	380	380	387
.12	\$ 456	456	456	456	456	456	456	456	456	456	456	456	462
THEORETICAL HEATING COST + FURNACE ONLY													
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR													
35,000													
.03	\$ 135	138	138	138	141	141	141	144	144	144	147	151	151
.04	\$ 179	182	182	185	185	185	188	188	188	192	195	195	195
.05	\$ 220	223	223	226	226	226	229	229	229	232	236	236	236
.06	\$ 264	267	267	270	270	270	273	273	273	277	280	280	280
.07	\$ 305	308	308	311	311	311	314	314	314	317	321	321	321
.08	\$ 346	349	349	352	352	352	355	355	355	358	361	361	361
.09	\$ 390	393	393	396	396	396	399	399	399	402	406	406	406
.10	\$ 431	434	434	437	437	437	440	440	440	443	446	446	446
.12	\$ 516	519	519	522	522	522	525	525	525	528	531	531	531
THEORETICAL HEATING COST + FURNACE ONLY													
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR													
40,000													
.03	\$ 163	166	169	169	173	176	179	182	182	188	195	198	198
.04	\$ 210	214	217	217	220	223	226	229	229	236	242	245	245
.05	\$ 254	258	261	261	264	267	270	273	273	280	286	289	289
.06	\$ 302	305	308	308	311	311	314	314	314	321	327	333	336
.07	\$ 346	349	352	352	352	355	355	355	355	371	377	380	380
.08	\$ 393	396	399	399	402	406	409	412	412	418	424	428	428
.09	\$ 440	443	446	446	450	453	456	459	459	465	472	475	475
.10	\$ 484	487	491	491	494	497	500	503	503	509	516	519	519
.12	\$ 579	582	585	585	588	591	594	598	598	604	610	613	613
THEORETICAL HEATING COST + FURNACE ONLY													
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR													

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03	\$.04	\$.05	\$.06	\$.07	\$.08	\$.09	\$.10	\$.12					
\$ 191	\$ 255	\$ 316	\$ 382	\$ 446	\$ 510	\$ 573	\$ 637	\$ 765					

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION_2
 HEAT_PUMP_MODEL: OUTDOOR_30HPD4 INDOOR_H3AQ/H3AQ1---
 ARI_RATED_COOLING_CAP.: BTUH 7951-29000 SEER 8.10
 ARI_RATED_HEATING_CAP.: BTUH 1471-32000 COP(17) 2.72 4SPF .650 MIN.DHR REG IV
 BTUH 117 -20200 COP(17) 1.90
 FURNACE_TYPE PROpane_GAS FURNACE EFFICIENCY _65.00%_AEVE

HEAT LOSS BTUH	ELEC. COST \$/KWH	\$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
20,000	\$ 195	210	226	242	258	273	292	308	324	355	390	390	--THEORETICAL HEATING COST @ FURNACE ONLY
.03	\$ 78	78	78	78	78	78	78	78	78	78	78	78	
.04	\$ 107	107	107	107	107	107	107	107	107	107	107	107	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP
.05	\$ 132	132	132	132	132	132	132	132	132	132	132	132	\$ PER YEAR
.06	\$ 160	160	160	160	160	160	160	160	160	160	160	160	
.07	\$ 185	185	185	185	185	185	185	185	185	185	185	185	
.08	\$ 214	214	214	214	214	214	214	214	214	214	214	214	
.09	\$ 239	239	239	239	239	239	239	239	239	239	239	239	
.10	\$ 267	267	267	267	267	267	267	267	267	267	267	267	BALANCE POINT 16 DEG.F.
.12	\$ 321	321	321	321	321	321	321	321	321	321	321	321	
25,000	\$ 242	264	283	302	324	343	365	384	406	446	487	487	--THEORETICAL HEATING COST @ FURNACE ONLY
.03	\$ 97	97	97	97	97	97	97	97	97	97	97	97	
.04	\$ 129	129	129	129	129	129	129	129	129	129	129	129	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP
.05	\$ 163	163	163	163	163	163	163	163	163	163	163	163	\$ PER YEAR
.06	\$ 195	195	195	195	195	195	195	195	195	195	195	195	
.07	\$ 226	226	226	226	226	226	226	226	226	226	226	226	
.08	\$ 258	258	258	258	258	258	258	258	258	258	258	258	
.09	\$ 292	292	292	292	292	292	292	292	292	292	292	292	
.10	\$ 324	324	324	324	324	324	324	324	324	324	324	324	BALANCE POINT 22 DEG.F.
.12	\$ 390	390	390	390	390	390	390	390	390	390	390	390	
30,000	\$ 292	314	339	365	390	412	437	462	487	535	585	585	--THEORETICAL HEATING COST @ FURNACE ONLY
.03	\$ 116	116	116	116	116	116	119	119	119	119	119	119	
.04	\$ 154	154	154	154	154	154	157	157	157	157	157	157	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP
.05	\$ 192	192	192	192	192	192	195	195	195	195	195	195	\$ PER YEAR
.06	\$ 229	229	229	229	229	229	232	232	232	232	232	232	
.07	\$ 267	267	267	267	267	267	270	270	270	270	270	270	
.08	\$ 305	305	305	305	305	305	308	308	308	308	308	308	
.09	\$ 343	343	343	343	343	343	346	346	346	346	346	346	
.10	\$ 380	380	380	380	380	380	384	384	384	384	384	384	BALANCE POINT 27 DEG.F.
.12	\$ 456	456	456	456	456	456	459	459	459	459	459	459	
35,000	\$ 339	368	396	424	453	481	509	538	566	626	683	683	--THEORETICAL HEATING COST @ FURNACE ONLY
.03	\$ 135	135	138	138	138	141	141	141	141	144	144	144	
.04	\$ 179	179	182	182	182	185	185	185	185	188	188	188	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP
.05	\$ 220	220	223	223	223	226	226	226	226	229	229	229	\$ PER YEAR
.06	\$ 264	264	267	267	267	270	270	270	270	273	273	273	
.07	\$ 305	305	308	308	308	311	311	311	311	314	314	314	
.08	\$ 346	346	349	349	349	352	352	352	352	355	355	355	
.09	\$ 390	390	393	393	393	396	396	396	396	399	399	399	
.10	\$ 431	431	434	434	434	437	437	437	437	440	440	440	BALANCE POINT 31 DEG.F.
.12	\$ 516	516	519	519	519	522	522	522	522	525	525	525	
40,000	\$ 390	421	453	487	519	550	585	616	648	714	780	780	--THEORETICAL HEATING COST @ FURNACE ONLY
.03	\$ 160	163	163	166	169	169	173	176	176	179	185	185	
.04	\$ 207	210	210	214	217	220	223	223	226	232	232	232	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP
.05	\$ 251	254	254	258	261	261	264	267	267	270	277	277	\$ PER YEAR
.06	\$ 299	302	302	305	308	308	311	314	314	317	324	324	
.07	\$ 343	346	346	349	352	352	355	358	358	361	368	368	
.08	\$ 390	393	393	396	399	399	402	406	406	409	415	415	
.09	\$ 437	440	440	443	446	446	450	453	453	456	462	462	
.10	\$ 481	484	484	487	491	491	494	497	497	500	506	506	BALANCE POINT 34 DEG.F.
.12	\$ 576	579	579	582	585	585	588	591	591	594	601	601	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12 <--ELECTRIC RATE \$/KWH
 \$ 191 255 318 382 446 510 573 637 765 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 36HP04 INDOOR_H3AQ_OR_H3AQ1
ARI RATED COOLING CAP.: BTUH 751-16600 SEER 7.50
ARI RATED HEATING CAP.: BTUH (47)-20200 COP(17)-2.62 HSPF 6.40 MIN.DHR REG IV
BTUH (17)-24800 COP(17)-1.95
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS
BTUH ELEC.
 COST
 \$/KWH

--- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 103	210	
.04	\$ 138	280	
.05	\$ 173	349	
.06	\$ 201	421	
.07	\$ 242	491	
.08	\$ 277	563	
.09	\$ 311	632	
.10	\$ 346	701	BALANCE POINT 16 DEG.F.
.12	\$ 415	843	
--- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 122	251	
.04	\$ 163	336	
.05	\$ 204	421	
.06	\$ 245	506	
.07	\$ 286	591	
.08	\$ 324	676	
.09	\$ 365	758	
.10	\$ 406	843	BALANCE POINT 21 DEG.F.
.12	\$ 487	1013	
--- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 138	295	
.04	\$ 188	393	
.05	\$ 236	491	
.06	\$ 283	591	
.07	\$ 327	689	
.08	\$ 374	786	
.09	\$ 421	887	
.10	\$ 469	985	BALANCE POINT 25 DEG.F.
.12	\$ 563	1183	
--- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 157	336	
.04	\$ 214	450	
.05	\$ 264	563	
.06	\$ 321	676	
.07	\$ 371	786	
.08	\$ 428	900	
.09	\$ 478	1013	
.10	\$ 535	1126	BALANCE POINT 29 DEG.F.
.12	\$ 638	1353	
--- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 201	421	
.04	\$ 267	563	
.05	\$ 333	701	
.06	\$ 402	843	
.07	\$ 469	985	
.08	\$ 535	1126	
.09	\$ 604	1268	
.10	\$ 670	1407	
.12	\$ 802	1690	BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 36HPQ4 INDOOR_H3A2/H3A21----
ARI RATED COOLING CAP.: BTUH 795 1--36600--SEER 7.50
ARI RATED HEATING CAP.: BTUH (17) 40500; COP(17) 2.52+ HSPF 6.40 MIN.DHR REG TV
BTUH (17) 24800; COP(17) 1.95
FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										THEORETICAL HEATING COST + FURNACE ONLY	
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80		
25,000	\$ 129	147	163	182	201	220	239	258	277	295	330	368	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	\$ 103	103	103	103	103	103	103	103	103	103	103	
	\$.04	\$ 138	138	138	138	138	138	138	138	138	138	138	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	\$ 173	173	173	173	173	173	173	173	173	173	173	
	\$.06	\$ 207	207	207	207	207	207	207	207	207	207	207	
	\$.07	\$ 242	242	242	242	242	242	242	242	242	242	242	
	\$.08	\$ 277	277	277	277	277	277	277	277	277	277	277	
	\$.09	\$ 311	311	311	311	311	311	311	311	311	311	311	
	\$.10	\$ 346	346	346	346	346	346	346	346	346	346	346	
	\$.12	\$ 415	415	415	415	415	415	415	415	415	415	415	BALANCE POINT 16 DEG.F.
30,000	\$ 154	176	198	220	242	264	286	308	330	352	399	443	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	\$ 122	122	122	122	122	125	125	125	125	125	125	
	\$.04	\$ 160	160	160	160	160	163	163	163	163	163	163	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	\$ 201	201	201	201	201	204	204	204	204	204	204	
	\$.06	\$ 242	242	242	242	242	245	245	245	245	245	245	
	\$.07	\$ 283	283	283	283	283	286	286	286	286	286	286	
	\$.08	\$ 324	324	324	324	324	327	327	327	327	327	327	
	\$.09	\$ 365	365	365	365	365	368	368	368	368	368	368	
	\$.10	\$ 406	406	406	406	406	409	409	409	409	409	409	BALANCE POINT 21 DEG.F.
	\$.12	\$ 484	484	484	484	484	487	487	487	487	487	487	
35,000	\$ 179	204	232	258	283	308	336	361	387	412	465	516	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	\$ 141	141	141	141	144	144	144	147	147	147	151	
	\$.04	\$ 188	188	188	188	192	192	192	195	195	195	198	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	\$ 232	232	232	232	236	236	236	239	239	239	242	
	\$.06	\$ 277	277	277	277	280	280	280	283	283	283	286	
	\$.07	\$ 324	324	324	324	327	327	327	330	330	330	333	
	\$.08	\$ 368	368	368	368	371	371	371	374	374	374	377	
	\$.09	\$ 412	412	412	412	415	415	415	418	418	418	421	
	\$.10	\$ 459	459	459	459	462	462	462	465	465	465	469	BALANCE POINT 25 DEG.F.
	\$.12	\$ 550	550	550	550	554	554	554	557	557	557	560	
40,000	\$ 204	236	264	295	324	352	384	412	443	472	531	591	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	\$ 160	163	166	166	169	173	176	179	182	182	188	
	\$.04	\$ 210	214	217	217	220	223	226	229	232	232	239	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	\$ 259	261	264	264	267	270	273	277	280	280	286	
	\$.06	\$ 305	308	311	314	317	321	324	327	327	327	333	
	\$.07	\$ 352	355	358	358	361	365	368	371	374	374	380	
	\$.08	\$ 399	402	406	406	409	412	415	418	421	421	428	
	\$.09	\$ 446	450	453	453	456	459	462	465	469	469	481	
	\$.10	\$ 494	497	500	500	503	506	509	513	516	516	528	BALANCE POINT 29 DEG.F.
	\$.12	\$ 591	594	598	598	601	604	607	610	613	613	620	
50,000	\$ 258	295	330	368	406	443	478	516	554	591	664	739	--THEORETICAL HEATING COST + FURNACE ONLY
	\$.03	\$ 204	214	220	229	236	245	251	261	267	277	292	
	\$.04	\$ 254	264	270	280	286	295	302	311	317	327	343	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	\$.05	\$ 302	311	317	327	333	343	349	358	365	374	390	
	\$.06	\$ 352	361	368	377	384	393	399	409	415	424	440	
	\$.07	\$ 402	412	418	428	434	443	450	459	465	475	491	
	\$.08	\$ 453	462	469	478	484	494	500	509	516	525	541	
	\$.09	\$ 503	513	519	528	535	544	550	560	566	576	591	
	\$.10	\$ 554	563	569	579	585	594	601	610	616	626	642	BALANCE POINT 34 DEG.F.
	\$.12	\$ 654	664	670	679	686	695	701	711	727	742	759	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 \$.04 \$.05 \$.06 \$.07 \$.08 \$.09 \$.10 \$.12
--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR 36HP04 INDOOR_H3A2/H3A01
 ARI RATED COOLING CAP.: BTUH 7951 - 36600, SEER 7.50
 ARI RATED HEATING CAP.: BTUH (47) - 20500, COP(47) 2.62, HSPF 6.40 MIN.DHR REG IV
 BTUH (17) - 24500, COP(17) 1.95
 FURNACE TYPE FUEL_OIL FURNACE EFFICIENCY .65.003_AEVE

HEAT LOSS BTUH	ELEC. COST* \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
25,000	\$ 264	292	317	346	371	399	424	453	478	531	585	639	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 103	103	103	103	103	103	103	103	103	103	103	103	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 138	138	138	138	138	138	138	138	138	138	138	138	
.05	\$ 173	173	173	173	173	173	173	173	173	173	173	173	
.06	\$ 207	207	207	207	207	207	207	207	207	207	207	207	
.07	\$ 242	242	242	242	242	242	242	242	242	242	242	242	
.08	\$ 277	277	277	277	277	277	277	277	277	277	277	277	
.09	\$ 311	311	311	311	311	311	311	311	311	311	311	311	
.10	\$ 346	346	346	346	346	346	346	346	346	346	346	346	
.12	\$ 415	415	415	415	415	415	415	415	415	415	415	415	BALANCE POINT 16 DEG.F.
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 122	122	122	122	122	122	122	122	122	122	122	122	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 163	163	163	163	163	163	163	163	163	163	163	163	
.05	\$ 204	204	204	204	204	204	204	204	204	204	204	204	
.06	\$ 245	245	245	245	245	245	245	245	245	245	245	245	
.07	\$ 283	283	283	283	283	283	283	283	283	283	283	283	
.08	\$ 324	324	324	324	324	324	324	324	324	324	324	324	
.09	\$ 365	365	365	365	365	365	365	365	365	365	365	365	
.10	\$ 406	406	406	406	406	406	406	406	406	406	406	406	BALANCE POINT 21 DEG.F.
.12	\$ 487	487	487	487	487	487	487	487	487	487	487	487	
35,000	\$ 371	409	446	484	522	560	594	632	670	746	821	893	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 141	141	141	141	141	141	144	144	144	144	144	144	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 188	188	188	188	188	188	192	192	192	192	192	192	
.05	\$ 236	236	236	236	236	236	239	239	239	239	239	239	
.06	\$ 280	280	280	280	280	280	283	283	283	283	283	283	
.07	\$ 327	327	327	327	327	327	330	330	330	330	330	330	
.08	\$ 374	374	374	374	374	374	377	377	377	377	377	377	
.09	\$ 418	418	418	418	418	418	421	421	421	421	421	421	
.10	\$ 465	465	465	465	465	465	469	469	469	469	469	469	BALANCE POINT 25 DEG.F.
.12	\$ 557	557	557	557	557	557	560	560	560	560	560	560	
40,000	\$ 424	469	509	554	594	638	683	723	768	853	938	1023	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 163	163	163	166	166	166	169	169	169	173	173	176	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 214	214	214	217	217	217	220	220	220	223	223	226	
.05	\$ 267	267	267	270	270	270	273	273	273	277	277	280	
.06	\$ 317	317	317	321	321	321	324	324	324	327	327	330	
.07	\$ 368	368	368	371	371	371	374	374	374	377	377	380	
.08	\$ 418	418	418	421	421	421	424	424	424	428	428	431	
.09	\$ 472	472	472	475	475	475	478	478	478	481	481	484	
.10	\$ 522	522	522	525	525	525	528	528	528	531	531	535	
.12	\$ 626	626	626	629	629	629	632	632	632	635	635	638	BALANCE POINT 29 DEG.F.
50,000	\$ 531	585	638	692	746	799	853	906	960	1067	1174	1277	--THEORETICAL HEATING COST * FURNACE ONLY
.03	\$ 214	217	220	223	226	229	232	236	239	245	251	258	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 273	277	280	283	286	289	292	295	299	305	311	317	
.05	\$ 333	336	339	343	346	349	352	355	358	365	371	377	
.06	\$ 393	396	399	402	406	409	412	415	418	424	431	437	
.07	\$ 453	456	459	462	465	469	472	475	478	484	491	497	
.08	\$ 513	516	519	522	525	528	531	535	538	544	550	557	
.09	\$ 572	576	579	582	585	588	591	594	598	604	610	616	
.10	\$ 632	635	638	642	645	648	651	654	657	664	670	676	
.12	\$ 752	755	758	761	764	768	771	774	777	783	790	796	BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR 36HPQ4 INDOOR_H2A2ZH2A21
 ARI RATED COOLING CAP.: BTUH 795 1-36500, SEER 7±50
 ARI RATED HEATING CAP.: BTUH 147 1-40500, COP 147 1-2.62+, HSPF 6±40 MIN.DHR REG IV
 BTUH 117 1-24800, COP 117 1-1.95
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 65±00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
25,000	\$ 242	264	263	302	324	343	355	384	406	446	487	487	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 103	103	103	103	103	103	103	103	103	103	103	103	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 138	138	138	138	138	138	138	138	138	138	138	138	
.05	\$ 173	173	173	173	173	173	173	173	173	173	173	173	
.06	\$ 207	207	207	207	207	207	207	207	207	207	207	207	
.07	\$ 242	242	242	242	242	242	242	242	242	242	242	242	
.08	\$ 277	277	277	277	277	277	277	277	277	277	277	277	
.09	\$ 311	311	311	311	311	311	311	311	311	311	311	311	
.10	\$ 346	346	346	346	346	346	346	346	346	346	346	346	
.12	\$ 415	415	415	415	415	415	415	415	415	415	415	415	BALANCE POINT 16 DEG.F.
30,000	\$ 292	314	339	365	390	412	437	462	487	535	585	585	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 122	122	122	122	122	122	122	122	122	122	122	122	
.04	\$ 163	163	163	163	163	163	163	163	163	163	163	163	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 204	204	204	204	204	204	204	204	204	204	204	204	
.06	\$ 245	245	245	245	245	245	245	245	245	245	245	245	
.07	\$ 283	283	283	283	283	283	283	283	283	283	283	283	
.08	\$ 324	324	324	324	324	324	324	324	324	324	324	324	
.09	\$ 365	365	365	365	365	365	365	365	365	365	365	365	
.10	\$ 406	406	406	406	406	406	406	406	406	406	406	406	BALANCE POINT 21 DEG.F.
.12	\$ 487	487	487	487	487	487	487	487	487	487	487	487	
35,000	\$ 339	368	396	424	453	481	509	538	566	626	683	683	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 141	141	141	141	141	141	141	141	141	144	144	144	
.04	\$ 188	188	188	188	188	188	188	188	188	192	192	192	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 236	236	236	236	236	236	236	236	236	239	239	239	
.06	\$ 280	280	280	280	280	280	280	280	280	283	283	283	
.07	\$ 327	327	327	327	327	327	327	327	327	330	330	330	
.08	\$ 374	374	374	374	374	374	374	374	374	377	377	377	
.09	\$ 418	418	418	418	418	418	418	418	418	421	421	421	
.10	\$ 465	465	465	465	465	465	465	465	465	469	469	469	BALANCE POINT 25 DEG.F.
.12	\$ 557	557	557	557	557	557	557	557	557	560	560	560	
40,000	\$ 390	421	453	487	519	550	585	616	648	714	780	780	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 163	163	163	163	165	166	166	166	166	169	169	169	
.04	\$ 214	214	214	217	217	217	217	217	217	220	220	220	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 267	267	267	270	270	270	270	270	270	273	273	273	
.06	\$ 317	317	317	321	321	321	321	321	321	324	324	324	
.07	\$ 368	368	368	371	371	371	371	371	371	374	374	374	
.08	\$ 418	418	418	418	421	421	421	421	421	424	424	424	
.09	\$ 472	472	472	475	475	475	475	475	475	479	479	479	
.10	\$ 522	522	522	525	525	525	525	525	525	528	528	528	
.12	\$ 626	626	626	626	629	629	629	629	629	632	632	632	BALANCE POINT 29 DEG.F.
50,000	\$ 487	528	566	607	648	689	730	771	812	893	975	975	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 210	210	214	217	220	223	223	226	229	236	239	239	
.04	\$ 270	270	273	277	280	283	283	286	289	295	299	299	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 330	330	333	336	339	343	343	346	349	355	358	358	
.06	\$ 390	390	393	396	399	402	402	406	409	415	418	418	
.07	\$ 450	450	453	456	459	462	462	465	469	475	478	478	
.08	\$ 509	509	513	516	519	522	522	525	528	535	538	538	
.09	\$ 569	569	572	576	579	582	582	585	588	594	598	598	
.10	\$ 629	629	632	635	638	642	642	645	649	654	657	657	
.12	\$ 749	749	752	755	758	761	761	764	768	774	777	777	BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 42HPQ INDOOR H5AQ
ARI RATED COOLING CAP.: BTUH 795 42500 SEER 8.00
ARI RATED HEATING CAP.: BTUH (47) 41500, COP(47) 2.70, HSPF 6.25 MIN.DHR REG IV
BTUH (17) 24000, COP(17) 1.80
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS COST ELEC.
BTUH \$/KWH

25,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 103	210	
.04	\$ 138	280	
.05	\$ 173	349	
.06	\$ 204	421	
.07	\$ 239	491	
.08	\$ 273	563	
.09	\$ 308	632	
.10	\$ 343	701	BALANCE POINT 17 DEG.F.
.12	\$ 412	843	
30,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 119	251	
.04	\$ 160	336	
.05	\$ 201	421	
.06	\$ 242	506	
.07	\$ 283	591	
.08	\$ 324	676	
.09	\$ 361	758	
.10	\$ 402	843	BALANCE POINT 21 DEG.F.
.12	\$ 484	1013	
35,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 138	295	
.04	\$ 188	393	
.05	\$ 232	491	
.06	\$ 280	591	
.07	\$ 324	689	
.08	\$ 371	786	
.09	\$ 418	887	
.10	\$ 465	985	BALANCE POINT 25 DEG.F.
.12	\$ 560	1183	
40,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 157	336	
.04	\$ 210	450	
.05	\$ 264	563	
.06	\$ 317	676	
.07	\$ 368	786	
.08	\$ 424	900	
.09	\$ 475	1013	BALANCE POINT 28 DEG.F.
.10	\$ 528	1126	
.12	\$ 632	1353	
50,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
.03	\$ 198	421	
.04	\$ 264	563	
.05	\$ 333	701	
.06	\$ 396	843	
.07	\$ 462	985	
.08	\$ 531	1126	
.09	\$ 594	1268	BALANCE POINT 33 DEG.F.
.10	\$ 661	1407	
.12	\$ 796	1590	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

* .03 .04 .05 .06 .07 .08 .09 .10 .12
* 286 382 478 573 669 765 860 956 1147

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR_424PQ INDOOR_H5A9
 ARI RATED COOLING CAP.: BTUH(95) 42500 SEER 8.00
 ARI RATED HEATING CAP.: BTUH(47) 41200 COP(47) 2.70 HSPF 6.25 MIN.DHR REG IV
 BTUH(17) 25000 COP(17) 1.80
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 85.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	.35	.40	.45	NATURAL GAS	.50	.55	.60	.65	COST - \$/THERM	.70	.75	.80	.90	1.00
25,000	\$ 129	147	163	182	2D1	220	239	258	277	295	330	368	--THEORETICAL HEATING COST @ FURNACE ONLY		
	•.03	\$ 103	103	103	103	103	103	103	107	107	107	107	107		
	•.04	\$ 135	135	135	135	135	135	135	138	138	138	138	138	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP	
	•.05	\$ 169	169	169	169	169	169	169	173	173	173	173	173	\$ PER YEAR	
	•.06	\$ 204	204	204	204	204	204	204	207	207	207	207	207		
	•.07	\$ 239	239	239	239	239	239	239	242	242	242	242	242		
	•.08	\$ 273	273	273	273	273	273	273	277	277	277	277	277		
	•.09	\$ 308	308	308	308	308	308	308	311	311	311	311	311		
	•.10	\$ 339	339	339	339	339	339	339	343	343	343	343	343		
	•.12	\$ 409	409	409	409	409	409	409	412	412	412	412	412	BALANCE POINT 17 DEG.F.	
30,000	\$ 154	175	193	220	242	264	286	308	330	352	399	443	--THEORETICAL HEATING COST @ FURNACE ONLY		
	•.03	\$ 119	119	119	119	119	122	122	122	122	122	122	122		
	•.04	\$ 160	160	160	160	160	163	163	163	163	163	163	163	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP	
	•.05	\$ 201	201	201	201	201	204	204	204	204	204	204	204	\$ PER YEAR	
	•.06	\$ 242	242	242	242	242	245	245	245	245	245	245	245		
	•.07	\$ 280	280	280	280	280	283	283	283	283	283	283	283		
	•.08	\$ 321	321	321	321	321	324	324	324	324	324	324	324		
	•.09	\$ 361	361	361	361	361	365	365	365	365	365	365	365		
	•.10	\$ 402	402	402	402	402	406	406	406	406	406	406	406	BALANCE POINT 21 DEG.F.	
	•.12	\$ 481	481	481	481	481	484	484	484	484	484	484	484		
35,000	\$ 179	204	232	258	283	308	336	361	387	412	465	516	--THEORETICAL HEATING COST @ FURNACE ONLY		
	•.03	\$ 141	141	141	141	144	144	144	147	147	147	147	151		
	•.04	\$ 185	185	185	185	188	188	188	192	192	192	192	195	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP	
	•.05	\$ 229	229	229	229	232	232	232	236	236	236	236	239	\$ PER YEAR	
	•.06	\$ 273	273	273	273	277	277	277	277	280	280	280	283		
	•.07	\$ 321	321	321	321	324	324	324	324	327	327	327	330		
	•.08	\$ 365	365	365	365	368	368	368	371	371	371	371	374		
	•.09	\$ 409	409	409	409	412	412	412	415	415	415	415	418		
	•.10	\$ 453	453	453	453	456	456	456	459	459	459	459	462	BALANCE POINT 25 DEG.F.	
	•.12	\$ 544	544	544	544	547	547	547	550	550	550	550	554		
40,000	\$ 204	236	264	295	324	352	384	412	443	472	531	591	--THEORETICAL HEATING COST @ FURNACE ONLY		
	•.03	\$ 160	163	166	166	173	176	179	182	182	188	195			
	•.04	\$ 207	210	214	214	217	220	223	226	229	236	242		THEORETICAL HEATING COST @ FURN.+ HEAT PUMP	
	•.05	\$ 254	258	261	261	264	267	270	273	277	283	289		\$ PER YEAR	
	•.06	\$ 302	305	308	308	311	314	317	321	324	330	336			
	•.07	\$ 349	352	355	355	358	361	365	368	371	371	377	384		
	•.08	\$ 396	399	402	402	406	409	412	415	418	418	424	431		
	•.09	\$ 443	446	450	450	453	456	459	462	465	465	472	478		
	•.10	\$ 491	495	497	497	500	503	506	509	513	513	519	525	BALANCE POINT 28 DEG.F.	
	•.12	\$ 582	585	588	588	591	594	598	601	604	604	610	616		
50,000	\$ 258	295	330	368	406	443	478	516	554	591	664	739	--THEORETICAL HEATING COST @ FURNACE ONLY		
	•.03	\$ 201	210	217	226	232	242	248	258	264	273	289	305		
	•.04	\$ 248	258	264	273	280	289	295	305	311	321	336	352	THEORETICAL HEATING COST @ FURN.+ HEAT PUMP	
	•.05	\$ 299	308	314	324	330	339	346	355	361	371	387	402	\$ PER YEAR	
	•.06	\$ 349	358	365	374	380	390	396	406	412	421	437	453		
	•.07	\$ 396	406	412	421	428	437	443	453	459	469	484	500		
	•.08	\$ 446	456	462	472	478	487	494	503	509	519	535	550		
	•.09	\$ 494	503	509	519	525	535	541	550	557	566	582	598		
	•.10	\$ 544	554	560	569	576	585	591	601	607	616	632	648	BALANCE POINT 33 DEG.F.	
	•.12	\$ 642	651	657	667	673	683	689	698	705	714	730	746		

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

*03 .04 .05 .06 .07 .08 .09 .10 .11 .12
 384 383 378 373 449 365 360 356 317

<-ELECTRIC RATE \$/KWH
<-THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 52HPO INDOOR_H5AQ
ARI RATED COOLING CAP.: BTUH 795 1--42500+ SEER 8.00
ARI RATED HEATING CAP.: BTUH 117 1--41500+ COP(17) 1.21Q+ HSPF 6.25 MIN.DHR REG IV
BTUH 117 1--24000+ COP(17) 1.18Q+
FURNACE TYPE FUEL_OIL FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
25,000	\$ 264	292	317	346	371	399	424	453	478	531	585	639	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 103	103	103	103	103	103	103	103	103	103	103	103	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 138	139	139	138	138	138	138	138	138	138	138	138	
.05	\$ 173	173	173	173	173	173	173	173	173	173	173	173	
.06	\$ 204	204	204	204	204	204	204	204	204	204	204	204	
.07	\$ 239	239	239	239	239	239	239	239	239	239	239	239	
.08	\$ 273	273	273	273	273	273	273	273	273	273	273	273	
.09	\$ 308	308	308	308	308	308	308	308	308	308	308	308	
.10	\$ 343	343	343	343	343	343	343	343	343	343	343	343	
.12	\$ 412	412	412	412	412	412	412	412	412	412	412	412	BALANCE POINT 17 DEG.F.
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 119	119	119	119	119	119	119	119	119	119	119	122	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 160	160	160	160	160	160	160	160	160	160	160	163	
.05	\$ 201	201	201	201	201	201	201	201	201	201	201	204	
.06	\$ 242	242	242	242	242	242	242	242	242	242	242	245	
.07	\$ 283	283	283	283	283	283	283	283	283	283	283	286	
.08	\$ 324	324	324	324	324	324	324	324	324	324	324	327	
.09	\$ 361	361	361	361	361	361	361	361	361	361	361	365	
.10	\$ 402	402	402	402	402	402	402	402	402	402	402	406	BALANCE POINT 21 DEG.F.
.12	\$ 484	484	484	484	484	484	484	484	484	484	484	487	
35,000	\$ 371	409	446	484	522	560	594	632	670	746	821	893	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 141	141	141	141	141	144	144	144	144	144	144	147	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 185	185	185	185	185	188	188	188	188	188	188	192	
.05	\$ 232	232	232	232	232	236	236	236	236	236	236	239	
.06	\$ 277	277	277	277	277	280	280	280	280	280	280	283	
.07	\$ 324	324	324	324	324	327	327	327	327	327	327	330	
.08	\$ 371	371	371	371	371	374	374	374	374	374	374	377	
.09	\$ 415	415	415	415	415	418	418	418	418	418	418	421	
.10	\$ 462	462	462	462	462	465	465	465	465	465	465	469	BALANCE POINT 25 DEG.F.
.12	\$ 554	554	554	554	557	557	557	557	557	557	557	560	
40,000	\$ 424	469	509	554	594	638	683	723	768	853	938	1023	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 163	163	163	166	166	166	169	169	169	173	173	176	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 214	214	214	217	217	217	220	220	220	220	223	226	
.05	\$ 264	264	264	267	267	267	270	270	270	273	273	277	
.06	\$ 314	314	314	317	317	317	321	321	321	324	324	327	
.07	\$ 365	365	365	368	368	368	371	371	371	374	374	377	
.08	\$ 415	415	415	418	418	418	421	421	421	424	424	428	
.09	\$ 469	469	469	472	472	472	475	475	475	478	478	481	
.10	\$ 519	519	519	522	522	522	525	525	525	528	528	531	BALANCE POINT 28 DEG.F.
.12	\$ 620	620	620	623	623	623	626	626	626	629	629	632	
50,000	\$ 531	585	638	692	746	799	853	906	950	1067	1174	1277	--THEORETICAL HEATING COST + FURNACE ONLY
.03	\$ 210	214	217	220	223	226	229	229	232	239	245	251	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
.04	\$ 270	273	277	280	283	286	289	289	292	299	305	311	
.05	\$ 330	333	336	339	343	346	349	349	352	358	365	371	
.06	\$ 387	390	393	396	399	402	406	406	409	415	421	428	
.07	\$ 446	450	453	456	459	462	465	465	469	475	481	487	
.08	\$ 506	509	513	516	519	522	525	525	528	535	541	547	
.09	\$ 566	569	572	576	579	582	585	585	588	594	601	607	
.10	\$ 626	629	632	635	638	642	645	645	648	654	661	667	BALANCE POINT 33 DEG.F.
.12	\$ 746	749	752	755	758	761	764	764	768	774	780	786	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12 --ELECTRIC RATE \$/KWH
\$ 286 382 478 573 669 765 860 956 1147 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

SARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
 HEAT PUMP MODEL: OUTDOOR 42HPQ INDOOR H549
 ARI RATED COOLING CAP.: BTUH 7931-42500 SEER 8.04
 ARI RATED HEATING CAP.: BTUH (17) 41500 COP(17) 1.272, HSPF 6.25 MIN.DHR REG IV
 BTUH (17) 24000 COP(17) 1.08
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	.60	.65	.70	.75	.80	GAS COST - .85	.90	.95	1.00	1.10	1.20	1.30
25,000	\$ 242	264	283	302	324	343	365	384	405	446	487	487	--THEORETICAL HEATING COST @ FURNACE ONLY
	.03	\$ 103	103	103	103	103	103	103	103	103	103	103	103
	.04	\$ 138	138	138	138	138	138	138	138	138	138	138	138
	.05	\$ 173	173	173	173	173	173	173	173	173	173	173	173
	.06	\$ 204	204	204	204	204	204	204	204	204	204	204	204
	.07	\$ 239	239	239	239	239	239	239	239	239	239	239	239
	.08	\$ 273	273	273	273	273	273	273	273	273	273	273	273
	.09	\$ 308	308	308	308	308	308	308	308	308	308	308	308
	.10	\$ 343	343	343	343	343	343	343	343	343	343	343	343
	.12	\$ 412	412	412	412	412	412	412	412	412	412	412	412
30,000	\$ 292	314	339	365	390	412	437	462	487	535	585	585	--THEORETICAL HEATING COST @ FURNACE ONLY
	.03	\$ 119	119	119	119	119	119	119	119	119	119	119	119
	.04	\$ 160	160	160	160	160	160	160	160	160	160	160	160
	.05	\$ 201	201	201	201	201	201	201	201	201	201	201	201
	.06	\$ 242	242	242	242	242	242	242	242	242	242	242	242
	.07	\$ 283	283	283	283	283	283	283	283	283	283	283	283
	.08	\$ 324	324	324	324	324	324	324	324	324	324	324	324
	.09	\$ 361	361	361	361	361	361	361	361	361	361	361	361
	.10	\$ 402	402	402	402	402	402	402	402	402	402	402	402
	.12	\$ 484	484	484	484	484	484	484	484	484	484	484	484
35,000	\$ 339	368	396	424	453	491	509	538	566	626	683	683	--THEORETICAL HEATING COST @ FURNACE ONLY
	.03	\$ 141	141	141	141	141	141	141	144	144	144	144	144
	.04	\$ 185	185	185	185	185	185	185	188	188	188	188	188
	.05	\$ 232	232	232	232	232	232	232	236	236	236	236	236
	.06	\$ 277	277	277	277	277	277	277	280	280	280	280	280
	.07	\$ 324	324	324	324	324	324	324	327	327	327	327	327
	.08	\$ 371	371	371	371	371	371	371	374	374	374	374	374
	.09	\$ 415	415	415	415	415	415	415	418	418	418	418	418
	.10	\$ 462	462	462	462	462	462	462	465	465	465	465	465
	.12	\$ 554	554	554	554	554	554	557	557	557	557	557	557
40,000	\$ 390	421	453	487	519	550	585	615	648	714	780	780	--THEORETICAL HEATING COST @ FURNACE ONLY
	.03	\$ 163	163	163	163	163	166	166	166	166	169	169	169
	.04	\$ 214	214	214	214	214	217	217	217	217	220	220	220
	.05	\$ 264	264	264	264	264	267	267	267	267	270	270	270
	.06	\$ 314	314	314	314	314	317	317	317	317	321	321	321
	.07	\$ 365	365	365	365	365	368	368	368	368	371	371	371
	.08	\$ 415	415	415	415	415	418	418	418	418	421	421	421
	.09	\$ 469	469	469	469	469	472	472	472	472	475	475	475
	.10	\$ 519	519	519	519	519	522	522	522	522	525	525	525
	.12	\$ 620	620	620	620	623	623	623	623	626	626	626	626
50,000	\$ 487	528	566	607	648	689	730	771	812	893	975	975	--THEORETICAL HEATING COST @ FURNACE ONLY
	.03	\$ 207	210	210	214	217	220	226	226	229	236	236	236
	.04	\$ 257	270	270	273	277	280	280	283	286	289	295	295
	.05	\$ 327	330	330	333	336	339	339	343	346	349	355	355
	.06	\$ 384	387	387	390	393	396	396	399	402	406	412	412
	.07	\$ 443	446	446	450	453	456	456	459	462	465	472	472
	.08	\$ 503	506	506	509	513	516	516	519	525	531	531	531
	.09	\$ 563	566	566	569	572	576	576	579	582	591	591	591
	.10	\$ 623	626	626	629	632	635	635	635	642	651	651	651
	.12	\$ 742	746	749	752	755	755	758	761	764	771	771	771
													BALANCE POINT 33 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

.03 .04 .05 .06 .07 .08 .09 .10 .11 .12
 286 383 478 573 669 765 860 956 1152

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 48H2Q2 INDOOR_H5AQ
ARI RATED COOLING CAP.: BTUH 1957 - 46500, SEER 8.10
ARI RATED HEATING CAP.: BTUH (47) - 44000, COP(47) 1.260, HSPF 6.12 MIN.DHR REG IV
BTUH (17) - 26800, COP(17) 1.08
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS COST
BTUH \$/KWH

30,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 125	251
.04	\$ 169	336
.05	\$ 210	421
.06	\$ 254	506
.07	\$ 295	591
.08	\$ 339	676
.09	\$ 380	758
.10	\$ 424	843
.12	\$ 506	1013

BALANCE POINT 19 DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 144	295
.04	\$ 195	393
.05	\$ 242	491
.06	\$ 292	591
.07	\$ 343	689
.08	\$ 390	786
.09	\$ 440	887
.10	\$ 487	985
.12	\$ 585	1183

BALANCE POINT 23 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 166	336
.04	\$ 220	450
.05	\$ 273	563
.06	\$ 327	676
.07	\$ 387	786
.08	\$ 440	900
.09	\$ 494	1013
.10	\$ 547	1126
.12	\$ 661	1353

BALANCE POINT 27 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 204	421
.04	\$ 273	563
.05	\$ 343	701
.06	\$ 409	843
.07	\$ 478	985
.08	\$ 544	1126
.09	\$ 613	1268
.10	\$ 683	1407
.12	\$ 818	1690

BALANCE POINT 32 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$ 248	506
.04	\$ 330	676
.05	\$ 412	843
.06	\$ 497	1013
.07	\$ 579	1183
.08	\$ 664	1353
.09	\$ 749	1520
.10	\$ 831	1690
.12	\$ 997	2030

BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12
\$ 309 413 516 619 723 826 929 1033 1239

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2		INDOOR_H5AQ											
HEAT PUMP MODEL: OUTDOOR 48HPQ2		INDOOR_H5AQ											
ARI RATED COOLING CAP.: BTUH 705 T-25500, SEER 8.10		BTUH (17) - 24000, COP(17) 2.60, HSPF 6.15 MIN.DHR REG IV											
FURNACE TYPE NATURAL GAS		FURNACE EFFICIENCY - 65.00% AFUE											
HEAT LOSS BTUH	ELEC. COST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
30,000	\$ 154	176	198	220	242	264	286	308	330	352	399	443	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	125	125	125	125	125	129	129	129	129	129	129	129
	+.04	166	166	166	166	166	169	169	169	169	169	169	169
	+.05	210	210	210	210	210	214	214	214	214	214	214	214
	+.06	251	251	251	251	251	254	254	254	254	254	254	254
	+.07	295	295	295	295	295	299	299	299	299	299	299	299
	+.08	336	336	336	336	336	339	339	339	339	339	339	339
	+.09	377	377	377	377	377	380	380	380	380	380	380	380
	+.10	421	421	421	421	421	424	424	424	424	424	424	424
	+.12	503	503	503	503	503	506	506	506	506	506	506	506
													BALANCE POINT 19 DEG.F.
35,000	\$ 179	204	232	258	283	308	336	361	387	412	465	516	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	147	167	147	147	151	151	151	151	154	154	154	157
	+.04	195	195	195	195	198	198	198	198	201	201	201	204
	+.05	242	242	242	242	245	245	245	245	248	248	248	251
	+.06	289	289	289	289	292	292	292	292	295	295	295	299
	+.07	336	336	336	336	339	339	339	339	343	343	343	346
	+.08	384	384	384	384	387	387	387	387	390	390	390	393
	+.09	431	431	431	431	434	434	434	434	437	437	437	440
	+.10	478	478	478	478	481	481	481	481	484	484	484	487
	+.12	572	572	572	572	576	576	576	579	579	579	579	582
													BALANCE POINT 23 DEG.F.
40,000	\$ 204	236	264	295	324	352	384	412	443	472	531	591	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	166	169	173	173	176	179	182	185	188	188	195	201
	+.04	217	220	223	223	226	229	232	236	239	239	245	251
	+.05	267	270	273	273	277	280	283	286	289	289	295	302
	+.06	314	317	321	321	324	327	330	333	336	336	343	349
	+.07	365	368	371	371	374	377	380	384	387	387	393	399
	+.08	415	418	421	421	424	428	431	434	437	437	443	450
	+.09	465	469	472	472	475	478	481	484	487	487	494	500
	+.10	513	516	519	519	522	525	528	531	535	535	541	547
	+.12	613	616	620	620	623	626	629	632	635	635	642	648
													BALANCE POINT 27 DEG.F.
50,000	\$ 258	295	330	368	406	443	478	516	554	591	664	739	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	207	217	223	232	239	248	254	264	270	280	295	311
	+.04	261	270	277	286	292	302	308	317	324	333	349	365
	+.05	311	321	327	336	343	352	358	368	374	384	399	415
	+.06	365	374	380	390	396	406	412	421	428	437	453	469
	+.07	415	424	431	440	446	456	462	472	478	487	503	519
	+.08	469	478	484	494	500	509	516	525	531	541	557	572
	+.09	519	526	535	544	550	560	566	576	582	591	607	623
	+.10	572	582	588	598	604	613	620	629	635	645	661	676
	+.12	673	683	689	698	705	714	720	730	736	746	761	777
													BALANCE POINT 32 DEG.F.
60,000	\$ 308	352	399	443	487	531	576	620	664	708	799	887	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	248	258	267	277	286	295	305	314	324	333	352	371
	+.04	308	317	327	336	346	355	365	374	384	393	412	431
	+.05	368	377	387	396	406	415	424	434	443	453	472	491
	+.06	428	437	446	456	465	475	484	494	503	513	531	550
	+.07	491	500	509	519	528	538	547	557	566	576	594	613
	+.08	550	560	569	579	588	598	607	616	626	635	654	673
	+.09	610	620	629	638	648	657	667	676	686	695	714	733
	+.10	670	679	689	698	708	717	727	736	746	755	774	793
	+.12	793	802	812	821	831	840	849	859	868	878	897	916

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 48HPQZ INDOOR H5AQ
ARI RATED COOLING CAP.: BTUH 7927 - 56300 SEER 8+10
ARI RATED HEATING CAP.: BTUH 1471 - 44000 COP(47) 2.60+ HSPF 6+15 MIN.DHR REG IV
BTUH (17) - 26800 COP(17) 1.25
FURNACE TYPE FUEL_OIL FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
30,000	\$ 317	349	384	415	446	478	509	541	576	638	701	768	--THEORETICAL HEATING COST > FURNACE ONLY
.03	\$ 125	125	125	125	125	125	125	125	125	125	125	125	
.04	\$ 169	169	169	169	169	169	169	169	169	169	169	169	THEORETICAL HEATING COST > FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 210	210	210	210	210	210	210	210	210	210	210	210	
.06	\$ 254	254	254	254	254	254	254	254	254	254	254	254	
.07	\$ 295	295	295	295	295	295	295	295	295	295	295	295	
.08	\$ 339	339	339	339	339	339	339	339	339	339	339	339	
.09	\$ 380	380	380	380	380	380	380	380	380	380	380	380	
.10	\$ 421	421	421	421	421	421	421	421	421	421	421	421	BALANCE POINT 19 DEG.F.
.12	\$ 506	506	506	506	506	506	506	506	506	506	506	506	
35,000	\$ 371	409	446	484	522	560	594	632	670	746	821	893	--THEORETICAL HEATING COST > FURNACE ONLY
.03	\$ 147	147	147	147	147	147	147	147	147	147	147	147	
.04	\$ 195	195	195	195	195	195	195	195	195	195	195	195	THEORETICAL HEATING COST > FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 245	245	245	245	245	245	245	245	245	245	245	245	
.06	\$ 292	292	292	292	292	292	292	292	292	292	292	292	
.07	\$ 339	339	339	339	339	339	339	339	339	339	339	339	
.08	\$ 390	390	390	390	390	390	390	390	390	390	390	390	
.09	\$ 437	437	437	437	437	437	437	437	437	437	437	437	
.10	\$ 487	487	487	487	487	487	487	487	487	487	487	487	BALANCE POINT 23 DEG.F.
.12	\$ 582	582	582	582	582	582	582	582	582	582	582	582	
40,000	\$ 424	469	509	554	594	638	683	723	768	853	938	1023	--THEORETICAL HEATING COST > FURNACE ONLY
.03	\$ 163	166	166	166	166	166	166	166	166	166	166	166	
.04	\$ 220	223	223	223	223	223	223	223	223	223	223	223	THEORETICAL HEATING COST > FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 273	277	277	277	277	277	277	277	277	277	277	277	
.06	\$ 327	330	330	330	330	330	330	330	330	330	330	330	
.07	\$ 380	384	384	384	384	384	384	384	384	384	384	384	
.08	\$ 434	437	437	437	437	437	437	437	437	437	437	437	
.09	\$ 487	491	491	491	491	491	491	491	491	491	491	491	
.10	\$ 544	547	547	547	547	547	547	547	547	550	550	550	BALANCE POINT 27 DEG.F.
.12	\$ 651	654	654	654	654	654	654	654	654	657	657	657	
50,000	\$ 531	585	638	692	746	799	853	906	960	1067	1174	1277	--THEORETICAL HEATING COST > FURNACE ONLY
.03	\$ 214	214	217	220	223	223	226	229	229	236	239	242	
.04	\$ 277	277	280	283	286	286	289	292	292	292	299	302	THEORETICAL HEATING COST > FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 339	339	343	346	349	349	352	355	355	361	365	368	
.06	\$ 402	402	406	409	412	412	415	418	418	424	428	431	
.07	\$ 465	465	469	472	475	475	478	481	481	487	491	494	
.08	\$ 531	531	535	538	541	541	544	547	547	554	557	560	
.09	\$ 594	594	598	601	604	604	607	610	610	616	620	623	
.10	\$ 657	657	661	664	667	667	670	673	673	679	683	686	
.12	\$ 783	783	786	790	793	793	796	799	799	805	808	812	BALANCE POINT 32 DEG.F.
60,000	\$ 638	701	768	831	893	960	1023	1085	1152	1277	1407	1536	--THEORETICAL HEATING COST > FURNACE ONLY
.03	\$ 267	270	277	283	286	292	299	302	308	317	330	339	
.04	\$ 339	343	349	355	358	371	374	380	390	402	412		THEORETICAL HEATING COST > FURN.+ HEAT PUMP \$ PER YEAR
.05	\$ 409	412	418	424	428	434	440	443	450	459	472	481	
.06	\$ 481	484	491	497	500	506	513	516	522	531	544	554	
.07	\$ 550	554	560	566	569	576	582	585	591	601	613	623	
.08	\$ 623	626	632	638	642	648	654	657	664	673	686	695	
.09	\$ 695	698	705	711	714	720	727	730	736	746	758	768	
.10	\$ 764	768	774	780	783	790	796	799	805	815	827	837	
.12	\$ 909	912	919	925	928	934	941	944	950	960	972	982	BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 2
HEAT PUMP MODEL: OUTDOOR 48HPQ2 INDOOR_H2A2
ARI RATED COOLING CAP.: BTUH 795 T-26000, SEER 8.10
ARI RATED HEATING CAP.: BTUH 147 F-26000, COP(17) 2.60, HSPF 6.15 MIN.DHR REG IV
BTUH 117 F-26000, COP(17) 2.65
FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 65.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON										
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20
30,000												
.03	\$ 292	314	339	365	390	412	437	462	487	513	585	685
.04	\$ 125	125	125	125	125	125	125	125	125	125	125	125
.05	\$ 169	169	169	169	169	169	169	169	169	169	169	169
.06	\$ 210	210	210	210	210	210	210	210	210	210	210	210
.07	\$ 254	254	254	254	254	254	254	254	254	254	254	254
.08	\$ 295	295	295	295	295	295	295	295	295	295	295	295
.09	\$ 339	339	339	339	339	339	339	339	339	339	339	339
.10	\$ 380	380	380	380	380	380	380	380	380	380	380	380
.12	\$ 506	506	506	506	506	506	506	506	506	506	506	506
THEORETICAL HEATING COST + FURNACE ONLY												
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR												
BALANCE POINT 19 DEG.F.												
35,000												
.03	\$ 339	368	396	424	453	481	509	538	566	626	683	683
.04	\$ 147	147	147	147	147	147	147	147	147	147	147	147
.05	\$ 195	195	195	195	195	195	195	195	195	195	195	195
.06	\$ 245	245	245	245	245	245	245	245	245	245	245	245
.07	\$ 292	292	292	292	292	292	292	292	292	292	292	292
.08	\$ 339	339	339	339	339	339	339	339	339	339	339	339
.09	\$ 390	390	390	390	390	390	390	390	390	390	390	390
.10	\$ 437	437	437	437	437	437	437	437	437	437	437	437
.12	\$ 582	582	582	582	582	582	582	582	582	582	582	582
THEORETICAL HEATING COST + FURNACE ONLY												
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR												
BALANCE POINT 23 DEG.F.												
40,000												
.03	\$ 390	421	453	487	519	550	585	616	648	714	780	780
.04	\$ 163	163	166	166	166	166	166	166	166	166	169	169
.05	\$ 220	220	223	223	223	223	223	223	223	223	226	226
.06	\$ 273	273	277	277	277	277	277	277	277	277	280	280
.07	\$ 327	327	330	330	330	330	330	330	330	330	333	333
.08	\$ 380	380	384	384	384	384	384	384	384	387	387	387
.09	\$ 434	434	437	437	437	437	437	437	437	437	440	440
.10	\$ 487	487	487	487	487	487	487	487	487	487	487	487
.12	\$ 651	651	654	654	654	654	654	654	654	657	657	657
THEORETICAL HEATING COST + FURNACE ONLY												
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR												
BALANCE POINT 27 DEG.F.												
50,000												
.03	\$ 487	528	566	607	648	689	730	771	812	893	975	975
.04	\$ 210	214	214	217	217	220	220	223	223	226	229	229
.05	\$ 273	277	277	280	280	283	283	286	286	289	292	292
.06	\$ 336	339	339	343	343	346	346	349	349	352	355	355
.07	\$ 399	402	402	406	406	409	409	412	412	415	418	418
.08	\$ 462	465	465	469	469	472	472	475	475	478	481	481
.09	\$ 528	531	531	535	535	538	538	541	541	544	547	547
.10	\$ 591	594	594	598	598	601	601	604	604	607	610	610
.12	\$ 780	783	783	786	786	790	790	793	793	796	799	799
THEORETICAL HEATING COST + FURNACE ONLY												
THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR												
BALANCE POINT 32 DEG.F.												
60,000												
.03	\$ 585	632	683	730	780	827	878	925	975	1073	1170	1170
.04	\$ 261	264	270	273	277	283	286	289	292	302	308	308
.05	\$ 333	336	343	346	349	355	358	361	365	374	380	380
.06	\$ 402	406	412	415	418	424	428	431	434	443	450	450
.07	\$ 475	478	484	487	491	497	500	503	506	516	522	522
.08	\$ 616	620	626	629	632	638	642	645	648	657	664	664
.09	\$ 689	692	698	701	705	711	714	717	720	730	736	736
.10	\$ 758	761	768	771	774	780	783	786	790	799	805	805
.12	\$ 903	906	912	916	919	925	928	931	934	944	950	950
<--ELECTRIC RATE \$/KWH												
<--THEORETICAL AIR CONDITIONING COST												

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.