

DUAL FUEL ADD-ON HEAT PUMP GUIDE FOR OPERATIONAL COST SAVINGS

REGION 5

BARD MANUFACTURING COMPANY, BOX 607, BRYAN, OHIO 43506

(419) 636-1194

**MANUAL 2100-073 REV. D
SUPERSEDES REV. C**




TABLE OF CONTENTS

General Description	i
How To use	ii

Heat Pump Outdoor Model	Heat Pump Indoor Model	Furnace Fuel	Furnace AFUE Efficiency Rating	Page
WQS30A	A36AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	1 2 3 4
WQS36A	A36AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	5 6 7 8
WQS42A	A42AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	9 10 11 12
24UHPQA	A30AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	13 14 15 16
24UHPQB	A36AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	17 18 19 20
30UHPQB	A36AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	21 22 23 24
30UHPQB	A37AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	25 26 27 28
36UHPQB	A36AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	29 30 31 32
36UHPQB	A37AQ-A	Electric Natural Gas Oil Propane	100% 78% 78% 78%	33 34 35 36

TABLE OF CONTENTS

Heat Pump Outdoor Model	Heat Pump Indoor Model	Furnace Fuel	Furnace AFUE Efficiency Rating	Page
42UHPQA	A61AQ-A	Electric	100%	37
		Natural Gas	78%	38
		Oil	78%	39
		Propane	78%	40
48UHPQB	A61AQ-A	Electric	100%	41
		Natural Gas	78%	42
		Oil	78%	43
		Propane	78%	44
60UHPQB	A61AQ-A	Electric	100%	45
		Natural Gas	78%	46
		Oil	78%	47
		Propane	78%	48

GENERAL DESCRIPTION

WHAT DOES THIS GUIDE SHOW?

This operational cost savings guide has been prepared to show theoretical cost savings for Bard dual fuel "add-on" heat pumps when used with either existing or new furnaces. It covers add-on applications for electric, oil, propane gas and natural gas type forced air furnaces. It includes both air source heat pumps and ground water source heat pumps at many combinations of gas, oil and electrical rates. It enables the user not only to make a theoretical operating cost comparison at today's fuel costs but also at future estimated higher energy costs.

It is important to understand that this is a theoretical comparison between fuels. Actual operation costs can vary depending on many difficult to predict variables such as the actual design heating or cooling load, air infiltration, and wind effects, solar effect, efficiency of existing furnace, severity of weather for a given heating or cooling season and also individual usage pattern.

SPECIAL FEATURE--FUEL SAVER MODULE

These estimates utilize the Bard Fuel Saver Module which permit the heat pump to operate below the balance point to maximize the energy savings. For each application an analysis should be made to determine the economic balance point which is the outdoor temperature at which it becomes more cost effective to shut the heat pump down with an outdoor thermostat. This temperature varies with each combination of fuel cost and furnace and heat pump efficiency level. Refer to tables included in the instructions with the Fuel Saver Module.

FURNACE EFFICIENCY

For purposes of these cost estimates, furnace efficiency levels of 100% AFUE for electric, 78% AFUE for natural and propane gas and 78% AFUE for oil was chosen. We recognize that any variation in efficiency from these values will change the operating cost somewhat. These values were chosen to best represent typical efficiency levels of most equipment in the field today.

HOW TO USE DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

1. Determine the heating Btuh loss and cooling Btuh gain for structure using a Bard "Whole-House Heat Loss and Gain Work Sheet," Form B008, ACCA "Load Calculation," Manual J.
 - a. Heating house Btuh loss is _____.
 - b. Cooling house Btuh gain is _____.
2. Determine the type of fuel available at structure (what type of {fuel} heating system is already there).
 - a. Electricity
 - b. Natural Gas
 - c. Propane Gas
 - d. Fuel Oil
 - e. Good water supply and disposal
3. Call local utilities and determine area energy costs.
 - a. Electricity _____ \$Kilowatt-hour
 - b. Natural Gas _____ \$/Therm
 - c. Propane Gas _____ \$/Gallon
 - d. Fuel Oil _____ \$/Gallon

4. Tentatively select an add-on heat pump system using Bard Manual 2100-057, "Heat Pump Sizing" as a guide, and a Bard equipment catalog.

- a. Air to air heat pump

Model _____ Indoor Coil _____
Btuh _____ Heat Btuh _____ Cool

- b. Water to air

Model _____ Indoor Coil _____
Btuh _____ Heat Btuh _____ Cool

5. Determine heating region where the structure is located. To do this, find the geographic location of house on regional heating load hours map. A map is located inside the front cover of this guide.

- A. Region structure is located _____.

YOU ARE NOW READY TO USE THE "DUAL FUEL ADD-ON HEAT PUMP GUIDE"

6. Select the "Dual Fuel Add-On Heat Pump Guide" for the region the structure is located. (See step 5 above.)

7. Locate the add-on heat pump model or models you tentatively selected (Step 4) in the "Guide." Refer to Table of Contents.

EXAMPLE: 36UHPQA w/A36AQ-A Indoor Coll

8. Now locate the furnace type by fuel used (Step 2).

EXAMPLE: A fuel oil furnace with AFUE of 78%.

9. You now have located the page or pages that will help you determine annual operating cost. See example--Figure 1.

- A. Locate the closest structure loss in Btuh column on left side of page (step 1).

EXAMPLE: 70,000 Btuh Heat Loss

- B. Locate the heating cost per unit at top of page (step 3).

EXAMPLE: \$1.40 per gallon fuel oil

- C. Now read down the fuel cost column until directly across from the structure heat loss in Btuh. This will be the theoretical annual heating cost using only the furnace.

EXAMPLE: 70,000 Btuh heat loss @ \$1.40 per gallon fuel oil, the annual cost will be \$1,912.

- D. Next locate the electric cost \$/KW under Heat Loss Btuh for structure (step 3).

EXAMPLE: \$.06 KW rate

- E. Now once again read down the fuel cost column until directly across from electric cost \$/KW. You now have located the annual heating cost for the house using an add-on heat pump with the furnace.

EXAMPLE: 70,000 Btuh structure heat loss, with \$.06 KW cost and \$1.40 per gallon fuel oil. The annual cost using a 36UHPQA Bard heat pump with the oil furnace would be \$1,613 for an annual savings of \$299 (\$1,912 minus \$1,613).

Now repeat steps 8 through 9 for each type fuel and/or heat pump selected. This will enable you to select the best combination of furnace and heat pump to use for a structure.

7. Locate the add-on heat pump model or models you tentatively selected (Step 4) in the "Guide." Refer to Table of Contents.

EXAMPLE: 36UHPQA w/A36AO-A Indoor Coil

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5	36UHPQA/A36AO-A
HEAT PUMP MODEL: OUTDOOR 36UHPQA	INDOOR A36AO-A
ARI RATED COOLING CAP.: BTUH(95) 33000, SEER 8.69	
ARI RATED HEATING CAP.: BTUH (47) 33600, COP(47) 2.90, EER 6.90 MIN.DRR REG IV	
BTUH (17) 20000, COP(17) 2.20	

8. Now locate the furnace type by fuel used (Step 2).

EXAMPLE: A fuel oil furnace with AFUE of 78%.

FURNACE TYPE FUEL OIL

FURNACE EFFICIENCY 78.00 % AFUE

9. You now have located the page or pages that will help you determine annual operating cost. See example--Figure 1.

- A. Locate the closest structure loss in Btuh column on left side of page (step 1).

EXAMPLE: 70,000 Btuh Heat Loss

- B. Locate the heating cost per unit at top of page (step 3).

EXAMPLE: \$1.40 per gallon fuel oil

- C. Now read down the fuel cost column until directly across from the structure heat loss in Btuh. This will be the theoretical annual heating cost using only the furnace.

EXAMPLE: 70,000 Btuh heat loss @ \$1.40 per gallon fuel oil, the annual cost will be \$1,912.

- D. Next locate the electric cost \$/KW under Heat Loss Btuh for structure (step 3).

EXAMPLE: \$.06 KW rate

- E. Now once again read down the fuel cost column until directly across from electric cost \$/KW. You now have located the annual heating cost for the house using an add-on heat pump with the furnace.

EXAMPLE: 70,000 Btuh structure heat loss, with \$.06 KW cost and \$1.40 per gallon fuel oil. The annual cost using a 36UHPQA Bard heat pump with the oil furnace would be \$1,613 for an annual savings of \$299 (\$1,912 minus \$1,613).

Now repeat steps 8 through 9 for each type fuel and/or heat pump selected. This will enable you to select the best combination of furnace and heat pump to use for a structure.

10. The balance point (the outdoor temperature at which the heat pump is running 100% of the time and just meeting structure heat loss requirements) is located on right side of page.

EXAMPLE: For a structure with a 70,000 Btuh with a 36UHPQA heat pump has a balance point of 31°F. Below this theoretical balance point, the heating load is automatically transferred between the heat pump and the furnace by the wall thermostat to maintain the desired temperature. This is accomplished with the Fuel Saver Module.

70,000	\$ 952 1092 1231 1363 1502 1641 1780 1912 2052 2191 2323 2462	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 946 1029 1119 1203 1286 1377 1460 1544 1627 1718 1801 1885	
.06	\$ 1015 1099 1189 1272 1356 1446 1530 1613 1697 1787 1871 1954	
.07	\$ 1085 1168 1259 1342 1426 1516 1599 1683 1766 1857 1940 2024	
.08	\$ 1154 1238 1328 1412 1495 1586 1669 1752 1836 1926 2010 2093	
.09	\$ 1224 1307 1398 1481 1565 1655 1739 1822 1905 1996 2079 2163	
.10	\$ 1293 1377 1467 1551 1634 1725 1808 1892 1975 2065 2149 2232	
.12	\$ 1432 1516 1606 1690 1773 1864 1947 2031 2114 2205 2288 2372	
.14	\$ 1572 1655 1745 1829 1912 2003 2086 2170 2253 2344 2427 2511	
.16	\$ 1711 1794 1885 1968 2052 2142 2225 2309 2392 2483 2566 2650	
		THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
		BALANCE POINT 31 DEG.F. -10

11. To find annual cooling cost of heat pump, look at the bottom of page under annual air conditioning cost. Directly under the electric rate \$/KW (step 3) line, is located the annual cooling cost.

EXAMPLE: At .06 \$/KW rate for electricity, the cooling cost would be \$91.00 annually.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.06	.07	.08	.09	.10	.12	.14	.16		--ELECTRIC RATE \$/KWH
75	91	106	121	136	151	182	212	243		--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED AS A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

NOTE: The accuracy of the "Dual Fuel-Add-On Heat Pump Guide to Energy Cost Savings," is directly affected by how accurately you estimate the structure's heat loss and heat gain in step 1. Because of uncontrollable variables, Bard Manufacturing Company is not responsible for any variation in actual operating costs from these theoretical estimates.

FIGURE 1

HEAT LOSS BTUH	ELEC. COST S/KWH	HEATING OIL COST - \$/GALLON												
		.70	.80	.90	1.00	1.10	1.20	1.30	(1.40)	1.50	1.60	1.70	1.80	
B														
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY	
.05	\$ 500	521	542	563	584	605	626	646	667	688	709	737		
.06	\$ 570	591	612	633	653	674	695	716	737	758	779	806	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR	
.07	\$ 639	660	681	702	723	744	765	786	806	827	848	876		
.08	\$ 716	737	758	779	799	820	841	862	883	904	925	952		
.09	\$ 786	806	827	848	869	890	911	932	952	973	994	1022		
.10	\$ 855	876	897	918	939	959	980	1001	1022	1043	1064	1092		
.12	\$ 994	1015	1036	1057	1078	1099	1119	1140	1161	1182	1203	1231		
.14	\$ 1140	1161	1182	1203	1224	1245	1266	1286	1307	1328	1349	1377		
.16	\$ 1279	1300	1321	1342	1363	1384	1405	1426	1446	1467	1488	1516	BALANCE POINT 13 DEG.F.	
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY	
.05	\$ 563	591	612	639	660	688	709	730	758	779	806	827		
.06	\$ 646	674	695	723	744	772	793	813	841	862	890	911	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR	
.07	\$ 723	751	772	799	820	848	869	890	918	939	966	987		
.08	\$ 799	827	848	876	897	925	946	966	994	1015	1043	1064		
.09	\$ 883	911	932	959	980	1008	1029	1050	1078	1109	1126	1147		
.10	\$ 959	987	1008	1036	1057	1085	1106	1126	1154	1175	1203	1224		
.12	\$ 1119	1147	1168	1196	1217	1245	1266	1286	1314	1335	1363	1384		
.14	\$ 1279	1307	1328	1356	1377	1405	1426	1446	1474	1495	1523	1544		
.16	\$ 1439	1467	1488	1516	1537	1565	1586	1606	1634	1655	1683	1704	BALANCE POINT 16 DEG.F.	
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY	
.05	\$ 695	744	793	841	890	939	987	1036	1085	1133	1189	1238		
.06	\$ 765	813	862	911	959	1008	1057	1106	1154	1203	1259	1307	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR	
.07	\$ 834	883	932	980	1029	1078	1126	1175	1224	1272	1328	1377		
.08	\$ 904	952	1001	1050	1099	1147	1196	1245	1293	1342	1398	1446		
.09	\$ 966	1015	1064	1112	1161	1210	1259	1307	1356	1405	1460	1509		
.10	\$ 1036	1083	1133	1182	1231	1279	1328	1377	1426	1474	1530	1579		
.12	\$ 1175	1224	1272	1321	1370	1419	1467	1516	1565	1613	1669	1718		
.14	\$ 1314	1363	1412	1460	1509	1558	1606	1655	1704	1752	1808	1857		
.16	\$ 1453	1502	1551	1599	1648	1697	1745	1794	1843	1892	1947	1996	BALANCE POINT 22 DEG.F.	
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	--THEORETICAL HEATING COST * FURNACE ONLY	
.05	\$ 820	890	966	1036	1112	1189	1259	1335	1405	1481	1551	1627		
.06	\$ 883	952	1029	1099	1175	1252	1321	1398	1467	1544	1613	1690	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR	
.07	\$ 946	1015	1092	1161	1238	1314	1384	1460	1530	1606	1676	1752		
.08	\$ 1001	1071	1147	1217	1293	1370	1439	1516	1586	1662	1732	1808		
.09	\$ 1064	1133	1210	1279	1356	1432	1502	1579	1648	1725	1794	1871		
.10	\$ 1126	1196	1272	1342	1419	1495	1565	1641	1711	1787	1857	1933		
.12	\$ 1252	1321	1398	1467	1544	1620	1690	1766	1836	1912	1982	2059		
.14	\$ 1370	1439	1516	1586	1662	1739	1808	1885	1954	2031	2100	2177		
.16	\$ 1495	1565	1641	1711	1787	1864	1933	2010	2079	2156	2225	2302	BALANCE POINT 27 DEG.F.	
A	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	--THEORETICAL HEATING COST * FURNACE ONLY	
D	.05	\$ 946	1029	1119	1203	1286	1377	1460	1544	1627	1718	1801	1885	
.06	\$ 1015	1099	1189	1272	1356	1446	1530	1613	1697	1787	1871	1954	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR	
.07	\$ 1085	1168	1259	1342	1426	1516	1599	1683	1766	1857	1940	2024		
.08	\$ 1154	1238	1328	1412	1495	1586	1669	1752	1836	1926	2010	2093		
.09	\$ 1224	1307	1398	1481	1565	1655	1739	1822	1905	1996	2079	2163		
.10	\$ 1293	1377	1467	1551	1634	1725	1808	1892	1975	2065	2149	2232		
.12	\$ 1432	1516	1606	1690	1773	1864	1947	2031	2114	2205	2288	2372		
.14	\$ 1572	1655	1745	1829	1912	2003	2086	2170	2253	2344	2427	2511		
.16	\$ 1711	1794	1885	1968	2052	2142	2225	2309	2392	2483	2566	2650	BALANCE POINT 31 DEG.F.	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

s .05 .06 .07 .08 .09 .10 .12 .14 .16
s .75 .91 .106 .121 .136 .151 .182 .212 .243

--ELECTRIC RATE S/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION WOS30A INDOOR A36AO-A
 COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 30900 BTUH, 17.25 SEER
 HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 24750 BTUH, 3.35 COP
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS BTUH	ELBC. COST \$/KWH
-------------------	-------------------------

25,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	306	772
.06	\$	368	925
.07	\$	438	1085
.08	\$	493	1238
.09	\$	556	1391
.10	\$	619	1544
.12	\$	744	1857
.14	\$	862	2170
.16	\$	994	2476

30,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	361	925
.06	\$	438	1112
.07	\$	507	1300
.08	\$	584	1488
.09	\$	653	1669
.10	\$	730	1857
.12	\$	876	2232
.14	\$	1022	2601
.16	\$	1168	2977

BALANCE POINT 15- DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	417	1085
.06	\$	500	1300
.07	\$	591	1516
.08	\$	667	1732
.09	\$	758	1947
.10	\$	841	2170
.12	\$	1008	2601
.14	\$	1182	3039
.16	\$	1349	3471

BALANCE POINT 3- DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	479	1238
.06	\$	577	1488
.07	\$	667	1732
.08	\$	765	1982
.09	\$	862	2232
.10	\$	959	2476
.12	\$	1147	2977
.14	\$	1342	3471
.16	\$	1530	3965

BALANCE POINT 5 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	626	1544
.06	\$	751	1857
.07	\$	869	2170
.08	\$	994	2476
.09	\$	1119	2789
.10	\$	1245	3095
.12	\$	1495	3721
.14	\$	1739	4340
.16	\$	1996	4959

BALANCE POINT 17 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.06	.07	.08	.09	.10	.12	.14	.16
35	42	50	57	64	71	85	100	114

<<--ELECTRIC RATE \$/KWH	<<--THEORETICAL AIR CONDITIONING COST
--------------------------	---------------------------------------

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION WOS30A INDOOR A36AO-A
 COOLING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 30900 BTUH 17.25 SEER
 HEATING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 24750 BTUH 3.35 COP
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										--THEORETICAL HEATING COST * FURNACE ONLY	
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	
25,000	\$ 236	271	299	333	368	403	438	473	507	542	605	674	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 271	271	271	278	278	278	285	285	285	292	299	
	.06	\$ 319	319	319	326	326	326	333	333	333	340	347	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
	.07	\$ 375	375	375	382	382	382	389	389	389	396	403	403
	.08	\$ 424	424	424	431	431	431	438	438	438	445	452	452
	.09	\$ 473	473	473	479	479	479	486	486	486	493	500	500
	.10	\$ 521	521	521	528	528	528	535	535	535	542	549	549
	.12	\$ 626	626	626	633	633	633	639	639	639	646	653	653
	.14	\$ 723	723	723	730	730	730	737	737	737	744	751	751
	.16	\$ 827	827	827	834	834	834	841	841	841	848	855	855
30,000	\$ 278	319	361	403	445	486	528	563	605	646	730	813	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 313	319	319	326	326	333	333	333	340	340	347	354
	.06	\$ 375	382	382	389	389	396	396	396	403	403	410	417
	.07	\$ 431	438	438	445	445	452	452	452	459	459	466	473
	.08	\$ 493	500	500	507	507	514	514	514	521	521	528	535
	.09	\$ 549	556	556	563	563	570	570	570	577	577	584	591
	.10	\$ 612	619	619	626	626	633	633	633	639	639	646	653
	.12	\$ 730	737	737	744	744	751	751	758	758	765	772	
	.14	\$ 848	855	855	862	862	869	869	869	876	876	883	890
	.16	\$ 959	966	966	973	973	980	980	980	987	987	994	1001
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 361	361	368	375	382	389	396	396	403	410	424	431
	.06	\$ 431	431	438	445	452	459	466	466	473	479	493	500
	.07	\$ 493	493	500	507	514	521	528	528	535	542	556	563
	.08	\$ 556	556	563	570	577	584	591	591	598	605	619	626
	.09	\$ 626	626	633	639	646	653	660	660	667	674	688	695
	.10	\$ 688	688	695	702	709	716	723	723	730	737	751	758
	.12	\$ 820	820	827	834	841	848	855	855	862	869	883	890
	.14	\$ 946	946	952	959	966	973	980	980	987	994	1008	1015
	.16	\$ 1078	1078	1085	1092	1099	1106	1112	1112	1119	1126	1140	1147
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 403	410	417	431	438	445	452	459	466	479	493	507
	.06	\$ 473	479	486	500	507	514	521	528	535	549	563	577
	.07	\$ 549	556	563	577	584	591	598	605	612	626	639	653
	.08	\$ 619	626	633	646	653	660	667	674	681	695	709	723
	.09	\$ 688	695	702	716	723	730	737	744	751	765	779	793
	.10	\$ 758	765	772	786	793	799	806	813	820	834	848	862
	.12	\$ 897	904	911	925	932	939	946	952	959	973	987	1001
	.14	\$ 1036	1043	1050	1064	1071	1078	1085	1092	1099	1112	1126	1140
	.16	\$ 1175	1182	1189	1203	1210	1217	1224	1231	1238	1252	1266	1279
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 493	521	549	577	605	626	653	681	709	737	793	841
	.06	\$ 556	584	612	639	667	688	716	744	772	799	855	904
	.07	\$ 619	646	674	702	730	751	779	806	834	862	918	966
	.08	\$ 681	709	737	765	793	813	841	869	897	925	980	1029
	.09	\$ 744	772	799	827	855	876	904	932	959	987	1043	1092
	.10	\$ 806	834	862	890	918	939	966	994	1022	1050	1106	1154
	.12	\$ 932	959	987	1015	1043	1064	1092	1119	1147	1175	1231	1279
	.14	\$ 1057	1085	1112	1140	1168	1189	1217	1245	1272	1300	1356	1405
	.16	\$ 1175	1203	1231	1259	1286	1307	1335	1363	1391	1419	1474	1523

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

 .05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 35 42 50 57 64 71 85 100 114

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION MOS30A INDOOR A36AO-A
 COOLING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 30900 BTUH 17.25 SEER
 HEATING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 24750 BTUH 3.35 COP
 FURNACE TYPE: FUEL OIL FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST S/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
25,000	\$ 340	389	438	486	535	584	633	681	730	779	827	876	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 278	278	285	285	292	292	299	299	306	306	313	313
	.06	\$ 326	326	333	333	340	340	347	347	354	354	361	361
	.07	\$ 382	382	389	389	396	396	403	403	410	410	417	417
	.08	\$ 431	431	438	438	445	445	452	452	459	459	466	466
	.09	\$ 479	479	486	486	493	493	500	500	507	507	514	514
	.10	\$ 528	528	535	535	542	542	549	549	556	556	563	563
	.12	\$ 633	633	639	639	646	646	653	653	660	660	667	667
	.14	\$ 730	730	737	737	744	744	751	751	758	758	765	765
	.16	\$ 834	834	841	841	848	848	855	855	862	862	869	869
30,000	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 326	326	333	340	340	347	354	354	361	368	368	375
	.06	\$ 389	389	396	403	403	410	417	417	424	431	431	438
	.07	\$ 445	445	452	459	459	466	473	473	479	486	486	493
	.08	\$ 507	507	514	521	521	528	535	535	542	549	549	556
	.09	\$ 563	563	570	577	577	584	591	591	598	605	605	612
	.10	\$ 626	626	633	639	639	646	653	653	660	667	667	674
	.12	\$ 744	744	751	758	758	765	772	772	779	786	786	793
	.14	\$ 862	862	869	876	876	883	890	890	897	904	904	911
	.16	\$ 973	973	980	987	987	994	1001	1001	1008	1015	1015	1022
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 375	382	389	403	410	417	424	431	438	452	459	466
	.06	\$ 445	452	459	473	479	486	493	500	507	521	528	535
	.07	\$ 507	514	521	535	542	549	556	563	570	584	591	598
	.08	\$ 570	577	584	598	605	612	619	626	633	646	653	660
	.09	\$ 639	646	653	667	674	681	688	695	702	716	723	730
	.10	\$ 702	709	716	730	737	744	751	758	765	779	786	793
	.12	\$ 834	841	848	862	869	876	883	890	897	911	918	925
	.14	\$ 959	966	973	987	994	1001	1008	1015	1022	1036	1043	1050
	.16	\$ 1092	1099	1106	1119	1126	1133	1140	1147	1154	1168	1175	1182
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 431	438	452	466	473	486	500	514	521	535	549	556
	.06	\$ 500	507	521	535	542	556	570	584	591	605	619	626
	.07	\$ 577	584	598	612	619	633	646	660	667	681	695	702
	.08	\$ 646	653	667	681	688	702	716	730	737	751	765	772
	.09	\$ 716	723	737	751	758	772	786	799	806	820	834	841
	.10	\$ 786	793	806	820	827	841	855	869	876	890	904	911
	.12	\$ 925	932	946	959	966	980	994	1008	1015	1029	1043	1050
	.14	\$ 1064	1071	1085	1099	1106	1119	1133	1147	1154	1168	1182	1189
	.16	\$ 1203	1210	1224	1238	1245	1259	1272	1286	1293	1307	1321	1328
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 577	619	653	695	730	772	813	848	890	925	966	1001
	.06	\$ 639	681	716	758	793	834	876	911	952	987	1029	1064
	.07	\$ 702	744	779	820	855	897	939	973	1015	1050	1092	1126
	.08	\$ 765	806	841	883	918	959	1001	1036	1078	1112	1154	1189
	.09	\$ 827	869	904	946	980	1022	1064	1099	1140	1175	1217	1252
	.10	\$ 890	932	966	1008	1043	1085	1126	1161	1203	1238	1279	1314
	.12	\$ 1015	1057	1092	1133	1168	1210	1252	1286	1328	1363	1405	1439
	.14	\$ 1140	1182	1217	1259	1293	1335	1377	1412	1453	1488	1530	1565
	.16	\$ 1259	1300	1335	1377	1412	1453	1495	1530	1572	1606	1648	1683

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

 .05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 35 42 50 57 64 71 85 100 114

--ELECTRIC RATE S/KWH
 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION WOS30A INDOOR A36AO-A
 COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 30900 BTUH, 17.25 SEER
 HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 24750 BTUH, 3.35 COP
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20
25,000	\$	445	479	521	556	591	633	667	702	744	813	890	890
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	285	285	292	292	292	299	299	306	306	313	319	319
.06	\$	333	333	340	340	340	347	347	354	354	361	368	368
.07	\$	389	389	396	396	396	403	403	410	410	417	424	424
.08	\$	438	438	445	445	445	452	452	459	459	466	473	473
.09	\$	486	486	493	493	493	500	500	507	507	514	521	521
.10	\$	535	535	542	542	542	549	549	556	556	563	570	570
.12	\$	639	639	646	646	646	653	653	660	660	667	674	674
.14	\$	737	737	744	744	744	751	751	758	758	765	772	772
.16	\$	841	841	848	848	848	855	855	862	862	869	876	876
30,000	\$	535	577	626	667	709	758	799	848	890	980	1071	1071
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	333	340	340	347	347	354	354	361	361	368	375	375
.06	\$	396	403	403	410	410	417	417	424	424	431	438	438
.07	\$	452	459	459	466	466	473	473	479	479	486	493	493
.08	\$	514	521	521	528	528	535	535	542	542	549	556	556
.09	\$	570	577	577	584	584	591	591	598	598	605	612	612
.10	\$	633	639	639	646	646	653	653	660	660	667	674	674
.12	\$	751	758	758	765	765	772	772	779	779	786	793	793
.14	\$	869	876	876	883	883	890	890	897	897	904	911	911
.16	\$	980	987	987	994	994	1001	1001	1008	1008	1015	1022	1022
35,000	\$	626	674	730	779	834	883	939	987	1043	1147	1252	1252
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	396	403	403	410	417	424	431	438	445	459	466	466
.06	\$	466	473	473	479	486	493	500	507	514	528	535	535
.07	\$	528	535	535	542	549	556	563	570	577	591	598	598
.08	\$	591	598	598	605	612	619	626	633	639	653	660	660
.09	\$	660	667	667	674	681	688	695	702	709	723	730	730
.10	\$	723	730	730	737	744	751	758	765	772	786	793	793
.12	\$	855	862	862	869	876	883	890	897	904	918	925	925
.14	\$	980	987	987	994	1001	1008	1015	1022	1029	1043	1050	1050
.16	\$	1112	1119	1119	1126	1133	1140	1147	1154	1161	1175	1182	1182
40,000	\$	709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	452	466	473	479	486	500	507	514	528	542	563	563
.06	\$	521	535	542	549	556	570	577	584	598	612	633	633
.07	\$	598	612	619	626	633	646	653	660	674	688	709	709
.08	\$	667	681	688	695	702	716	723	730	744	758	779	779
.09	\$	737	751	758	765	772	786	793	799	813	827	848	848
.10	\$	806	820	827	834	841	855	862	869	883	897	918	918
.12	\$	946	959	966	973	980	994	1001	1008	1022	1036	1057	1057
.14	\$	1085	1099	1106	1112	1119	1133	1140	1147	1161	1175	1196	1196
.16	\$	1224	1238	1245	1252	1259	1272	1279	1286	1300	1314	1335	1335
50,000	\$	890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	660	688	723	751	779	806	841	869	897	959	1015	1015
.06	\$	723	751	786	813	841	869	904	932	959	1022	1078	1078
.07	\$	786	813	848	876	904	932	966	994	1022	1085	1140	1140
.08	\$	848	876	911	939	966	994	1029	1057	1085	1147	1203	1203
.09	\$	911	939	973	1001	1029	1057	1092	1119	1147	1210	1266	1266
.10	\$	973	1001	1036	1064	1092	1119	1154	1182	1210	1272	1328	1328
.12	\$	1099	1126	1161	1189	1217	1245	1279	1307	1335	1398	1453	1453
.14	\$	1224	1252	1286	1314	1342	1370	1405	1432	1460	1523	1579	1579
.16	\$	1342	1370	1405	1432	1460	1488	1523	1551	1579	1641	1697	1697

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05 \$.06 \$.07 \$.08 \$.09 \$.10 \$.12 \$.14 \$.16
 s .35 .42 .50 .57 .64 .71 .85 .100 .114

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION: WOS36A INDOOR: A36AO-A
 COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 36950 BTUH 16.70 SEER
 HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 32300 BTUH 3.50 COP
 FURNACE TYPE: ELECTRIC FURNACE EFFICIENCY: 100.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH
----------------	-------------------

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	417	1085
.06	\$	500	1300
.07	\$	571	1516
.08	\$	667	1732
.09	\$	751	1947
.10	\$	827	2170
.12	\$	1001	2601
.14	\$	1168	3039
.16	\$	1328	3471

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	466	1238
.06	\$	563	1488
.07	\$	660	1732
.08	\$	751	1982
.09	\$	841	2232
.10	\$	939	2476
.12	\$	1126	2977
.14	\$	1307	3471
.16	\$	1502	3965

BALANCE POINT 13- DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	577	1544
.06	\$	695	1857
.07	\$	806	2170
.08	\$	925	2476
.09	\$	1043	2789
.10	\$	1154	3095
.12	\$	1384	3721
.14	\$	1620	4340
.16	\$	1850	4959

BALANCE POINT 2 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	709	1857
.06	\$	848	2232
.07	\$	987	2601
.08	\$	1126	2977
.09	\$	1272	3345
.10	\$	1412	3721
.12	\$	1657	4465
.14	\$	1982	5210
.16	\$	2260	5954

BALANCE POINT 12 DEG.F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	869	2170
.06	\$	1036	2601
.07	\$	1217	3039
.08	\$	1391	3471
.09	\$	1565	3902
.10	\$	1739	4340
.12	\$	2086	5210
.14	\$	2434	6079
.16	\$	2782	6942

BALANCE POINT 20 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

	.05	.06	.07	.08	.09	.10	.12	.14	.16
\$	44	53	61	70	79	88	106	123	141

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: COMPRESSOR SECTION WOS36A INDOOR A36AO-A
COOLING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 36950 BTUH, 16.70 SEER
HEATING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 32300 BTUH, 3.50 COP
FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
30,000	\$	278	319	361	403	445	486	528	563	605	646	730	813
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	313	313	319	319	326	326	333	333	340	340	347	354
.06	\$	368	368	375	375	382	382	389	389	396	396	403	410
.07	\$	431	431	438	438	445	445	452	452	459	459	466	473
.08	\$	486	486	493	493	500	500	507	507	514	514	521	528
.09	\$	549	549	556	556	563	563	570	570	577	577	584	591
.10	\$	605	605	612	612	619	619	626	626	633	633	639	646
.12	\$	723	723	730	730	737	737	744	744	751	751	758	765
.14	\$	841	841	848	848	855	855	862	862	869	869	876	883
.16	\$	952	952	959	959	966	966	973	973	980	980	987	994
35,000	\$	326	375	424	473	521	563	612	660	709	758	848	946
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	361	361	368	368	375	375	382	382	389	389	396	403
.06	\$	431	431	438	438	445	445	452	452	459	459	466	473
.07	\$	493	493	500	500	507	507	514	514	521	521	528	535
.08	\$	563	563	570	570	577	577	584	584	591	591	598	605
.09	\$	633	633	639	639	646	646	653	653	660	660	667	674
.10	\$	695	695	702	702	709	709	716	716	723	723	730	737
.12	\$	834	834	841	841	848	848	855	855	862	862	869	876
.14	\$	966	966	973	973	980	980	987	987	994	994	1001	1008
.16	\$	1099	1099	1106	1106	1112	1112	1119	1119	1126	1126	1133	1140
40,000	\$	375	431	486	542	591	646	702	758	813	862	973	1085
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	410	410	417	424	424	431	438	438	445	452	459	466
.06	\$	479	479	486	493	493	500	507	507	514	521	528	535
.07	\$	556	556	563	570	570	577	584	584	591	598	605	612
.08	\$	633	633	639	646	646	653	660	660	667	674	681	688
.09	\$	702	702	709	716	716	723	730	730	737	744	751	758
.10	\$	779	779	786	793	793	799	806	806	813	820	827	834
.12	\$	925	925	932	939	939	946	952	952	959	966	973	980
.14	\$	1078	1078	1085	1092	1092	1099	1106	1106	1112	1119	1126	1133
.16	\$	1224	1224	1231	1238	1238	1245	1252	1252	1259	1266	1272	1279
50,000	\$	473	542	605	674	744	813	876	946	1015	1085	1217	1356
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	493	507	514	528	535	542	556	563	577	584	605	626
.06	\$	577	591	598	612	619	626	639	646	660	667	688	709
.07	\$	660	674	681	685	695	702	709	723	730	744	751	772
.08	\$	744	758	765	779	786	793	806	813	827	834	855	876
.09	\$	827	841	848	862	869	876	890	897	911	918	939	959
.10	\$	911	925	932	939	939	946	952	959	973	980	994	1001
.12	\$	1085	1099	1106	1119	1126	1133	1147	1154	1168	1175	1196	1217
.14	\$	1252	1266	1272	1286	1293	1300	1314	1321	1335	1342	1363	1384
.16	\$	1419	1432	1439	1453	1460	1467	1481	1488	1502	1509	1530	1551
60,000	\$	563	646	730	813	890	973	1057	1133	1217	1300	1460	1627
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	584	612	633	660	688	709	737	758	786	813	862	911
.06	\$	660	688	709	737	765	786	813	834	862	880	939	987
.07	\$	744	772	793	820	848	869	897	918	946	973	1022	1071
.08	\$	827	855	876	904	932	952	980	1001	1029	1057	1106	1154
.09	\$	911	939	959	987	1015	1036	1064	1085	1112	1140	1189	1238
.10	\$	987	1015	1036	1064	1092	1112	1140	1161	1189	1217	1266	1314
.12	\$	1154	1182	1203	1231	1259	1279	1307	1328	1356	1384	1432	1481
.14	\$	1314	1342	1363	1391	1419	1439	1467	1488	1516	1544	1592	1641
.16	\$	1481	1509	1530	1558	1586	1606	1634	1655	1683	1711	1759	1808
70,000	\$	660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	674	709	751	786	827	862	897	939	973	1015	1092	1161
.06	\$	758	793	834	869	911	946	980	1022	1057	1099	1175	1245
.07	\$	834	869	911	946	987	1022	1057	1099	1133	1175	1252	1321
.08	\$	918	952	994	1029	1071	1106	1140	1182	1217	1259	1335	1405
.09	\$	1001	1036	1078	1112	1154	1182	1224	1266	1300	1342	1419	1488
.10	\$	1085	1119	1161	1196	1238	1272	1307	1349	1384	1426	1502	1572
.12	\$	1245	1279	1321	1356	1398	1432	1467	1509	1544	1586	1662	1732
.14	\$	1412	1446	1488	1523	1565	1599	1634	1676	1711	1752	1829	1899
.16	\$	1572	1606	1648	1683	1725	1759	1794	1836	1871	1912	1989	2059

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

--ELECTRIC RATE \$/KWH
 s .05 .06 .07 .08 .09 .10 .12 .14 .16
 s 44 53 61 70 79 88 123 141

--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: COMPRESSOR SECTION WOS36A INDOOR A36AO-A
 COOLING CAPACITY AT 45 DEG F. ENTERING WATER TEMP.: 36950 BTUH, 16.70 SEER
 HEATING CAPACITY AT 45 DEG F. ENTERING WATER TEMP.: 32300 BTUH, 3.50 COP
 FURNACE TYPE: FUEL OIL FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON														
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80			
30,000	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 319	326	333	333	340	347	347	354	354	361	368	368			
	.06	\$ 315	382	389	389	396	403	403	410	410	417	424	424	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 438	445	452	452	459	466	466	473	473	479	486	486			
	.08	\$ 493	500	507	507	514	521	521	528	528	535	542	542			
	.09	\$ 556	563	570	570	577	584	584	591	591	598	605	605			
	.10	\$ 612	619	626	626	633	639	639	646	646	653	660	660			
	.12	\$ 730	737	744	744	751	758	758	765	765	772	779	779			
	.14	\$ 848	855	862	862	869	876	876	883	883	890	897	897			
	.16	\$ 959	966	973	973	980	987	987	994	994	1001	1008	1008			
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 368	375	382	382	389	396	403	403	410	417	417	424			
	.06	\$ 438	445	452	452	459	466	473	473	479	486	486	493	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 500	507	514	514	521	528	535	535	542	549	549	556			
	.08	\$ 570	577	584	584	591	598	605	605	612	619	619	626			
	.09	\$ 639	646	653	653	660	667	674	674	681	688	688	695			
	.10	\$ 702	709	716	716	723	730	737	737	744	751	751	758			
	.12	\$ 841	848	855	855	862	869	876	876	883	890	890	897			
	.14	\$ 973	980	987	987	994	1001	1008	1008	1015	1022	1022	1029	BALANCE POINT 63 DEG.F.		
	.16	\$ 1106	1112	1119	1119	1126	1133	1140	1140	1147	1154	1154	1161			
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 424	431	438	445	452	459	466	466	473	479	486	493			
	.06	\$ 493	500	507	514	521	528	535	535	542	549	556	563	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 570	577	584	591	598	605	612	612	619	626	633	639			
	.08	\$ 646	653	660	667	674	681	688	688	695	702	709	716			
	.09	\$ 716	723	730	737	744	751	758	758	765	772	779	786			
	.10	\$ 793	799	806	813	820	827	834	834	841	848	855	862			
	.12	\$ 939	946	952	959	966	973	980	980	987	994	1001	1008			
	.14	\$ 1092	1099	1106	1112	1119	1126	1133	1133	1140	1147	1154	1161	BALANCE POINT 13 DEG.F.		
	.16	\$ 1238	1245	1252	1259	1266	1272	1279	1279	1286	1293	1300	1307			
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 528	542	556	570	584	598	612	626	639	660	674	688			
	.06	\$ 612	626	639	653	667	681	695	709	723	744	758	772	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 695	709	723	737	751	765	779	793	806	827	841	855			
	.08	\$ 779	793	806	820	834	848	862	876	890	911	925	939			
	.09	\$ 862	876	890	904	918	932	946	959	973	994	1008	1022			
	.10	\$ 946	959	973	987	1001	1015	1029	1043	1057	1078	1092	1106			
	.12	\$ 1119	1133	1147	1161	1175	1189	1203	1217	1231	1252	1266	1279			
	.14	\$ 1286	1300	1314	1328	1342	1356	1370	1384	1398	1419	1432	1446	BALANCE POINT 2 DEG.F.		
	.16	\$ 1453	1467	1481	1495	1509	1523	1537	1551	1565	1586	1599	1613			
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 660	702	737	772	806	841	883	918	952	987	1022	1057			
	.06	\$ 737	779	813	848	883	918	959	994	1029	1064	1099	1133	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 820	862	897	932	966	1001	1043	1078	1112	1147	1182	1217			
	.08	\$ 904	946	980	1015	1050	1085	1126	1161	1196	1231	1266	1300			
	.09	\$ 987	1029	1064	1099	1133	1168	1210	1245	1279	1314	1349	1384			
	.10	\$ 1064	1106	1140	1175	1210	1245	1286	1321	1356	1391	1426	1460			
	.12	\$ 1231	1272	1307	1342	1377	1412	1453	1488	1523	1558	1592	1627	BALANCE POINT 12 DEG.F.		
	.14	\$ 1391	1432	1467	1502	1537	1572	1613	1648	1683	1718	1752	1787			
	.16	\$ 1558	1599	1634	1669	1704	1739	1780	1815	1850	1885	1919	1954			
70,000	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	<--THEORETICAL HEATING COST * FURNACE ONLY			
	.05	\$ 793	841	897	952	1008	1064	1119	1168	1224	1279	1335	1391			
	.06	\$ 876	925	980	1036	1092	1147	1203	1252	1307	1363	1419	1474	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR		
	.07	\$ 952	1001	1057	1112	1168	1224	1279	1328	1384	1439	1495	1551			
	.08	\$ 1036	1085	1140	1196	1252	1307	1363	1412	1467	1523	1579	1634			
	.09	\$ 1119	1168	1224	1279	1335	1391	1446	1495	1551	1606	1662	1718			
	.10	\$ 1203	1252	1307	1363	1419	1474	1530	1579	1634	1690	1745	1801			
	.12	\$ 1363	1412	1467	1523	1579	1634	1690	1739	1794	1850	1905	1961	BALANCE POINT 20 DEG.F.		
	.14	\$ 1530	1579	1634	1690	1745	1801	1857	1905	1961	2017	2072	2128			
	.16	\$ 1690	1739	1794	1850	1905	1961	2017	2065	2121	2177	2232	2288			

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05 .06 .07 .08 .09 .10 .12 .14 .16 <-ELECTRIC RATE \$/KWH
 \$ 44 53 61 70 79 88 106 123 141 <-THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5		HEAT PUMP MODEL: COMPRESSOR SECTION WOS36A		INDOOR A36AO-A																
COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 36950 BTUH, 16.70 SEER		HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 32300 BTUH, 3.50 COP		FURNACE TYPE PROPANE GAS		FURNACE EFFICIENCY 78.00% AFUE														
HEAT LOSS BTUH	ELEC. COST \$/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70			
30,000	\$ 535	577	626	667	709	758	799	848	890	980	1071	1071	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 333	333	340	340	347	347	354	354	361	368	375	375	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 389	389	396	396	403	403	410	410	417	424	431	431	S PER YEAR						
	.07	\$ 452	452	459	459	466	466	473	473	479	486	493	493							
	.08	\$ 507	507	514	514	521	521	528	528	535	542	549	549							
	.09	\$ 570	570	577	577	584	584	591	591	598	605	612	612							
	.10	\$ 626	626	633	633	639	639	646	646	653	660	667	667							
	.12	\$ 744	744	751	751	758	758	765	765	772	779	786	786							
	.14	\$ 862	862	869	869	876	876	883	883	890	897	904	904							
	.16	\$ 973	973	980	980	987	987	994	994	1001	1008	1015	1015							
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 382	382	389	389	396	403	403	410	410	417	424	424	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 452	452	459	459	466	473	473	479	479	486	493	493	S PER YEAR						
	.07	\$ 514	514	521	521	528	535	535	542	542	549	556	556							
	.08	\$ 584	584	591	591	598	605	605	612	612	619	626	626							
	.09	\$ 653	653	660	660	667	674	674	681	681	688	695	695							
	.10	\$ 716	716	723	723	730	737	737	744	744	751	758	758							
	.12	\$ 855	855	862	862	869	876	876	883	883	890	897	897							
	.14	\$ 987	987	994	994	1001	1008	1008	1015	1015	1022	1029	1029							
	.16	\$ 1119	1119	1126	1126	1133	1140	1140	1147	1147	1154	1161	1161	BALANCE POINT 63 DEG.F.						
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 438	445	445	452	459	459	466	473	479	486	500	500	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 507	514	514	521	528	528	535	542	549	556	570	570	S PER YEAR						
	.07	\$ 584	591	591	598	605	605	612	619	626	633	646	646							
	.08	\$ 660	667	667	674	681	681	688	695	702	709	723	723							
	.09	\$ 730	737	737	744	751	751	758	765	772	779	793	793							
	.10	\$ 806	813	813	820	827	827	834	841	848	855	869	869							
	.12	\$ 952	959	959	966	973	973	980	987	994	1001	1015	1015							
	.14	\$ 1106	1112	1112	1126	1126	1133	1140	1147	1154	1168	1168	1168	BALANCE POINT 13- DEG.F.						
	.16	\$ 1252	1259	1259	1266	1272	1272	1279	1286	1293	1300	1314	1314							
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 556	570	577	591	605	612	626	633	646	667	688	688	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 639	653	660	674	688	695	709	716	730	751	772	772	S PER YEAR						
	.07	\$ 723	737	744	758	772	779	793	813	834	855	855	855							
	.08	\$ 806	820	827	841	855	862	876	883	897	918	939	939							
	.09	\$ 890	904	911	925	939	946	959	966	980	1001	1022	1022							
	.10	\$ 973	987	994	1008	1022	1029	1043	1050	1064	1085	1106	1106							
	.12	\$ 1147	1161	1168	1182	1196	1203	1217	1224	1238	1259	1279	1279	BALANCE POINT 2 DEG.F.						
	.14	\$ 1314	1328	1335	1349	1363	1370	1384	1391	1405	1426	1446	1446							
	.16	\$ 1481	1495	1502	1516	1530	1537	1551	1558	1572	1592	1613	1613							
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 737	765	793	820	848	876	904	932	959	1015	1071	1071	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 813	841	869	897	925	952	980	1008	1036	1064	1092	1147	S PER YEAR						
	.07	\$ 897	925	952	980	1008	1036	1064	1092	1119	1147	1175	1203	1259	1314	1314				
	.08	\$ 980	1008	1036	1064	1092	1119	1147	1175	1203	1231	1259	1286	1342	1398	1398				
	.09	\$ 1064	1092	1119	1147	1175	1203	1231	1259	1286	1342	1398	1398							
	.10	\$ 1140	1168	1196	1224	1252	1279	1307	1335	1363	1419	1474	1474							
	.12	\$ 1307	1335	1363	1391	1419	1446	1474	1502	1530	1586	1641	1641							
	.14	\$ 1467	1495	1523	1551	1579	1606	1634	1662	1690	1745	1801	1801	BALANCE POINT 12 DEG.F.						
	.16	\$ 1634	1662	1690	1718	1745	1773	1801	1829	1857	1912	1968	1968							
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504	2504	<--THEORETICAL HEATING COST * FURNACE ONLY							
	.05	\$ 904	946	987	1029	1071	1112	1154	1196	1238	1321	1405	1405	THEORETICAL HEATING COST * FURN.+ HEAT PUMP						
	.06	\$ 987	1029	1071	1112	1154	1196	1238	1279	1321	1405	1488	1488	S PER YEAR						
	.07	\$ 1064	1104	1147	1189	1231	1272	1314	1356	1398	1481	1565	1565							
	.08	\$ 1147	1189	1231	1272	1314	1356	1398	1439	1481	1523	1565	1648							
	.09	\$ 1231	1272	1314	1356	1398	1439	1481	1523	1565	1648	1732	1732							
	.10	\$ 1314	1356	1398	1439	1481	1523	1565	1606	1648	1732	1815	1815							
	.12	\$ 1474	1516	1558	1599	1641	1683	1725	1766	1808	1892	1975	1975							
	.14	\$ 1641	1683	1725	1766	1808	1850	1892	1933	1975	2059	2142	2142	BALANCE POINT 20 DEG.F.						
	.16	\$ 1801	1843	1885	1926	1968	2010	2052	2093	2135	2219	2302	2302							

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION WOS42A INDOOR A42AO-A
 COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 43600 BTUH 17.45 SEER
 HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 37500 BTUH 3.40 COP
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH
-------------------	-------------------------

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	486	1238
.06	\$	584	1488
.07	\$	681	1732
.08	\$	779	1982
.09	\$	876	2232
.10	\$	980	2476
.12	\$	1168	2977
.14	\$	1363	3471
.16	\$	1565	3965

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	598	1544
.06	\$	716	1857
.07	\$	834	2170
.08	\$	952	2476
.09	\$	1071	2789
.10	\$	1196	3095
.12	\$	1432	3721
.14	\$	1669	4340
.16	\$	1905	4959

BALANCE POINT 8- DEG. F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	709	1857
.06	\$	855	2232
.07	\$	994	2601
.08	\$	1140	2977
.09	\$	1279	3345
.10	\$	1419	3721
.12	\$	1704	4465
.14	\$	1989	5210
.16	\$	2274	5954

BALANCE POINT 4 DEG. F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	841	2170
.06	\$	1008	2601
.07	\$	1182	3039
.08	\$	1349	3471
.09	\$	1516	3902
.10	\$	1690	4340
.12	\$	2024	5210
.14	\$	2358	6079
.16	\$	2698	6942

BALANCE POINT 13 DEG. F.

80,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1001	2476
.06	\$	1210	2977
.07	\$	1405	3471
.08	\$	1613	3965
.09	\$	1808	4465
.10	\$	2010	4959
.12	\$	2413	5954
.14	\$	2817	6942
.16	\$	3220	7936

BALANCE POINT 19 DEG. F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S	.05	.06	.07	.08	.09	.10	.12	.14	.16
	49	59	69	79	89	99	119	139	159

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: COMPRESSOR SECTION M0542A INDOOR A42AO-A
COOLING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 43600 BTUH, 17.45 SEER
HEATING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 37500 BTUH, 3.40 COP
FURNACE TYPE: NATURAL GAS FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 375	375	382	382	389	389	396	396	403	403	410	417
.06	\$ 452	452	459	459	466	466	473	473	479	479	486	493
.07	\$ 521	521	528	528	535	535	542	542	549	549	556	563
.08	\$ 591	591	598	598	605	605	612	612	619	619	626	633
.09	\$ 660	660	667	667	674	674	681	681	688	688	695	702
.10	\$ 730	730	737	737	744	744	751	751	758	758	765	772
.12	\$ 869	869	876	876	883	883	890	890	897	897	904	911
.14	\$ 1008	1008	1015	1015	1022	1022	1029	1029	1036	1036	1043	1050
.16	\$ 1147	1147	1154	1154	1161	1161	1168	1168	1175	1175	1182	1189
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 424	431	431	438	438	445	452	452	459	459	466	479
.06	\$ 500	507	507	514	514	521	528	528	535	535	542	556
.07	\$ 577	584	584	591	591	598	605	605	612	612	619	633
.08	\$ 660	667	667	674	674	681	688	688	695	695	702	716
.09	\$ 737	744	744	751	751	758	765	765	772	772	779	793
.10	\$ 820	827	827	834	834	841	848	848	855	855	862	876
.12	\$ 973	980	980	987	987	994	1001	1001	1008	1008	1015	1029
.14	\$ 1133	1140	1140	1147	1147	1154	1161	1161	1168	1168	1175	1189
.16	\$ 1293	1300	1300	1307	1307	1314	1321	1321	1328	1328	1335	1349
		BALANCE POINT 63 DEG.F.										
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 514	521	528	535	535	542	549	556	563	570	584	598
.06	\$ 612	619	626	633	633	639	646	653	660	667	681	695
.07	\$ 702	709	716	723	723	730	737	744	751	758	772	786
.08	\$ 799	806	813	820	820	827	834	841	848	855	869	883
.09	\$ 890	897	904	911	911	918	925	932	939	946	959	973
.10	\$ 987	994	1001	1008	1008	1015	1022	1029	1036	1043	1057	1071
.12	\$ 1175	1182	1189	1196	1196	1203	1210	1217	1224	1231	1245	1259
.14	\$ 1363	1370	1377	1384	1384	1391	1398	1405	1412	1419	1432	1446
.16	\$ 1551	1558	1565	1572	1572	1579	1586	1592	1599	1606	1620	1634
		BALANCE POINT 8 DEG.F.										
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 605	619	633	639	653	667	681	688	702	716	737	765
.06	\$ 709	723	737	744	758	772	786	793	806	820	841	869
.07	\$ 806	820	834	841	855	869	883	890	904	918	939	966
.08	\$ 911	925	939	946	959	973	987	994	1008	1022	1043	1071
.09	\$ 1015	1029	1043	1050	1064	1078	1092	1099	1112	1126	1147	1175
.10	\$ 1119	1133	1147	1154	1168	1182	1196	1203	1217	1231	1252	1279
.12	\$ 1328	1342	1356	1363	1377	1391	1405	1412	1426	1439	1460	1488
.14	\$ 1537	1551	1565	1572	1586	1599	1613	1620	1634	1648	1669	1697
.16	\$ 1745	1759	1773	1780	1794	1808	1822	1829	1843	1857	1878	1905
		BALANCE POINT 4 DEG.F.										
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 695	730	758	786	813	841	876	904	932	959	1022	1078
.06	\$ 793	827	855	883	911	939	973	1001	1029	1057	1119	1175
.07	\$ 890	925	952	980	1008	1036	1071	1099	1126	1154	1217	1272
.08	\$ 987	1022	1050	1078	1106	1133	1168	1196	1224	1252	1314	1370
.09	\$ 1085	1119	1147	1175	1203	1231	1266	1293	1321	1349	1412	1467
.10	\$ 1182	1217	1245	1272	1300	1328	1363	1391	1419	1446	1509	1565
.12	\$ 1377	1412	1439	1467	1495	1523	1558	1586	1613	1641	1704	1759
.14	\$ 1572	1606	1634	1662	1690	1718	1752	1780	1808	1836	1899	1954
.16	\$ 1773	1808	1836	1864	1892	1919	1954	1982	2010	2038	2100	2156
		BALANCE POINT 13 DEG.F.										
80,000	\$ 758	862	973	1085	1189	1300	1405	1516	1627	1732	1947	2170
		--THEORETICAL HEATING COST * FURNACE ONLY										
.05	\$ 779	827	869	911	952	994	1036	1085	1126	1168	1252	1342
.06	\$ 876	925	966	1008	1050	1092	1133	1182	1224	1266	1349	1439
.07	\$ 973	1022	1064	1106	1147	1189	1229	1279	1321	1363	1446	1537
.08	\$ 1071	1119	1161	1203	1245	1286	1328	1377	1419	1460	1544	1634
.09	\$ 1168	1217	1259	1300	1342	1384	1426	1474	1510	1558	1641	1732
.10	\$ 1266	1314	1356	1398	1439	1481	1523	1572	1613	1655	1739	1829
.12	\$ 1460	1509	1551	1592	1634	1676	1718	1766	1808	1850	1933	2024
.14	\$ 1655	1704	1745	1787	1829	1871	1912	1961	2003	2045	2128	2219
.16	\$ 1843	1892	1933	1975	2017	2059	2100	2149	2191	2232	2316	2406
		BALANCE POINT 19 DEG.F.										

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05	.06	.07	.08	.09	.10	.12	.14	.16	<--ELECTRIC RATE \$/KWH		
\$.49	.59	.69	.79	.89	.99	.119	.139	.159	<--THEORETICAL AIR CONDITIONING COST		

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: COMPRESSOR SECTION WOS42A INDOOR A42AO-A
COOLING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 43600 BTUH, 17.45 SEER
HEATING CAPACITY AT 45 DEG.F. ENTERING WATER TEMP.: 37500 BTUH, 13.40 CO
FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	KWH. S/KWH	HEATING OIL COST - \$/GALLON													
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80		
35,000 \$ 473 542 612 681 751 820 890 952 1022 1092 1161 1231 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 382 389 396 396 403 410 417 417 424 431 431 438														
.06	\$ 459 466 473 473 479 486 493 493 500 507 507 514														
.07	\$ 528 535 542 542 549 556 563 563 570 577 577 584														
.08	\$ 598 605 612 612 619 626 633 633 639 646 646 653														
.09	\$ 667 674 681 681 688 695 702 702 709 716 716 723														
.10	\$ 737 744 751 751 758 765 772 772 779 786 786 793														
.12	\$ 876 883 890 890 897 904 911 911 918 925 925 932														
.14	\$ 1015 1022 1029 1029 1036 1043 1050 1050 1057 1064 1064 1071														
.16	\$ 1154 1161 1168 1168 1175 1182 1189 1189 1196 1203 1203 1210														
40,000 \$ 542 626 702 779 855 939 1015 1092 1168 1252 1328 1405 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 438 445 452 452 459 466 473 479 486 486 493 500														
.06	\$ 514 521 528 528 535 542 549 556 563 563 570 577														
.07	\$ 591 598 605 605 612 619 626 633 639 639 646 653														
.08	\$ 674 681 688 688 695 702 709 716 723 723 730 737														
.09	\$ 751 758 765 765 772 779 786 793 799 799 806 813														
.10	\$ 834 841 848 848 855 862 869 876 883 883 890 897														
.12	\$ 987 994 1001 1001 1008 1015 1022 1029 1036 1036 1043 1050														
.14	\$ 1147 1154 1161 1161 1168 1175 1182 1189 1196 1196 1203 1210														
.16	\$ 1307 1314 1321 1321 1328 1335 1342 1349 1356 1356 1363 1370														BALANCE POINT 63 DEG.F.
50,000 \$ 681 779 876 973 1071 1168 1266 1363 1467 1565 1662 1759 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 535 542 549 563 570 584 591 598 612 619 626 639														
.06	\$ 633 639 646 660 667 681 688 695 709 716 723 737														
.07	\$ 723 730 737 751 758 772 779 786 799 806 813 827														
.08	\$ 820 827 834 848 855 869 876 883 897 904 911 925														
.09	\$ 911 918 925 939 946 959 966 973 987 994 1001 1015														
.10	\$ 1008 1015 1022 1036 1043 1057 1064 1071 1085 1092 1099 1112														
.12	\$ 1196 1203 1210 1224 1231 1245 1252 1259 1272 1279 1286 1300														
.14	\$ 1384 1391 1398 1412 1419 1423 1439 1446 1460 1467 1474 1488														BALANCE POINT 8- DEG.F.
.16	\$ 1572 1579 1586 1599 1606 1620 1627 1634 1648 1655 1662 1676														
60,000 \$ 820 939 1050 1168 1286 1405 1523 1641 1759 1878 1996 2107 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 646 660 681 695 716 730 751 765 786 799 820 834														
.06	\$ 751 765 786 799 820 834 855 869 890 904 925 939														
.07	\$ 848 862 883 897 918 932 952 966 987 1001 1022 1036														
.08	\$ 952 966 987 1001 1022 1036 1057 1071 1092 1106 1126 1140														
.09	\$ 1057 1071 1092 1106 1126 1140 1161 1175 1196 1210 1231 1245														
.10	\$ 1161 1175 1196 1210 1231 1245 1266 1279 1300 1314 1335 1349														
.12	\$ 1370 1384 1405 1419 1439 1453 1474 1488 1509 1523 1544 1558														
.14	\$ 1579 1592 1613 1627 1648 1662 1683 1697 1718 1732 1752 1766														BALANCE POINT 4 DEG.F.
.16	\$ 1787 1801 1822 1836 1857 1871 1892 1905 1926 1940 1961 1975														
70,000 \$ 952 1092 1231 1363 1502 1641 1780 1912 2052 2191 2323 2462 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 786 827 876 918 959 1001 1043 1085 1126 1168 1210 1252														
.06	\$ 883 925 973 1015 1057 1099 1140 1182 1224 1266 1307 1349														
.07	\$ 980 1022 1071 1112 1154 1196 1238 1279 1321 1363 1405 1446														
.08	\$ 1078 1119 1168 1210 1252 1293 1335 1377 1419 1460 1502 1544														
.09	\$ 1175 1217 1266 1307 1349 1391 1432 1474 1516 1558 1599 1641														
.10	\$ 1272 1314 1363 1405 1446 1488 1530 1572 1613 1655 1697 1739														
.12	\$ 1467 1509 1558 1599 1641 1683 1725 1766 1808 1850 1892 1933														
.14	\$ 1662 1704 1752 1794 1836 1878 1919 1961 2003 2045 2086 2128														
.16	\$ 1864 1905 1954 1996 2038 2079 2121 2163 2205 2246 2288 2330														
80,000 \$ 1092 1252 1405 1565 1718 1878 2031 2191 2344 2504 2657 2817 <-THEORETICAL HEATING COST * FURNACE ONLY															
.05	\$ 911 973 1036 1099 1161 1224 1286 1349 1412 1474 1537 1599														
.06	\$ 1008 1071 1133 1196 1259 1321 1384 1446 1509 1572 1634 1697														
.07	\$ 1106 1168 1231 1293 1356 1419 1481 1544 1606 1669 1732 1794														
.08	\$ 1203 1266 1328 1391 1453 1516 1579 1641 1704 1766 1829 1892														
.09	\$ 1300 1363 1426 1488 1551 1613 1676 1739 1801 1864 1926 1989														
.10	\$ 1398 1460 1523 1586 1648 1711 1773 1836 1899 1961 2024 2086														
.12	\$ 1592 1655 1718 1780 1843 1905 1968 2031 2093 2156 2219 2281														
.14	\$ 1787 1850 1912 1975 2038 2100 2163 2225 2288 2351 2413 2476														
.16	\$ 1975 2038 2100 2163 2225 2288 2351 2413 2476 2538 2601 2664														

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05	.06	.07	.08	.09	.10	.11	.12	.13	.14	.15	.16
\$ 49	59	69	79	89	99	119	139	159			

<-ELECTRIC RATE \$/KWH	<-THEORETICAL AIR CONDITIONING COST
------------------------	-------------------------------------

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5

HEAT PUMP MODEL: COMPRESSOR SECTION MOS42A INDOOR A42AO-A
 COOLING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 43600 BTUH 17.45 SEER
 HEATING CAPACITY AT 45 DEG. F. ENTERING WATER TEMP.: 37500 BTUH 3.40 COP
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON										
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 396	396	403	403	410	417	417	424	424	431	438
	.06	\$ 473	473	479	479	486	493	493	500	500	507	514
	.07	\$ 542	542	549	549	556	563	563	570	570	577	584
	.08	\$ 612	612	619	619	626	633	633	639	639	646	653
	.09	\$ 681	681	688	688	695	702	702	709	709	716	723
	.10	\$ 751	751	758	758	765	772	772	779	779	786	793
	.12	\$ 890	890	897	897	904	911	911	918	918	925	932
	.14	\$ 1029	1029	1036	1036	1043	1050	1050	1057	1057	1064	1071
	.16	\$ 1168	1168	1175	1175	1182	1189	1189	1196	1196	1203	1210
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 452	452	459	466	466	473	479	479	486	493	500
	.06	\$ 528	528	535	542	542	549	556	556	563	570	577
	.07	\$ 605	605	612	619	619	626	633	633	646	653	653
	.08	\$ 688	688	695	702	702	709	716	716	723	730	737
	.09	\$ 765	765	772	779	779	786	793	793	799	806	813
	.10	\$ 848	848	855	862	862	869	876	876	883	890	897
	.12	\$ 1001	1001	1008	1015	1015	1022	1029	1029	1036	1043	1050
	.14	\$ 1161	1161	1168	1175	1175	1182	1189	1189	1196	1203	1210
	.16	\$ 1321	1321	1328	1335	1335	1342	1349	1349	1356	1363	1370
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 556	563	570	577	584	591	598	605	612	626	639
	.06	\$ 653	660	667	674	681	688	695	702	709	723	737
	.07	\$ 744	751	758	765	772	779	786	793	799	813	827
	.08	\$ 841	848	855	862	869	876	883	890	897	911	925
	.09	\$ 932	939	946	952	959	966	973	980	987	1001	1015
	.10	\$ 1029	1036	1043	1050	1057	1064	1071	1078	1085	1099	1112
	.12	\$ 1217	1224	1231	1238	1245	1252	1259	1266	1272	1286	1300
	.14	\$ 1405	1412	1419	1426	1432	1439	1446	1453	1460	1474	1488
	.16	\$ 1592	1599	1606	1613	1620	1627	1634	1641	1648	1662	1676
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 681	695	709	723	737	751	765	772	786	813	841
	.06	\$ 786	799	813	827	841	855	869	876	890	918	946
	.07	\$ 883	897	911	925	939	952	966	973	987	1015	1043
	.08	\$ 987	1001	1015	1029	1043	1057	1071	1078	1092	1119	1147
	.09	\$ 1092	1106	1119	1133	1147	1161	1175	1182	1196	1224	1252
	.10	\$ 1196	1210	1224	1238	1252	1266	1279	1286	1300	1328	1356
	.12	\$ 1405	1419	1432	1446	1460	1474	1488	1495	1509	1537	1565
	.14	\$ 1613	1627	1641	1655	1669	1683	1697	1704	1718	1745	1773
	.16	\$ 1822	1836	1850	1864	1878	1892	1905	1912	1926	1954	1982
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504	2504
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 876	911	946	973	1008	1036	1071	1106	1133	1203	1266
	.06	\$ 973	1008	1043	1071	1106	1133	1168	1203	1231	1300	1363
	.07	\$ 1071	1106	1140	1168	1203	1231	1266	1300	1328	1398	1460
	.08	\$ 1168	1203	1238	1266	1300	1328	1363	1398	1426	1495	1558
	.09	\$ 1266	1300	1335	1363	1398	1426	1460	1495	1523	1592	1655
	.10	\$ 1363	1398	1432	1460	1495	1523	1558	1592	1620	1690	1752
	.12	\$ 1558	1592	1627	1655	1690	1718	1752	1787	1815	1885	1947
	.14	\$ 1752	1787	1822	1850	1912	1947	1982	2010	2079	2142	2142
	.16	\$ 1954	1989	2024	2052	2086	2114	2149	2184	2212	2281	2344
80,000	\$ 1426	1551	1669	1787	1905	2024	2142	2260	2385	2622	2858	2858
	--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 1050	1092	1140	1189	1238	1286	1328	1377	1426	1523	1613
	.06	\$ 1147	1189	1238	1286	1335	1384	1426	1474	1523	1620	1711
	.07	\$ 1245	1286	1335	1384	1432	1481	1523	1572	1620	1718	1808
	.08	\$ 1342	1384	1432	1481	1530	1579	1620	1669	1718	1785	1905
	.09	\$ 1439	1481	1530	1579	1627	1676	1718	1766	1815	1912	2003
	.10	\$ 1537	1579	1627	1676	1725	1773	1815	1864	1912	2010	2100
	.12	\$ 1732	1773	1822	1871	1919	1968	2010	2059	2107	2205	2295
	.14	\$ 1926	1968	2017	2065	2114	2163	2205	2253	2302	2399	2490
	.16	\$ 2114	2156	2205	2253	2302	2351	2392	2441	2490	2587	2678

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 49 59 69 79 89 99 119 139 159

--ELECTRIC RATE \$/KWH
 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 24UHPQA INDOOR A30AO-A
 ARI RATED COOLING CAP.: BTUH(95) 24000 SEER 9.69
 ARI RATED HEATING CAP.: BTUH (47) 24800 COP(47) 2.90 BSPP 6.40 MIN.DER REG IV
 BTUH (17) 12500 COP(17) 1.90
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH KLEC.
 COST
 \$/KWH

25,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	473	772
.06	\$	570	929
.07	\$	667	1085
.08	\$	765	1238
.09	\$	855	1391
.10	\$	952	1544
.12	\$	1147	1857
.14	\$	1335	2170
.16	\$	1523	2476

BALANCE POINT 16 DEG.F.

30,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	577	925
.06	\$	695	1112
.07	\$	806	1300
.08	\$	925	1488
.09	\$	1043	1669
.10	\$	1154	1857
.12	\$	1384	2232
.14	\$	1613	2601
.16	\$	1843	2977

BALANCE POINT 20 DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	681	1085
.06	\$	820	1300
.07	\$	952	1516
.08	\$	1092	1732
.09	\$	1224	1947
.10	\$	1363	2170
.12	\$	1634	2601
.14	\$	1912	3039
.16	\$	2191	3471

BALANCE POINT 24 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	793	1238
.06	\$	952	1488
.07	\$	1106	1732
.08	\$	1272	1982
.09	\$	1426	2232
.10	\$	1579	2476
.12	\$	1899	2977
.14	\$	2212	3471
.16	\$	2532	3965

BALANCE POINT 27 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1029	1544
.06	\$	1231	1857
.07	\$	1439	2170
.08	\$	1648	2476
.09	\$	1850	2789
.10	\$	2059	3095
.12	\$	2469	3721
.14	\$	2879	4340
.16	\$	3290	4959

BALANCE POINT 31 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.59	.69	.79	.89	.99	1.18	1.38	1.58
--------	-----	-----	-----	-----	-----	------	------	------

<--ELECTRIC RATE \$/KWH	<--THEORETICAL AIR CONDITIONING COST
-------------------------	--------------------------------------

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

		24UHPOA/A30AO-A											
REGION 5		OUTDOOR 24UHPOA						INDOOR A30AO-A					
ARI RATED COOLING CAP.: BTUH(95)	BTUH(47)	24000 SEER 9.69						BTUH(17) 12500 COP(17) 1.90					
ARI RATED HEATING CAP.: BTUH(47)	BTUH(17)	24800 COP(47) 2.90, BSPP 6.40 MIN.DHR REG IV						FURNACE EFFICIENCY 78.00 % AFUE					
HEAT LOSS BTUH	ELEC. COST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
25,000	\$ 236	271	299	333	368	403	438	473	507	542	605	674	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 347	354	368	375	389	396	410	417	431	438	459	479
	.06	\$ 396	403	417	424	438	445	459	466	479	486	507	528
	.07	\$ 452	459	473	479	493	500	514	521	535	542	563	584
	.08	\$ 507	514	528	535	549	556	570	577	591	598	619	639
	.09	\$ 563	570	584	591	605	612	626	633	646	653	674	695
	.10	\$ 612	619	633	639	653	660	674	681	695	702	723	744
	.12	\$ 723	730	744	751	765	772	786	793	806	813	834	855
	.14	\$ 827	834	848	855	869	876	890	897	911	918	939	959
	.16	\$ 939	946	959	966	980	987	1001	1008	1022	1029	1050	1071
30,000	\$ 278	319	361	403	445	486	528	563	605	646	730	813	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 382	403	417	431	452	466	479	500	514	528	563	591
	.06	\$ 438	459	473	486	507	521	535	556	570	584	619	646
	.07	\$ 493	514	528	542	563	577	591	612	626	639	674	702
	.08	\$ 549	570	584	598	619	633	646	667	681	695	730	758
	.09	\$ 598	619	633	646	667	681	695	716	730	744	779	806
	.10	\$ 653	674	688	702	723	737	751	772	786	799	834	862
	.12	\$ 765	786	799	813	834	848	862	883	897	911	946	973
	.14	\$ 869	890	904	918	939	952	966	987	1001	1015	1050	1078
	.16	\$ 980	1001	1015	1029	1050	1064	1078	1099	1112	1126	1161	1189
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 417	445	466	486	514	535	563	584	612	633	681	730
	.06	\$ 473	500	521	542	570	591	619	639	667	688	737	786
	.07	\$ 521	549	570	591	619	639	667	688	716	737	786	834
	.08	\$ 570	598	619	639	667	688	716	737	765	786	834	883
	.09	\$ 619	646	667	688	716	737	765	786	813	834	883	932
	.10	\$ 674	702	723	744	772	793	820	841	869	890	939	987
	.12	\$ 772	799	820	841	869	890	918	939	966	987	1036	1085
	.14	\$ 876	904	925	946	973	994	1022	1043	1071	1092	1140	1189
	.16	\$ 973	1001	1022	1043	1071	1092	1119	1140	1168	1189	1238	1286
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 452	486	521	556	591	619	653	688	723	758	827	890
	.06	\$ 493	528	563	598	633	660	695	730	765	799	869	932
	.07	\$ 535	570	605	639	674	702	737	772	806	841	911	973
	.08	\$ 577	612	646	681	716	744	779	813	848	883	952	1015
	.09	\$ 619	653	688	723	758	786	820	855	890	925	994	1057
	.10	\$ 660	695	730	765	799	827	862	897	932	966	1036	1099
	.12	\$ 744	779	813	848	883	911	946	980	1015	1050	1119	1182
	.14	\$ 834	869	904	939	973	1001	1036	1071	1106	1140	1210	1272
	.16	\$ 918	952	987	1022	1057	1085	1119	1154	1189	1224	1293	1356
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 556	598	639	681	723	765	806	848	890	932	1022	1106
	.06	\$ 605	646	688	730	772	813	855	897	939	980	1071	1154
	.07	\$ 660	702	744	786	827	869	911	952	994	1036	1126	1210
	.08	\$ 709	751	793	834	876	918	959	1001	1043	1085	1175	1259
	.09	\$ 758	799	841	883	925	966	1008	1050	1092	1133	1224	1307
	.10	\$ 813	855	897	939	980	1022	1064	1106	1147	1189	1279	1363
	.12	\$ 911	952	994	1036	1078	1119	1161	1203	1245	1286	1377	1460
	.14	\$ 1015	1057	1099	1140	1182	1224	1266	1307	1349	1391	1481	1565
	.16	\$ 1119	1161	1203	1245	1286	1328	1370	1412	1453	1495	1586	1669

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05	.06	.07	.08	.09	.10	.12	.14	.16
\$.49	.59	.69	.79	.89	.99	118	138	158

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 24UHPOA/A30AO-A
HEAT PUMP MODEL: OUTDOOR 24UHPOA INDOOR A30AO-A
ARI RATED COOLING CAP.: BTUH(95) 24000, SEER 9.69
ARI RATED HEATING CAP.: BTUH (47) 24800, COP(47) 2.90, BSPF 6.40 MIN.DER REG IV
BTUH (17) 12500, COP(17) 1.90
FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
25,000	\$ 340	389	438	486	535	584	633	681	730	779	827	876	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 375	389	403	424	438	452	466	479	493	514	528	542
	.06	\$ 424	438	452	473	486	500	514	528	542	563	577	591
	.07	\$ 479	493	507	527	542	556	570	584	598	619	633	646
	.08	\$ 535	549	563	584	598	612	626	639	653	674	688	702
	.09	\$ 591	605	619	639	653	667	681	695	709	730	744	758
	.10	\$ 639	653	667	688	702	716	730	744	758	779	793	806
	.12	\$ 751	765	779	799	813	827	841	855	869	890	904	918
	.14	\$ 855	869	883	904	918	932	946	959	973	994	1008	1022
	.16	\$ 966	980	994	1015	1029	1043	1057	1071	1085	1106	1119	1133
30,000	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 431	459	479	500	528	549	577	598	619	646	667	688
	.06	\$ 486	514	535	556	584	605	633	653	674	702	723	744
	.07	\$ 542	570	591	612	639	660	688	709	730	758	779	799
	.08	\$ 598	626	646	667	695	716	744	765	786	813	834	855
	.09	\$ 646	674	695	716	744	765	793	813	834	862	883	904
	.10	\$ 702	730	751	772	799	820	848	869	890	918	939	959
	.12	\$ 813	841	862	883	911	932	959	980	1001	1029	1050	1071
	.14	\$ 918	946	966	987	1015	1036	1064	1085	1106	1133	1154	1175
	.16	\$ 1029	1057	1078	1099	1126	1147	1175	1196	1217	1245	1266	1286
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 493	528	563	598	633	667	702	730	765	799	834	869
	.06	\$ 549	584	619	653	688	723	758	786	820	855	890	925
	.07	\$ 598	633	667	702	737	772	806	834	869	904	939	973
	.08	\$ 646	681	716	751	786	820	855	883	918	952	987	1022
	.09	\$ 695	730	765	799	834	869	904	932	966	1001	1036	1071
	.10	\$ 751	786	820	855	890	925	959	987	1022	1057	1092	1126
	.12	\$ 848	883	918	952	987	1022	1057	1085	1119	1154	1189	1224
	.14	\$ 952	987	1022	1057	1092	1126	1161	1189	1224	1259	1293	1328
	.16	\$ 1050	1085	1119	1154	1189	1224	1259	1286	1321	1356	1391	1426
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	13	405	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 556	605	653	702	751	799	848	897	946	994	10	399
	.06	\$ 598	646	695	744	793	841	890	939	987	1036	1083	1140
	.07	\$ 639	688	737	786	834	883	932	980	1029	1078	1126	1182
	.08	\$ 681	730	779	827	876	925	973	1022	1071	1119	1168	1224
	.09	\$ 723	772	820	869	918	966	1015	1064	1112	1161	1210	1266
	.10	\$ 765	813	862	911	959	1008	1057	1106	1154	1203	1252	1307
	.12	\$ 848	897	946	994	1043	1092	1140	1189	1238	1286	1335	1391
	.14	\$ 939	987	1036	1085	1133	1182	1231	1279	1328	1377	1426	1481
	.16	\$ 1022	1071	1119	1168	1217	1266	1314	1363	1412	1460	1509	1565
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 681	744	806	869	932	987	1050	1112	1175	1238	1293	1356
	.06	\$ 730	793	855	918	980	1036	1099	1161	1224	1286	1342	1405
	.07	\$ 786	848	911	973	1036	1092	1154	1217	1279	1342	1398	1460
	.08	\$ 834	897	959	1022	1085	1140	1203	1266	1328	1391	1446	1509
	.09	\$ 883	946	1008	1071	1133	1189	1252	1314	1377	1439	1495	1558
	.10	\$ 939	1001	1064	1126	1189	1245	1307	1370	1432	1495	1551	1613
	.12	\$ 1036	1099	1161	1224	1286	1342	1405	1467	1530	1592	1648	1711
	.14	\$ 1140	1203	1266	1328	1391	1446	1509	1572	1634	1697	1752	1815
	.16	\$ 1245	1307	1370	1432	1495	1551	1613	1676	1739	1801	1857	1919

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S .05 .06 .07 .08 .09 .10 .12 .14 .16
 S 49 59 69 79 89 99 118 138 158

--ELECTRIC RATE \$/KWH
 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 24UHPOA INDOOR A30AO-A
 ARI RATED COOLING CAP.: BTUH(95) 24000 SEER 9.69
 ARI RATED HEATING CAP.: BTUH (47) 24800 COP(47) 2.90, EER 6.40 MIN.DHR REG IV
 BTUH (17) 12500, COP(17) 1.90
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20
25,000	\$ 445	479	521	556	591	633	667	702	744	813	890	890	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 410	417	431	445	452	466	479	486	500	521	549	549
	.06	\$ 459	466	479	493	500	514	528	535	549	570	598	598
	.07	\$ 514	521	535	549	556	570	584	591	605	626	653	653
	.08	\$ 570	577	591	605	612	626	639	646	660	681	709	709
	.09	\$ 626	633	646	660	667	681	695	702	716	737	765	765
	.10	\$ 674	681	695	709	716	730	744	751	765	786	813	813
	.12	\$ 786	793	806	820	827	841	855	862	876	897	925	925
	.14	\$ 890	897	911	925	932	946	959	966	980	1001	1029	1029
	.16	\$ 1001	1008	1022	1036	1043	1057	1071	1078	1092	1112	1140	1140
30,000	\$ 535	577	626	667	709	758	799	848	890	980	1071	1071	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 486	500	521	535	556	570	591	605	626	660	695	695
	.06	\$ 542	556	577	591	612	626	646	660	681	716	751	751
	.07	\$ 598	612	633	646	667	681	702	716	737	772	806	806
	.08	\$ 653	667	688	702	723	737	758	772	793	821	862	862
	.09	\$ 702	716	737	751	772	786	806	820	841	876	911	911
	.10	\$ 758	772	793	806	827	841	862	876	897	932	966	966
	.12	\$ 869	883	904	918	939	952	973	987	1008	1043	1078	1078
	.14	\$ 973	987	1008	1022	1043	1057	1078	1092	1112	1147	1182	1182
	.16	\$ 1085	1099	1119	1133	1154	1168	1189	1203	1224	1259	1293	1293
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 563	591	619	646	674	695	723	751	779	827	883	883
	.06	\$ 619	646	674	702	730	751	779	806	834	883	939	939
	.07	\$ 667	695	723	751	779	827	855	883	932	987	987	987
	.08	\$ 716	744	772	799	827	848	876	904	932	980	1036	1036
	.09	\$ 765	793	820	848	876	897	925	952	980	1029	1085	1085
	.10	\$ 820	848	876	904	932	952	980	1008	1036	1085	1140	1140
	.12	\$ 918	946	973	1001	1029	1050	1078	1106	1133	1182	1238	1238
	.14	\$ 1022	1050	1078	1106	1133	1154	1182	1210	1238	1286	1342	1342
	.16	\$ 1119	1147	1175	1203	1231	1252	1279	1307	1335	1384	1439	1439
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 660	702	737	772	813	848	883	925	959	1036	1112	1112
	.06	\$ 702	744	779	813	855	890	925	966	1001	1078	1154	1154
	.07	\$ 744	786	820	855	897	932	966	1008	1043	1119	1196	1196
	.08	\$ 786	827	862	897	939	973	1008	1050	1085	1161	1238	1238
	.09	\$ 827	869	904	939	980	1015	1050	1092	1126	1203	1279	1279
	.10	\$ 869	911	946	980	1022	1057	1092	1133	1168	1245	1321	1321
	.12	\$ 952	994	1029	1064	1106	1140	1175	1217	1252	1328	1405	1405
	.14	\$ 1043	1085	1119	1154	1196	1231	1266	1307	1342	1419	1495	1495
	.16	\$ 1126	1168	1203	1238	1279	1314	1349	1391	1426	1502	1579	1579
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 813	862	911	952	1001	1050	1099	1140	1189	1279	1377	1377
	.06	\$ 862	911	959	1001	1050	1099	1147	1189	1238	1328	1426	1426
	.07	\$ 918	966	1015	1057	1106	1154	1203	1245	1293	1384	1481	1481
	.08	\$ 966	1015	1064	1106	1154	1203	1252	1293	1342	1432	1530	1530
	.09	\$ 1015	1064	1112	1154	1203	1252	1300	1342	1391	1481	1579	1579
	.10	\$ 1071	1119	1168	1210	1259	1307	1356	1398	1446	1537	1634	1634
	.12	\$ 1168	1217	1266	1307	1356	1405	1453	1495	1544	1634	1732	1732
	.14	\$ 1272	1321	1370	1412	1460	1509	1558	1599	1648	1739	1836	1836
	.16	\$ 1377	1426	1474	1516	1565	1613	1662	1704	1752	1843	1940	1940

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 49 59 69 79 89 99 118 138 158

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 24UHPQB/A36AO-A
 HEAT PUMP MODEL: OUTDOOR 24UHPQB INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 23000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 23600 COP(47) 3.10, HSPF 7.50 MIN.DER REG IV
 BTUH (17) 14200 COP(17) 2.10
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH ELEC.
COST
S/KWH

25,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	417	772
.06	\$	500	925
.07	\$	584	1085
.08	\$	667	1238
.09	\$	758	1391
.10	\$	841	1544
.12	\$	1008	1857
.14	\$	1175	2170
.16	\$	1342	2476

BALANCE POINT 13 DEG.F.

30,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	507	925
.06	\$	612	1112
.07	\$	716	1300
.08	\$	813	1488
.09	\$	918	1669
.10	\$	1022	1857
.12	\$	1231	2232
.14	\$	1432	2601
.16	\$	1634	2977

BALANCE POINT 18 DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	605	1085
.06	\$	730	1300
.07	\$	848	1516
.08	\$	973	1732
.09	\$	1092	1947
.10	\$	1217	2170
.12	\$	1460	2601
.14	\$	1704	3039
.16	\$	1947	3471

BALANCE POINT 22 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	709	1238
.06	\$	855	1488
.07	\$	1001	1732
.08	\$	1147	1982
.09	\$	1286	2232
.10	\$	1432	2476
.12	\$	1711	2977
.14	\$	2003	3471
.16	\$	2288	3965

BALANCE POINT 25 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	946	1544
.06	\$	1133	1857
.07	\$	1321	2170
.08	\$	1509	2476
.09	\$	1697	2789
.10	\$	1885	3095
.12	\$	2260	3721
.14	\$	2643	4340
.16	\$	3018	4959

BALANCE POINT 31 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S .05	.06	.07	.08	.09	.10	.12	.14	.16
S 43	52	61	70	78	87	105	122	140

<--ELECTRIC RATE S/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 24UHPOB 24UHPQB/A36AO-A
 INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 23000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 23600 COP(47) 3.10, ESSPF 7.50 MIN.DR REG IV
 BTUH (17) 14200 COP(17) 2.10
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	.1.00
25,000	\$ 236	271	299	333	368	403	438	473	507	542	605	674	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 313	319	333	340	354	361	375	382	396	403	424	445
	.06	\$ 354	361	375	382	396	403	417	424	438	445	466	486
	.07	\$ 403	410	424	431	445	452	466	473	486	493	514	535
	.08	\$ 452	459	473	479	493	500	514	521	535	542	563	584
	.09	\$ 500	507	521	528	542	549	563	570	584	591	612	633
	.10	\$ 542	549	563	570	584	591	605	612	626	633	653	674
	.12	\$ 639	646	660	667	681	688	702	709	723	730	751	772
	.14	\$ 730	737	751	758	772	779	793	799	813	820	841	862
	.16	\$ 827	834	848	855	869	876	890	897	911	918	939	959
30,000	\$ 278	319	361	403	445	486	528	563	605	646	730	813	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 347	368	382	396	417	431	445	466	479	493	528	556
	.06	\$ 396	417	431	445	466	479	493	514	528	542	577	605
	.07	\$ 445	466	479	493	514	528	542	563	577	591	626	653
	.08	\$ 486	501	521	535	556	570	584	605	619	633	667	695
	.09	\$ 535	556	570	584	605	619	633	653	667	681	716	744
	.10	\$ 584	605	619	633	653	667	681	702	716	730	765	793
	.12	\$ 681	702	716	730	751	765	779	793	813	827	862	890
	.14	\$ 772	793	806	820	841	855	869	890	904	918	952	980
	.16	\$ 869	890	904	918	939	952	966	987	1001	1015	1050	1078
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 389	417	438	459	486	507	535	556	584	605	653	702
	.06	\$ 431	459	479	500	528	549	577	598	626	646	695	744
	.07	\$ 473	500	521	542	570	591	619	639	667	688	737	786
	.08	\$ 521	549	570	591	619	639	667	688	716	737	786	834
	.09	\$ 563	591	612	633	660	681	709	730	758	779	827	876
	.10	\$ 605	633	653	674	702	723	751	772	799	820	869	918
	.12	\$ 695	723	744	765	793	813	841	862	890	911	959	1008
	.14	\$ 779	806	827	848	876	897	925	946	973	994	1043	1092
	.16	\$ 869	897	918	939	966	987	1015	1036	1064	1085	1133	1182
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 445	466	493	521	549	577	605	633	660	688	744	799
	.06	\$ 493	514	542	570	598	626	653	681	709	737	793	848
	.07	\$ 542	563	591	619	646	674	702	730	758	786	841	897
	.08	\$ 591	612	639	667	695	723	751	779	806	834	890	946
	.09	\$ 639	660	688	716	744	772	799	827	855	883	939	994
	.10	\$ 688	709	737	765	793	820	848	876	904	932	987	1043
	.12	\$ 793	813	841	869	897	925	952	980	1008	1036	1092	1147
	.14	\$ 890	911	939	966	994	1022	1050	1078	1106	1133	1189	1245
	.16	\$ 987	1008	1036	1064	1092	1119	1147	1175	1203	1231	1286	1342
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 521	563	605	646	688	730	772	813	855	897	987	1071
	.06	\$ 570	612	653	695	737	779	820	862	904	946	1036	1119
	.07	\$ 612	653	695	737	779	820	862	904	946	987	1078	1161
	.08	\$ 660	702	744	786	827	869	911	952	994	1036	1126	1210
	.09	\$ 702	744	786	827	869	911	952	994	1036	1078	1168	1252
	.10	\$ 751	793	834	876	918	959	1001	1043	1085	1126	1217	1300
	.12	\$ 841	883	925	966	1008	1050	1092	1133	1175	1217	1307	1391
	.14	\$ 925	966	1008	1050	1092	1133	1175	1217	1259	1300	1391	1474
	.16	\$ 1015	1057	1099	1140	1182	1224	1266	1307	1349	1391	1481	1565

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

 --ELECTRIC RATE \$/KWH
 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 24UHPQB INDOOR A36AO-A
ARI RATED COOLING CAP.: BTUB(95) 23000 SEER10.50
ARI RATED HEATING CAP.: BTUB (47) 23500 COP(47) 3.10, BSPP 7.50 MIN.DER REG IV
BTUB (17) 14200 COP(17) 2.10
FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	KLEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
25,000	\$ 340	389	438	486	535	584	633	681	730	779	827	876	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 340	354	368	389	403	417	431	445	459	479	493	507
	.06	\$ 382	396	410	431	445	459	473	486	500	521	535	549
	.07	\$ 431	445	459	479	493	507	521	535	549	570	584	598
	.08	\$ 479	493	507	528	542	556	570	584	598	619	633	646
	.09	\$ 528	542	556	577	591	605	619	633	646	667	681	695
	.10	\$ 570	584	598	619	633	646	660	674	688	709	723	737
	.12	\$ 667	681	695	716	730	744	758	772	786	806	820	834
	.14	\$ 758	772	786	806	820	834	848	862	876	897	911	925
	.16	\$ 855	869	883	904	918	932	946	959	973	994	1008	1022
													BALANCE POINT 13 DEG.F.
30,000	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 396	424	445	466	493	514	542	563	584	612	633	653
	.06	\$ 445	473	493	514	542	563	591	612	633	660	681	702
	.07	\$ 493	521	542	563	591	612	639	660	681	709	730	751
	.08	\$ 535	563	584	605	633	653	681	702	723	751	772	793
	.09	\$ 584	612	633	653	681	702	730	751	772	799	820	841
	.10	\$ 633	660	681	702	730	751	779	799	820	848	869	890
	.12	\$ 730	758	779	799	827	848	876	897	918	946	966	987
	.14	\$ 820	848	869	890	918	939	966	987	1008	1036	1057	1078
	.16	\$ 918	946	966	987	1015	1036	1064	1085	1106	1133	1154	1175
													BALANCE POINT 18 DEG.F.
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 466	500	535	570	605	639	674	702	737	772	806	841
	.06	\$ 507	542	577	612	646	681	716	744	779	813	848	883
	.07	\$ 549	584	619	653	688	723	758	786	820	855	890	925
	.08	\$ 598	633	667	702	737	772	806	834	869	904	939	973
	.09	\$ 639	674	709	744	779	813	848	876	911	946	980	1015
	.10	\$ 681	716	751	786	820	855	890	918	952	987	1022	1057
	.12	\$ 772	806	841	876	911	946	980	1008	1043	1078	1112	1147
	.14	\$ 855	890	925	959	994	1029	1064	1092	1126	1161	1196	1231
	.16	\$ 946	980	1015	1050	1085	1119	1154	1182	1217	1252	1286	1321
													BALANCE POINT 22 DEG.F.
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 528	563	605	646	681	723	765	799	841	883	918	959
	.06	\$ 577	612	653	695	730	772	813	848	890	932	966	1008
	.07	\$ 626	660	702	744	779	820	862	897	939	980	1015	1057
	.08	\$ 674	709	751	793	827	869	911	946	987	1029	1064	1106
	.09	\$ 723	758	799	841	876	918	959	994	1036	1078	1112	1154
	.10	\$ 772	806	848	890	925	966	1008	1043	1085	1126	1161	1203
	.12	\$ 876	911	952	994	1029	1071	1112	1147	1189	1231	1266	1307
	.14	\$ 973	1008	1050	1092	1126	1168	1210	1245	1286	1328	1363	1405
	.16	\$ 1071	1106	1147	1189	1224	1266	1307	1342	1384	1426	1460	1502
													BALANCE POINT 25 DEG.F.
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 646	709	772	834	897	952	1015	1078	1140	1203	1259	1321
	.06	\$ 695	758	820	883	946	1001	1064	1126	1189	1252	1307	1370
	.07	\$ 737	799	862	925	987	1043	1106	1168	1231	1293	1349	1412
	.08	\$ 786	848	911	973	1036	1092	1154	1217	1279	1342	1398	1460
	.09	\$ 827	890	952	1015	1078	1133	1196	1259	1321	1384	1439	1502
	.10	\$ 876	939	1001	1064	1126	1182	1245	1307	1370	1432	1488	1551
	.12	\$ 966	1029	1092	1154	1217	1272	1335	1398	1460	1523	1579	1641
	.14	\$ 1050	1112	1175	1238	1300	1356	1419	1481	1544	1606	1662	1725
	.16	\$ 1140	1203	1266	1328	1391	1446	1509	1572	1634	1697	1752	1815
													BALANCE POINT 31 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.06	.07	.08	.09	.10	.12	.14	.16	--ELECTRIC RATE \$/KWH
43	52	61	70	78	87	105	122	140	<<THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 24UHPOB INDOOR A36AO-A
ARI RATED COOLING CAP.: BTUH(95) 23000 SEER10.50
ARI RATED HEATING CAP.: BTUH (47) 23600 COP(47) 3.10, ESEPF 7.50 MIN.DHR REG IV
BTUH (17) 14200 COP(17) 2.10
FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20
25,000	\$	445	479	521	556	591	633	667	702	744	813	890	890
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	375	382	396	410	417	431	445	452	466	486	514	514
.06	\$	417	424	438	452	459	473	486	493	507	528	556	556
.07	\$	466	473	486	500	507	521	535	542	556	577	605	605
.08	\$	514	521	535	549	556	570	584	591	605	626	653	653
.09	\$	563	570	584	598	605	619	633	639	653	674	702	702
.10	\$	605	612	626	639	646	660	674	681	695	716	744	744
.12	\$	702	709	723	737	744	758	772	779	793	813	841	841
.14	\$	793	799	813	827	834	848	862	869	883	904	932	932
.16	\$	890	897	911	925	932	946	959	966	980	1001	1029	1029
		THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR											
		BALANCE POINT 13 DEG.F.											
30,000	\$	535	577	626	667	709	758	799	848	890	980	1071	1071
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	452	466	486	500	521	535	556	570	591	626	660	660
.06	\$	500	514	535	549	570	584	605	619	639	674	709	709
.07	\$	549	563	584	598	619	633	653	667	688	723	758	758
.08	\$	591	605	626	639	660	674	695	709	730	765	799	799
.09	\$	639	653	674	688	709	723	744	758	779	813	848	848
.10	\$	688	702	723	737	758	772	793	806	827	862	897	897
.12	\$	786	799	820	834	855	869	890	904	925	959	994	994
.14	\$	876	890	911	925	946	959	980	994	1015	1050	1085	1085
.16	\$	973	987	1008	1022	1043	1057	1078	1092	1112	1147	1182	1182
		BALANCE POINT 18 DEG.F.											
35,000	\$	626	674	730	779	834	883	939	987	1043	1147	1252	1252
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	535	563	591	619	646	667	695	723	751	799	855	855
.06	\$	577	605	633	660	688	709	737	765	793	841	897	897
.07	\$	619	646	674	702	730	751	779	806	834	883	939	939
.08	\$	667	695	723	751	779	799	827	855	883	932	987	987
.09	\$	709	737	765	793	820	841	869	897	925	973	1029	1029
.10	\$	751	779	806	834	862	883	911	939	966	1015	1071	1071
.12	\$	841	869	897	925	952	973	1001	1029	1057	1106	1161	1161
.14	\$	925	952	980	1008	1036	1057	1085	1112	1140	1189	1245	1245
.16	\$	1015	1043	1071	1099	1126	1147	1175	1203	1231	1279	1335	1335
		BALANCE POINT 22 DEG.F.											
40,000	\$	709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	612	639	674	702	730	758	793	820	848	911	973	973
.06	\$	660	688	723	751	779	806	841	869	897	959	1022	1022
.07	\$	709	737	772	799	827	855	890	918	946	1008	1071	1071
.08	\$	758	786	820	848	876	904	939	966	994	1057	1119	1119
.09	\$	806	834	869	897	925	952	987	1015	1043	1106	1168	1168
.10	\$	855	883	918	946	973	1001	1036	1064	1092	1154	1217	1217
.12	\$	959	987	1022	1050	1078	1106	1140	1168	1196	1259	1321	1321
.14	\$	1057	1085	1119	1147	1175	1203	1238	1266	1293	1356	1419	1419
.16	\$	1154	1182	1217	1245	1272	1300	1335	1363	1391	1453	1516	1516
		BALANCE POINT 25 DEG.F.											
50,000	\$	890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787
		--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$	779	827	876	918	966	1015	1064	1106	1154	1245	1342	1342
.06	\$	827	876	925	966	1015	1064	1112	1154	1203	1293	1391	1391
.07	\$	869	918	966	1008	1057	1106	1154	1196	1245	1335	1432	1432
.08	\$	918	966	1015	1057	1106	1154	1203	1245	1293	1384	1481	1481
.09	\$	959	1008	1057	1099	1147	1196	1245	1286	1335	1426	1523	1523
.10	\$	1008	1057	1106	1147	1196	1245	1293	1335	1384	1474	1572	1572
.12	\$	1099	1147	1196	1238	1286	1335	1384	1426	1474	1565	1662	1662
.14	\$	1182	1231	1279	1321	1370	1419	1467	1509	1558	1648	1745	1745
.16	\$	1272	1321	1370	1412	1460	1509	1558	1599	1648	1739	1836	1836
		BALANCE POINT 31 DEG.F.											

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

s .05 .06 .07 .08 .09 .10 .12 .14 .16	<--ELECTRIC RATE \$/KWH
s 43 52 61 70 78 87 105 122 140	<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHP08 INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 28200, SEER 9.19
 ARI RATED HEATING CAP.: BTUH (47) 29800, COP(47) 3.00, ESPF 6.90 MIN.DR REG IV
 BTUH (17) 16400, COP(17) 2.10
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH ELEC.
 COST
 \$/KWH

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	626	1085
.06	\$	751	1300
.07	\$	876	1516
.08	\$	1001	1732
.09	\$	1126	1947
.10	\$	1251	2170
.12	\$	1502	2601
.14	\$	1752	3039
.16	\$	2003	3471

BALANCE POINT 18 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	723	1238
.06	\$	869	1488
.07	\$	1008	1732
.08	\$	1154	1982
.09	\$	1307	2232
.10	\$	1446	2476
.12	\$	1732	2977
.14	\$	2031	3471
.16	\$	2316	3965

BALANCE POINT 21 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	939	1544
.06	\$	1126	1857
.07	\$	1314	2170
.08	\$	1495	2476
.09	\$	1683	2789
.10	\$	1871	3095
.12	\$	2253	3721
.14	\$	2622	4340
.16	\$	2998	4959

BALANCE POINT 27 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1175	1857
.06	\$	1405	2232
.07	\$	1641	2601
.08	\$	1878	2977
.09	\$	2107	3345
.10	\$	2344	3721
.12	\$	2810	4465
.14	\$	3283	5210
.16	\$	3749	5954

BALANCE POINT 31 DEG.F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1426	2170
.06	\$	1711	2601
.07	\$	1996	3039
.08	\$	2281	3471
.09	\$	2566	3902
.10	\$	2852	4340
.12	\$	322	5210
.14	\$	3992	6079
.16	\$	4570	6942

BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S	.05	.06	.07	.08	.09	.10	.12	.14	.16
S	61	73	85	98	110	122	147	171	196

<-ELECTRIC RATE \$/KWH
 <-THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHPQB INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 28200 SEER 9.19
 ARI RATED HEATING CAP.: BTUH (47) 29800 COP(47) 3.00, BSPF 6.90 MIN.DHR REG IV
 BTUH (17) 16400 COP(17) 2.10
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC COST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
NATURAL GAS COST - \$/THERM													
30,000	\$ 278	319	361	403	445	486	528	563	605	646	730	813	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 396	403	417	431	445	459	466	479	493	507	528	556	
.06	\$ 452	459	473	486	500	514	521	535	549	563	584	612	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 514	521	535	549	563	577	584	598	612	626	646	674	
.08	\$ 577	584	598	612	626	639	646	660	674	688	709	737	
.09	\$ 633	639	653	667	681	695	702	716	730	744	765	793	
.10	\$ 695	702	716	730	744	758	765	779	793	806	827	855	
.12	\$ 820	827	841	855	869	883	890	904	918	932	952	980	
.14	\$ 939	946	959	973	987	1001	1008	1022	1036	1050	1071	1099	
.16	\$ 1057	1064	1078	1092	1106	1119	1126	1140	1154	1168	1189	1217	BALANCE POINT 14 DEG.F.
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 431	452	466	486	507	528	542	563	584	598	639	674	
.06	\$ 493	514	528	549	570	591	605	626	646	660	702	737	THEORETICAL BEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 549	570	584	605	626	646	660	681	702	716	758	793	
.08	\$ 612	633	646	667	688	709	723	744	765	779	820	855	
.09	\$ 674	695	709	730	751	772	786	806	827	841	883	918	
.10	\$ 730	751	765	786	806	827	841	862	883	897	939	973	
.12	\$ 848	869	883	904	925	946	959	980	1001	1015	1057	1092	
.14	\$ 973	994	1008	1029	1050	1071	1085	1106	1126	1140	1182	1217	
.16	\$ 1092	1112	1126	1147	1168	1189	1203	1224	1245	1259	1300	1335	BALANCE POINT 18 DEG.F.
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 486	507	528	549	570	591	612	633	653	681	723	765	
.06	\$ 556	577	598	619	639	660	681	702	723	751	793	834	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 626	646	667	688	709	730	751	772	793	820	862	904	
.08	\$ 688	709	730	751	772	793	813	834	855	883	925	966	
.09	\$ 758	779	820	841	862	883	904	925	952	994	1036		
.10	\$ 820	841	862	883	904	925	946	966	987	1015	1057	1099	
.12	\$ 959	980	1001	1022	1043	1064	1085	1106	1126	1154	1196	1238	
.14	\$ 1092	1112	1133	1154	1175	1196	1217	1238	1259	1286	1328	1370	
.16	\$ 1224	1245	1266	1286	1307	1328	1349	1370	1391	1419	1460	1502	BALANCE POINT 21 DEG.F.
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 549	591	633	674	716	758	799	841	883	925	1015	1099	
.06	\$ 598	639	681	723	765	806	848	890	932	973	1064	1147	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 646	688	730	772	813	855	897	939	980	1022	1112	1196	
.08	\$ 702	744	786	827	869	911	952	994	1036	1078	1168	1252	
.09	\$ 751	793	834	876	918	959	1001	1043	1085	1126	1217	1300	
.10	\$ 799	841	883	925	966	1008	1050	1092	1133	1175	1266	1349	
.12	\$ 897	939	980	1022	1064	1106	1147	1189	1231	1272	1363	1446	
.14	\$ 1001	1043	1085	1126	1168	1210	1252	1293	1335	1377	1467	1551	
.16	\$ 1099	1140	1182	1224	1266	1307	1349	1391	1432	1474	1565	1648	BALANCE POINT 27 DEG.F.
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 646	695	751	799	848	904	952	1001	1057	1106	1210	1307	
.06	\$ 702	751	806	855	904	959	1008	1057	1112	1161	1266	1363	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 765	813	869	918	966	1022	1071	1119	1175	1224	1328	1426	
.08	\$ 820	869	925	973	1022	1078	1126	1175	1231	1279	1384	1481	
.09	\$ 876	925	980	1029	1078	1133	1182	1231	1286	1335	1439	1537	
.10	\$ 939	987	1043	1092	1140	1196	1245	1293	1349	1398	1502	1599	
.12	\$ 1057	1106	1161	1210	1259	1314	1363	1412	1467	1516	1620	1718	
.14	\$ 1168	1217	1272	1321	1370	1426	1474	1523	1579	1627	1732	1829	
.16	\$ 1286	1335	1391	1439	1488	1544	1592	1641	1697	1745	1850	1947	BALANCE POINT 31 DEG.F.
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 723	793	862	932	1001	1071	1140	1210	1279	1349	1488	1634	
.06	\$ 772	841	911	980	1050	1119	1189	1259	1328	1398	1537	1683	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 813	883	952	1022	1092	1161	1231	1300	1370	1439	1579	1725	
.08	\$ 862	932	1001	1071	1140	1210	1279	1349	1419	1488	1627	1713	
.09	\$ 911	980	1050	1119	1189	1259	1328	1398	1467	1537	1676	1822	
.10	\$ 952	1022	1092	1161	1231	1300	1370	1439	1509	1579	1718	1864	
.12	\$ 1050	1119	1189	1259	1328	1398	1467	1537	1606	1676	1815	1961	
.14	\$ 1140	1210	1279	1349	1419	1488	1558	1627	1697	1766	1905	2052	
.16	\$ 1231	1300	1370	1439	1509	1579	1648	1718	1787	1857	1996	2142	BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16

<--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHP0B INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95°) 28200, SEER 9.19
 ARI RATED HEATING CAP.: BTUH (47°) 29800, COP(47°) 3.00, HSPF 6.90 MIN.DHR REG IV
 BTUH (17°) 16400, COP(17°) 2.10
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	HEATING OIL COST - \$/GALLON	
30,000															
.05	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 431	452	466	486	507	521	542	556	577	598	612	633	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 486	507	521	542	563	577	598	612	633	653	667	688	S PER YEAR		
.08	\$ 549	570	584	605	626	639	660	674	695	716	730	751			
.09	\$ 612	633	646	667	688	702	723	737	758	779	793	813			
.10	\$ 667	688	702	723	744	758	779	793	813	834	848	869			
.11	\$ 730	751	765	786	806	820	841	855	876	897	911	932			
.12	\$ 855	876	890	911	932	946	966	980	1001	1022	1036	1057			
.13	\$ 913	994	1008	1029	1050	1064	1085	1099	1119	1140	1154	1175			
.14	\$ 1092	1112	1126	1147	1168	1182	1203	1217	1238	1259	1272	1293	BALANCE POINT 14 DEG.F.		
.16															
35,000															
.05	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 486	514	542	570	598	626	653	681	709	730	758	786	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 549	577	605	633	660	688	716	744	772	799	827	848	S PER YEAR		
.08	\$ 605	633	660	688	716	744	772	799	827	848	876	904			
.09	\$ 667	695	723	751	779	806	834	862	890	911	939	966			
.10	\$ 730	758	786	813	841	869	897	925	952	973	1001	1029			
.11	\$ 886	813	841	869	897	925	952	980	1008	1029	1057	1085			
.12	\$ 904	932	959	987	1015	1043	1071	1099	1126	1147	1175	1203			
.13	\$ 1029	1057	1085	1112	1140	1168	1196	1224	1252	1272	1300	1328	BALANCE POINT 18 DEG.F.		
.16	\$ 1147	1175	1203	1231	1259	1286	1314	1342	1370	1391	1419	1446			
40,000															
.05	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 549	584	612	646	674	709	737	765	799	827	862	890	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 619	653	681	716	744	779	806	834	869	897	932	959	S PER YEAR		
.08	\$ 688	723	751	786	813	848	876	904	939	966	1001	1029			
.09	\$ 751	786	813	848	876	911	939	966	1001	1029	1064	1092			
.10	\$ 820	855	883	918	946	980	1008	1036	1071	1099	1133	1161			
.11	\$ 883	918	946	980	1008	1043	1071	1099	1133	1161	1196	1224			
.12	\$ 1022	1057	1085	1119	1147	1182	1210	1238	1272	1300	1335	1363			
.13	\$ 1154	1189	1217	1252	1279	1314	1342	1370	1405	1432	1467	1495	BALANCE POINT 21 DEG.F.		
.16	\$ 1286	1321	1349	1384	1412	1446	1474	1502	1537	1565	1599	1627			
50,000															
.05	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 674	737	799	862	925	980	1043	1106	1168	1231	1286	1349	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 723	786	848	911	973	1029	1092	1154	1217	1279	1335	1398	S PER YEAR		
.08	\$ 772	834	897	959	1022	1078	1140	1203	1266	1328	1384	1446			
.09	\$ 827	890	952	1015	1078	1133	1196	1259	1321	1384	1439	1502			
.10	\$ 876	939	1001	1064	1126	1182	1245	1307	1370	1432	1488	1551			
.11	\$ 925	987	1050	1112	1175	1231	1293	1356	1419	1481	1537	1599			
.12	\$ 1022	1085	1147	1210	1272	1328	1391	1453	1516	1579	1634	1697			
.13	\$ 1126	1189	1252	1314	1377	1432	1495	1558	1620	1683	1739	1801	BALANCE POINT 27 DEG.F.		
.16	\$ 1224	1286	1349	1412	1474	1530	1592	1655	1718	1780	1836	1899			
60,000															
.05	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 806	876	952	1022	1099	1175	1245	1321	1391	1467	1537	1613	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 862	932	1008	1078	1154	1231	1300	1377	1446	1523	1592	1669	S PER YEAR		
.08	\$ 925	994	1071	1140	1217	1293	1363	1439	1509	1586	1655	1732			
.09	\$ 980	1050	1126	1196	1272	1349	1419	1495	1565	1641	1711	1787			
.10	\$ 1036	1106	1182	1252	1328	1405	1474	1551	1620	1697	1766	1843			
.11	\$ 1121	1188	1245	1314	1391	1467	1537	1613	1683	1759	1829	1905			
.12	\$ 1217	1286	1363	1432	1509	1586	1655	1732	1801	1878	1947	2024			
.13	\$ 1328	1398	1474	1544	1620	1697	1766	1843	1912	1989	2059	2135	BALANCE POINT 31 DEG.F.		
.16	\$ 1446	1516	1592	1662	1739	1815	1885	1961	2031	2107	2177	2253			
70,000															
.05	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	--THEORETICAL HEATING COST * FURNACE ONLY		
.06	\$ 939	1036	1140	1238	1342	1439	1544	1641	1745	1850	1947	2052	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 987	1085	1189	1286	1391	1488	1592	1690	1794	1899	1996	2100	S PER YEAR		
.08	\$ 1029	1126	1231	1328	1432	1530	1634	1732	1836	1940	2038	2142			
.09	\$ 1078	1175	1279	1377	1481	1579	1683	1780	1885	1989	2086	2191			
.10	\$ 1126	1224	1328	1426	1530	1627	1732	1829	1933	2038	2139	2239			
.11	\$ 1168	1266	1370	1467	1572	1669	1773	1871	1975	2079	2177	2281			
.12	\$ 1266	1363	1467	1565	1669	1766	1871	1968	2072	2177	2274	2379			
.13	\$ 1356	1453	1558	1655	1759	1857	1961	2059	2163	2267	2365	2469	BALANCE POINT 34 DEG.F.		
.16	\$ 1446	1544	1648	1745	1850	1947	2052	2149	2253	2358	2455	2559			

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 <--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 30UHPQB INDOOR A36AO-A
ARI RATED COOLING CAP.: BTUH(95) 28200 SEER 9.19
ARI RATED HEATING CAP.: BTUH (47) 29800 COP(47) 3.00, BHPF 6.90 MIN.DHR REG IV
BTUH (17) 16400 COP(17) 2.10
FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC COST \$/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20
PROPSANE GAS COST - \$/GALLON													
30,000	\$ 535	577	626	667	709	758	799	848	890	980	1071	1071	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 473	486	500	514	528	542	556	570	584	612	633	633	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 528	542	556	570	584	598	612	626	639	667	688	688	S PER YEAR
.07	\$ 591	605	619	633	646	660	674	688	702	730	751	751	
.08	\$ 653	667	681	695	709	723	737	751	765	793	813	813	
.09	\$ 709	723	737	751	765	779	793	806	820	848	869	869	
.10	\$ 772	786	799	813	827	841	855	869	883	911	932	932	
.12	\$ 897	911	925	939	952	966	980	994	1008	1036	1057	1057	
.14	\$ 1015	1029	1043	1057	1071	1085	1099	1112	1126	1154	1175	1175	BALANCE POINT 14 DEG.F.
.16	\$ 1133	1147	1161	1175	1189	1203	1217	1231	1245	1272	1293	1293	
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 549	570	591	612	633	653	674	695	716	751	793	793	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 612	633	653	674	695	716	737	758	779	813	855	855	S PER YEAR
.07	\$ 667	688	709	730	751	772	793	813	834	869	911	911	
.08	\$ 730	751	772	793	813	834	855	876	897	932	973	973	
.09	\$ 793	813	834	855	876	897	918	939	959	994	1036	1036	
.10	\$ 848	869	890	911	932	952	973	994	1015	1050	1092	1092	
.12	\$ 966	987	1008	1029	1050	1071	1092	1112	1133	1168	1210	1210	
.14	\$ 1092	1112	1133	1154	1175	1196	1217	1238	1259	1293	1335	1335	BALANCE POINT 18 DEG.F.
.16	\$ 1210	1231	1252	1272	1293	1314	1335	1356	1377	1412	1453	1453	
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 619	639	667	688	709	737	758	786	806	855	904	904	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 688	709	737	758	779	806	827	855	876	925	973	973	S PER YEAR
.07	\$ 758	779	806	827	848	876	897	925	946	994	1043	1043	
.08	\$ 820	841	869	890	911	939	959	987	1008	1057	1106	1106	
.09	\$ 890	911	939	959	980	1008	1029	1057	1078	1126	1175	1175	
.10	\$ 952	973	1001	1022	1043	1071	1092	1119	1140	1189	1238	1238	
.12	\$ 1092	1112	1140	1161	1182	1210	1231	1259	1279	1328	1377	1377	
.14	\$ 1224	1245	1272	1293	1314	1342	1363	1391	1412	1460	1509	1509	BALANCE POINT 21 DEG.F.
.16	\$ 1356	1377	1405	1426	1446	1474	1495	1523	1544	1592	1641	1641	
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 806	855	904	946	994	1043	1092	1133	1182	1272	1370	1370	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 855	904	952	994	1043	1092	1140	1182	1231	1321	1419	1419	S PER YEAR
.07	\$ 904	952	1001	1043	1092	1140	1189	1231	1279	1370	1467	1467	
.08	\$ 959	1008	1057	1099	1147	1196	1245	1286	1335	1426	1523	1523	
.09	\$ 1008	1057	1106	1147	1196	1245	1293	1335	1384	1474	1572	1572	
.10	\$ 1057	1106	1154	1196	1245	1293	1342	1384	1432	1523	1620	1620	
.12	\$ 1154	1203	1252	1293	1342	1391	1439	1481	1530	1620	1718	1718	
.14	\$ 1259	1307	1356	1398	1446	1495	1544	1586	1634	1725	1822	1822	
.16	\$ 1356	1405	1453	1495	1544	1592	1641	1683	1732	1822	1919	1919	BALANCE POINT 27 DEG.F.
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 959	1015	1071	1133	1189	1245	1300	1356	1412	1523	1634	1634	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 1015	1071	1126	1189	1245	1300	1356	1412	1467	1579	1690	1690	S PER YEAR
.07	\$ 1078	1133	1189	1252	1307	1363	1419	1474	1530	1641	1752	1752	
.08	\$ 1133	1189	1245	1307	1363	1419	1474	1530	1586	1697	1808	1808	
.09	\$ 1189	1245	1300	1363	1419	1474	1530	1586	1641	1752	1864	1864	
.10	\$ 1252	1307	1363	1426	1481	1537	1592	1648	1704	1815	1926	1926	
.12	\$ 1370	1426	1481	1544	1599	1655	1711	1766	1822	1933	2045	2045	
.14	\$ 1481	1537	1592	1655	1711	1766	1822	1878	1933	2045	2156	2156	
.16	\$ 1599	1655	1711	1773	1829	1885	1940	1996	2052	2163	2274	2274	BALANCE POINT 31 DEG.F.
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504	2504	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 1154	1231	1307	1384	1460	1537	1613	1690	1773	1926	2079	2079	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 1203	1279	1356	1432	1509	1586	1662	1739	1822	1975	2128	2128	S PER YEAR
.07	\$ 1245	1321	1398	1474	1551	1627	1704	1780	1864	2017	2170	2170	
.08	\$ 1293	1370	1446	1523	1599	1676	1752	1829	1912	2065	2219	2219	
.09	\$ 1342	1419	1495	1572	1648	1725	1801	1878	1961	2114	2267	2267	
.10	\$ 1384	1460	1537	1613	1690	1766	1843	1919	2003	2156	2309	2309	
.12	\$ 1481	1558	1634	1711	1787	1864	1940	2017	2100	2253	2406	2406	
.14	\$ 1572	1648	1725	1801	1878	1954	2031	2107	2191	2344	2497	2497	
.16	\$ 1662	1739	1815	1892	1968	2045	2121	2198	2281	2434	2587	2587	BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 --ELECTRIC RATE \$/KWH .

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHPQB INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 30000 SEER10.00
 ARI RATED HEATING CAP.: BTUH (47) 29000 COP(47) 3.00 ESEPF 7.20 MIN.DHR REG IV
 BTUH (17) 17000 COP(17) 2.10 FURNACE EFFICIENCY 100.00 % AFUE
 FURNACE TYPE ELECTRIC

HEAT LOSS
BTUH ELRC.
 COST
 \$/KWH

30,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	514	925
.06	\$	612	1112
.07	\$	716	1300
.08	\$	813	1488
.09	\$	918	1669
.10	\$	1022	1857
.12	\$	1231	2232
.14	\$	1432	2601
.16	\$	1641	2977

BALANCE POINT 13 DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	605	1085
.06	\$	723	1300
.07	\$	841	1516
.08	\$	966	1732
.09	\$	1085	1947
.10	\$	1203	2170
.12	\$	1446	2601
.14	\$	1683	3039
.16	\$	1919	3471

BALANCE POINT 17 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	695	1238
.06	\$	841	1488
.07	\$	980	1732
.08	\$	1119	1982
.09	\$	1259	2232
.10	\$	1398	2476
.12	\$	1669	2977
.14	\$	1947	3471
.16	\$	2225	3965

BALANCE POINT 20 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	904	1544
.06	\$	1085	1857
.07	\$	1259	2170
.08	\$	1446	2476
.09	\$	1627	2789
.10	\$	1801	3095
.12	\$	2163	3721
.14	\$	2532	4340
.16	\$	2886	4959

BALANCE POINT 25 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1126	1857
.06	\$	1349	2232
.07	\$	1579	2601
.08	\$	1808	2977
.09	\$	2031	3345
.10	\$	2260	3721
.12	\$	2705	4465
.14	\$	3158	5210
.16	\$	3610	5954

BALANCE POINT 29 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.06	.07	.08	.09	.10	.12	.14	.16
60	72	84	96	108	120	144	168	192

<-- ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 30UHPQB A37AO-A
INDOOR A37AO-A
ARI RATED COOLING CAP.: BTUH(95) 30000, SEER10.00
ARI RATED HEATING CAP.: BTUH (47) 29000, COP(47) 3.00, ESPE 7.20 MIN.DER RGB IV
BTUH (17) 17000, COP(17) 2.10
FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	
30,000	\$ 278	319	361	403	445	486	528	563	605	646	730	813
	--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$ 375	382	396	410	424	438	445	459	473	486	507	535
.06	\$ 438	445	459	473	486	500	507	521	535	549	570	598
.07	\$ 493	500	514	528	542	556	563	577	591	605	626	653
.08	\$ 549	556	570	584	598	612	619	633	646	660	681	709
.09	\$ 605	612	626	639	653	667	674	688	702	716	737	765
.10	\$ 667	674	688	702	716	730	737	751	765	779	799	827
.12	\$ 779	786	799	813	827	841	848	862	876	890	911	939
.14	\$ 897	904	918	932	946	959	966	980	994	1008	1029	1057
.16	\$ 1008	1015	1029	1043	1057	1071	1078	1092	1106	1119	1140	1168
	BALANCE POINT 13 DEG.F.											
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946
	--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$ 417	438	452	473	493	514	528	549	570	584	626	660
.06	\$ 473	493	507	528	549	570	584	605	626	639	681	716
.07	\$ 528	549	563	584	605	626	639	660	681	695	737	772
.08	\$ 584	605	619	639	660	681	695	716	737	751	793	827
.09	\$ 639	660	674	695	716	737	751	772	793	806	848	883
.10	\$ 695	716	730	751	772	793	806	827	848	862	904	939
.12	\$ 813	834	848	869	890	911	925	946	966	980	1022	1057
.14	\$ 925	946	959	980	1001	1022	1036	1057	1078	1092	1133	1168
.16	\$ 1036	1057	1071	1092	1112	1133	1147	1168	1189	1203	1245	1279
	BALANCE POINT 17 DEG.F.											
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085
	--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$ 473	493	514	535	556	577	598	619	639	667	709	751
.06	\$ 535	556	577	598	619	639	660	681	702	730	772	813
.07	\$ 598	619	639	660	681	702	723	744	765	793	834	876
.08	\$ 660	681	702	723	744	765	786	806	827	855	897	939
.09	\$ 723	744	765	786	806	827	848	869	890	918	959	1001
.10	\$ 786	806	827	848	869	890	911	932	952	980	1022	1064
.12	\$ 918	939	959	980	1001	1022	1043	1064	1085	1112	1154	1196
.14	\$ 1043	1064	1085	1106	1126	1147	1168	1189	1210	1238	1279	1321
.16	\$ 1168	1189	1210	1231	1252	1272	1293	1314	1335	1363	1405	1446
	BALANCE POINT 20 DEG.F.											
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356
	--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$ 549	584	619	653	688	723	758	793	827	862	932	994
.06	\$ 612	646	681	716	751	786	820	855	890	925	994	1057
.07	\$ 674	709	744	779	813	848	883	918	952	987	1057	1119
.08	\$ 737	772	806	841	876	911	946	980	1015	1050	1119	1182
.09	\$ 799	834	869	904	939	973	1008	1043	1078	1112	1182	1245
.10	\$ 862	897	932	966	1001	1036	1071	1106	1140	1175	1245	1307
.12	\$ 987	1022	1057	1092	1126	1161	1196	1231	1266	1300	1370	1432
.14	\$ 1112	1147	1182	1217	1252	1286	1321	1356	1391	1426	1495	1558
.16	\$ 1238	1272	1307	1342	1377	1412	1446	1481	1516	1551	1620	1683
	BALANCE POINT 25 DEG.F.											
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627
	--THEORETICAL HEATING COST * FURNACE ONLY											
.05	\$ 626	674	730	779	827	883	932	980	1036	1085	1189	1286
.06	\$ 681	730	786	834	883	939	987	1036	1092	1140	1245	1342
.07	\$ 737	786	841	890	939	994	1043	1092	1147	1196	1300	1398
.08	\$ 793	841	897	946	994	1050	1099	1147	1203	1252	1356	1453
.09	\$ 848	897	952	1001	1050	1106	1154	1203	1259	1307	1412	1509
.10	\$ 904	952	1008	1057	1106	1161	1210	1259	1314	1363	1467	1565
.12	\$ 1015	1064	1119	1168	1217	1272	1321	1370	1426	1474	1579	1676
.14	\$ 1126	1175	1231	1279	1328	1384	1432	1481	1537	1586	1690	1787
.16	\$ 1231	1279	1335	1384	1432	1488	1537	1586	1641	1690	1794	1892
	BALANCE POINT 29 DEG.F.											

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S .05 .06 .07 .08 .09 .10 .12 .14 .16	<--ELECTRIC RATE \$/KWH
S .60 .72 .84 .96 .108 .120 .144 .168 .192	<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHPQB INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95°) 30000 SEER10.00
 ARI RATED HEATING CAP.: BTUH (47°) 29000 COP(47°) 3.00, HSPF 7.20 MIN.DER REG IV
 BTUH (17°) 17000 COP(17°) 2.10
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELBC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
30,000	\$ 410	466	521	584	639	702	758	820	876	939	994	1050	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 410	431	445	466	486	500	521	535	556	577	591	612
	.06	\$ 473	493	507	528	549	563	584	598	619	639	653	674
	.07	\$ 528	549	563	584	605	619	639	653	674	695	709	730
	.08	\$ 584	605	619	639	660	674	695	709	730	751	765	786
	.09	\$ 639	660	674	695	716	730	751	765	786	806	820	841
	.10	\$ 702	723	737	758	779	793	813	827	848	869	883	904
	.12	\$ 813	834	848	869	890	904	925	939	959	980	994	1015
	.14	\$ 932	952	966	987	1008	1022	1043	1057	1078	1093	1112	1133
	.16	\$ 1043	1064	1078	1099	1119	1133	1154	1168	1189	1210	1224	1245
													BALANCE POINT 13 DEG.F.
35,000	\$ 4	542	612	681	751	80	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 47	500	528	556	584	612	639	667	695	716	744	772
	.06	\$ 528	556	584	612	639	667	695	723	751	772	799	827
	.07	\$ 584	612	639	667	695	723	751	779	806	827	855	883
	.08	\$ 639	667	695	723	751	779	806	831	862	883	911	939
	.09	\$ 695	723	751	779	806	834	862	890	918	939	966	994
	.10	\$ 751	779	806	834	862	890	918	946	973	994	1022	1050
	.12	\$ 869	897	925	952	980	1008	1036	1064	1092	1112	1140	1168
	.14	\$ 980	1008	1036	1064	1092	1119	1147	1175	1203	1224	1252	1279
	.16	\$ 1092	1119	1147	1175	1203	1231	1259	1286	1314	1335	1363	1391
													BALANCE POINT 17 DEG.F.
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 535	570	598	633	660	695	723	751	786	813	848	876
	.06	\$ 598	633	660	695	723	758	786	813	848	876	911	939
	.07	\$ 660	695	723	758	786	820	848	876	911	939	973	1001
	.08	\$ 723	758	786	820	848	883	911	939	973	1001	1036	1064
	.09	\$ 786	820	848	883	911	946	973	1001	1036	1064	1099	1126
	.10	\$ 848	883	911	946	973	1008	1036	1064	1099	1126	1161	1189
	.12	\$ 980	1015	1043	1078	1106	1140	1168	1196	1231	1259	1293	1321
	.14	\$ 1106	1140	1168	1203	1231	1266	1293	1321	1356	1384	1419	1446
	.16	\$ 1231	1266	1293	1328	1356	1391	1419	1446	1481	1509	1544	1572
													BALANCE POINT 20 DEG.F.
50,000	\$ 681	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY	
	.05	\$ 660	758	806	855	904	952	1001	1050	1099	1154	1203	
	.06	\$ 723	820	869	918	966	1015	1064	1112	1161	1217	1266	
	.07	\$ 786	883	932	980	1029	1078	1126	1175	1224	1279	1328	
	.08	\$ 848	897	946	994	1043	1092	1140	1189	1238	1286	1342	1391
	.09	\$ 911	959	1008	1057	1106	1154	1203	1252	1300	1349	1405	1453
	.10	\$ 973	1022	1071	1119	1168	1217	1266	1314	1363	1412	1467	1516
	.12	\$ 1099	1147	1196	1245	1293	1342	1391	1439	1488	1537	1592	1641
	.14	\$ 1224	1272	1321	1370	1419	1467	1516	1565	1613	1662	1718	1766
	.16	\$ 1349	1398	1446	1495	1544	1592	1641	1690	1739	1787	1843	1892
													BALANCE POINT 25 DEG.F.
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 786	855	932	1001	1078	1154	1224	1300	1370	1446	1516	1592
	.06	\$ 841	911	987	1057	1133	1210	1279	1356	1426	1502	1572	1648
	.07	\$ 897	966	1043	1112	1189	1266	1335	1412	1481	1558	1627	1704
	.08	\$ 952	1022	1099	1168	1245	1321	1391	1467	1537	1613	1683	1759
	.09	\$ 1008	1078	1154	1224	1300	1377	1446	1523	1592	1669	1739	1815
	.10	\$ 1064	1133	1210	1279	1356	1432	1502	1579	1648	1725	1794	1871
	.12	\$ 1175	1245	1321	1391	1467	1544	1613	1690	1759	1836	1905	1982
	.14	\$ 1286	1356	1432	1502	1579	1655	1725	1801	1871	1947	2017	2093
	.16	\$ 1391	1460	1537	1606	1683	1759	1829	1905	1975	2052	2121	2198
													BALANCE POINT 29 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 60 72 84 96 108 120 144 168 192

--ELECTRIC RATE \$/KWH
 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 30UHPQB INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 30000 SEER10.00
 ARI RATED HEATING CAP.: BTUH (47) 29000, COP(47) 3.00, EERPF 7.20 MIN.DER REG IV
 BTUH (17) 17000, COP(17) 2.10
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC. COST \$/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20	
PROPANE GAS COST - \$/GALLON														
30,000	\$ 535	577	626	667	709	758	799	848	890	980	1071	1071		--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 452	466	479	493	507	521	535	549	563	591	612	612		
.06	\$ 514	528	542	556	570	584	598	612	626	653	674	674		THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 570	584	598	612	626	639	653	667	681	709	730	730		
.08	\$ 626	639	653	667	681	695	709	723	737	765	786	786		
.09	\$ 681	695	709	723	737	751	765	779	793	820	841	841		
.10	\$ 744	758	772	786	799	813	827	841	855	883	904	904		
.12	\$ 855	869	883	897	911	925	939	952	966	994	1015	1015		
.14	\$ 973	987	1001	1015	1029	1043	1057	1071	1085	1112	1133	1133		
.16	\$ 1085	1099	1112	1126	1140	1154	1168	1182	1196	1224	1245	1245		BALANCE POINT 13 DEG.F.
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252		--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 535	556	577	598	619	639	660	681	702	737	779	779		
.06	\$ 591	612	633	653	674	695	716	737	758	793	834	834		THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 646	667	688	709	730	751	772	793	813	848	890	890		
.08	\$ 702	723	744	765	786	806	827	848	869	904	946	946		
.09	\$ 758	779	799	820	841	862	883	904	925	959	1001	1001		
.10	\$ 813	834	855	876	897	918	939	959	980	1015	1057	1057		
.12	\$ 932	952	973	994	1015	1036	1057	1078	1099	1133	1175	1175		
.14	\$ 1043	1064	1085	1106	1126	1147	1168	1189	1210	1245	1286	1286		BALANCE POINT 17 DEG.F.
.16	\$ 1154	1175	1196	1217	1238	1259	1279	1300	1321	1356	1398	1398		
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426		--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 605	626	653	674	695	723	744	772	793	841	890	890		
.06	\$ 667	688	716	737	758	786	806	834	855	904	952	952		THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 730	751	779	799	820	848	869	897	918	966	1015	1015		
.08	\$ 793	813	841	862	883	911	932	959	980	1029	1078	1078		
.09	\$ 855	876	904	925	946	973	994	1022	1043	1092	1140	1140		
.10	\$ 918	939	966	987	1008	1036	1057	1085	1106	1154	1203	1203		
.12	\$ 1050	1071	1099	1119	1140	1168	1189	1217	1238	1286	1335	1335		
.14	\$ 1175	1196	1224	1245	1266	1293	1314	1342	1363	1412	1460	1460		BALANCE POINT 20 DEG.F.
.16	\$ 1300	1321	1349	1370	1391	1419	1439	1467	1488	1537	1586	1586		
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787		--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 765	799	841	876	911	952	987	1029	1064	1140	1217	1217		
.06	\$ 827	862	904	939	973	1015	1050	1092	1126	1203	1279	1279		THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 890	925	966	1001	1036	1078	1112	1154	1189	1266	1342	1342		
.08	\$ 952	987	1029	1064	1099	1140	1175	1217	1252	1328	1405	1405		
.09	\$ 1015	1050	1092	1126	1161	1203	1238	1279	1314	1391	1467	1467		
.10	\$ 1078	1112	1154	1189	1224	1266	1300	1342	1377	1453	1530	1530		
.12	\$ 1203	1238	1279	1314	1349	1391	1426	1467	1502	1579	1655	1655		
.14	\$ 1328	1363	1405	1439	1474	1516	1551	1592	1627	1704	1780	1780		BALANCE POINT 25 DEG.F.
.16	\$ 1453	1488	1530	1565	1599	1641	1676	1718	1752	1829	1905	1905		
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142		--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 939	994	1050	1112	1168	1224	1279	1335	1391	1502	1613	1613		
.06	\$ 994	1050	1106	1168	1224	1279	1335	1391	1446	1558	1669	1669		THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.07	\$ 1050	1106	1161	1224	1279	1335	1391	1446	1502	1558	1669	1725		
.08	\$ 1106	1161	1217	1279	1335	1391	1446	1502	1558	1613	1725	1780		
.09	\$ 1161	1217	1272	1335	1391	1446	1502	1558	1613	1725	1836	1836		
.10	\$ 1217	1272	1328	1391	1446	1502	1558	1613	1669	1780	1892	1892		
.12	\$ 1328	1384	1439	1502	1558	1613	1669	1725	1780	1892	2003	2003		
.14	\$ 1439	1495	1551	1613	1669	1725	1780	1836	1892	1903	2114	2114		BALANCE POINT 29 DEG.F.
.16	\$ 1544	1599	1655	1718	1773	1829	1885	1940	1996	2107	2219	2219		

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

s .05	.06	.07	.08	.09	.10	.12	.14	.16
s .60	72	84	96	108	120	144	168	192

<--ELECTRIC RATE \$/KWH	<--THEORETICAL AIR CONDITIONING COST
-------------------------	--------------------------------------

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 36UHPQB INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 33000 SEER 8.69
 ARI RATED HEATING CAP.: BTUH (47) 33600 COP(47) 2.90, HSPF 6.90 MIN.DER REG IV
 BTUH (17) 20000, COP(17) 2.20 FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH KILOCOST.
 \$/KWH

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	605	1085
.06	\$	730	1300
.07	\$	848	1516
.08	\$	973	1732
.09	\$	1092	1947
.10	\$	1217	2170
.12	\$	1453	2601
.14	\$	1690	3039
.16	\$	1933	3471

BALANCE POINT 13 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	695	1238
.06	\$	834	1488
.07	\$	973	1732
.08	\$	1112	1982
.09	\$	1259	2232
.10	\$	1391	2476
.12	\$	1669	2977
.14	\$	1947	3471
.16	\$	2225	3965

BALANCE POINT 16 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	890	1544
.06	\$	1071	1857
.07	\$	1245	2170
.08	\$	1432	2476
.09	\$	1606	2789
.10	\$	1787	3095
.12	\$	2142	3721
.14	\$	2504	4340
.16	\$	2858	4959

BALANCE POINT 22 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1112	1857
.06	\$	1335	2232
.07	\$	1551	2601
.08	\$	1773	2977
.09	\$	1996	3345
.10	\$	2219	3721
.12	\$	2664	4465
.14	\$	3109	5210
.16	\$	3554	5954

BALANCE POINT 27 DEG.F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1349	2170
.06	\$	1613	2601
.07	\$	1885	3039
.08	\$	2156	3471
.09	\$	2420	3902
.10	\$	2692	4340
.12	\$	3234	5210
.14	\$	3770	6079
.16	\$	4305	6942

BALANCE POINT 31 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$ 75 91 106 121 136 151 182 212 243

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 **36UHPQB/A36AQ-A**
HEAT PUMP MODEL: OUTDOOR 36UHPQB INDOOR A36AQ-A
ARI RATED COOLING CAP.: BTUH(95) 33000 SEER 8.69
ARI RATED HEATING CAP.: BTUH (47) 33600 COP(47) 2.90, HSPF 6.90 MIN.DRR REG IV
BTUH (17) 20000 COP(17) 2.20
FURNACE TYPE NATURAL GAS **FURNACE EFFICIENCY 78.00 % AFUE**

HEAT LOSS BTUH	ELEC. COST S/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	
35,000		\$ 326	375	424	473	521	563	612	660	709	758	848	946
		--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 459	473	486	500	514	528	542	556	577	591	619	646
	.06	\$ 528	542	556	570	584	598	612	626	646	660	688	716
	.07	\$ 598	612	626	639	653	667	681	695	716	730	758	786
	.08	\$ 674	688	702	716	730	744	758	772	793	806	834	862
	.09	\$ 744	758	772	786	799	813	827	841	862	876	904	932
	.10	\$ 813	827	841	855	869	883	897	911	932	946	973	1001
	.12	\$ 952	966	980	994	1008	1022	1036	1050	1071	1085	1112	1140
	.14	\$ 1099	1112	1126	1140	1154	1168	1182	1196	1217	1231	1259	1286
	.16	\$ 1238	1252	1266	1279	1293	1307	1321	1335	1356	1370	1398	1426
40,000		\$ 375	431	486	542	591	646	702	758	813	862	973	1085
		--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 514	528	549	563	577	598	612	633	646	660	695	730
	.06	\$ 598	612	633	646	660	681	695	716	730	744	779	813
	.07	\$ 674	688	709	723	737	758	772	793	806	820	855	890
	.08	\$ 751	765	786	799	813	834	848	869	883	897	932	966
	.09	\$ 834	848	869	883	897	918	932	952	966	980	1015	1050
	.10	\$ 911	925	946	959	973	994	1008	1029	1043	1057	1092	1126
	.12	\$ 1071	1085	1106	1119	1133	1154	1168	1189	1203	1217	1252	1286
	.14	\$ 1231	1245	1266	1279	1293	1314	1328	1349	1363	1377	1412	1446
	.16	\$ 1391	1405	1426	1439	1453	1474	1488	1509	1523	1537	1572	1606
50,000		\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356
		--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 584	619	653	688	723	758	793	827	862	897	966	1029
	.06	\$ 653	688	723	758	793	827	862	897	932	966	1036	1099
	.07	\$ 723	758	793	827	862	897	932	966	1001	1036	1106	1168
	.08	\$ 793	827	862	897	932	966	1001	1036	1071	1106	1175	1238
	.09	\$ 855	890	925	959	994	1029	1064	1099	1133	1168	1238	1300
	.10	\$ 925	959	994	1029	1064	1099	1133	1168	1203	1238	1307	1370
	.12	\$ 1064	1099	1133	1168	1203	1238	1272	1307	1342	1377	1446	1509
	.14	\$ 1203	1238	1272	1307	1342	1377	1412	1446	1481	1516	1586	1648
	.16	\$ 1342	1377	1412	1446	1481	1516	1551	1586	1620	1655	1725	1787
60,000		\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627
		--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 660	709	765	813	862	918	966	1015	1071	1119	1224	1321
	.06	\$ 723	772	827	876	925	980	1029	1078	1133	1182	1286	1384
	.07	\$ 786	834	890	939	987	1043	1092	1140	1196	1245	1349	1446
	.08	\$ 841	890	946	994	1043	1099	1147	1196	1252	1300	1405	1502
	.09	\$ 904	952	1008	1057	1106	1161	1210	1259	1314	1363	1467	1565
	.10	\$ 966	1015	1071	1119	1168	1224	1272	1321	1377	1426	1530	1627
	.12	\$ 1092	1140	1196	1245	1293	1349	1398	1446	1502	1551	1655	1752
	.14	\$ 1210	1259	1314	1363	1412	1467	1516	1565	1620	1669	1773	1871
	.16	\$ 1335	1384	1439	1488	1537	1592	1641	1690	1745	1794	1899	1996
70,000		\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899
		--THEORETICAL HEATING COST * FURNACE ONLY											
	.05	\$ 765	820	883	939	1001	1057	1119	1175	1238	1293	1419	1537
	.06	\$ 834	890	952	1008	1071	1126	1189	1245	1307	1363	1488	1606
	.07	\$ 904	959	1022	1078	1140	1196	1259	1314	1377	1432	1558	1676
	.08	\$ 973	1029	1092	1147	1210	1266	1328	1384	1446	1502	1627	1745
	.09	\$ 1043	1099	1161	1217	1279	1335	1398	1453	1516	1572	1697	1815
	.10	\$ 1112	1168	1231	1286	1349	1405	1467	1523	1586	1641	1766	1885
	.12	\$ 1252	1307	1370	1426	1488	1544	1606	1662	1725	1780	1905	2024
	.14	\$ 1391	1446	1509	1565	1627	1683	1745	1801	1864	1919	2045	2163
	.16	\$ 1530	1586	1648	1704	1766	1822	1885	1940	2003	2059	2184	2302

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

S .05 .06 .07 .08 .09 .10 .12 .14 .16

<--ELECTRIC RATE S/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 36UHPQ8 INDOOR A36AO-A

ARI RATED COOLING CAP.: BTUH(95) 33000 SEER 8.69
 ARI RATED HEATING CAP.: BTUH (47) 33500 COP(47) 2.90, RSPE 6.90 MIN.DRR REG IV
 BTUH (17) 20000 COP(17) 2.20
 FURNACE TYPE FUEL OIL

FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 500	521	542	563	584	605	626	646	667	688	709	737	
.06	\$ 570	591	612	633	653	674	695	716	737	758	779	806	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 639	660	681	702	723	744	765	786	806	827	848	876	
.08	\$ 716	737	758	779	799	820	841	862	883	904	925	952	
.09	\$ 786	806	827	848	869	890	911	932	952	973	994	1022	
.10	\$ 855	876	897	918	939	959	980	1001	1022	1043	1064	1092	
.12	\$ 994	1015	1036	1057	1078	1099	1119	1140	1161	1182	1203	1231	
.14	\$ 1140	1161	1182	1203	1224	1245	1266	1286	1307	1328	1349	1377	BALANCE POINT 13 DEG.F.
.16	\$ 1279	1300	1321	1342	1363	1384	1405	1426	1446	1467	1488	1516	
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 563	591	612	639	660	688	709	730	758	779	806	827	
.06	\$ 646	674	695	723	744	772	793	813	841	862	890	911	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 723	751	772	799	820	848	869	890	918	939	966	987	
.08	\$ 799	827	848	876	897	925	946	966	994	1015	1043	1064	
.09	\$ 883	911	932	959	980	1008	1029	1050	1078	1099	1126	1147	
.10	\$ 959	987	1008	1036	1057	1085	1106	1126	1154	1175	1203	1224	
.12	\$ 1119	1147	1168	1196	1217	1245	1266	1286	1314	1335	1363	1384	
.14	\$ 1279	1307	1328	1356	1377	1405	1426	1446	1474	1495	1523	1544	BALANCE POINT 16 DEG.F.
.16	\$ 1439	1467	1488	1516	1537	1565	1586	1606	1634	1655	1683	1704	
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 695	744	793	841	890	939	987	1036	1085	1133	1189	1238	
.06	\$ 765	813	862	911	959	1008	1057	1106	1154	1203	1259	1307	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 834	883	932	980	1029	1078	1126	1175	1224	1272	1328	1377	
.08	\$ 904	952	1001	1050	1099	1147	1196	1245	1293	1342	1398	1446	
.09	\$ 966	1015	1064	1112	1161	1210	1259	1307	1356	1405	1460	1509	
.10	\$ 1036	1085	1133	1182	1231	1279	1328	1377	1426	1474	1530	1579	
.12	\$ 1175	1224	1272	1321	1370	1419	1467	1516	1565	1613	1669	1718	
.14	\$ 1314	1363	1412	1460	1509	1558	1606	1655	1704	1752	1808	1857	BALANCE POINT 22 DEG.F.
.16	\$ 1453	1502	1551	1599	1648	1697	1745	1794	1843	1892	1947	1996	
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 820	890	966	1036	1112	1189	1259	1335	1405	1481	1551	1627	
.06	\$ 883	952	1029	1099	1175	1252	1321	1398	1467	1544	1613	1690	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 946	1015	1092	1161	1238	1314	1384	1460	1530	1606	1676	1752	
.08	\$ 1001	1071	1147	1217	1293	1370	1439	1516	1586	1662	1732	1808	
.09	\$ 1064	1133	1210	1279	1356	1432	1502	1579	1648	1725	1794	1871	
.10	\$ 1126	1196	1272	1342	1419	1495	1565	1641	1711	1787	1857	1933	
.12	\$ 1252	1321	1398	1467	1544	1620	1690	1766	1836	1912	1982	2059	
.14	\$ 1370	1439	1516	1586	1662	1739	1808	1885	1954	2031	2100	2177	BALANCE POINT 27 DEG.F.
.16	\$ 1495	1565	1641	1711	1787	1864	1933	2010	2079	2156	2225	2302	
70,000	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 946	1029	1119	1203	1286	1377	1460	1544	1627	1718	1801	1885	
.06	\$ 1015	1099	1189	1272	1356	1446	1530	1613	1697	1787	1871	1954	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1085	1168	1259	1342	1426	1516	1599	1683	1766	1857	1940	2024	
.08	\$ 1154	1238	1328	1412	1495	1585	1669	1752	1836	1926	2010	2093	
.09	\$ 1224	1307	1398	1481	1565	1655	1739	1822	1905	1996	2079	2163	
.10	\$ 1293	1377	1467	1551	1634	1725	1808	1892	1975	2065	2149	2232	
.12	\$ 1432	1516	1606	1690	1773	1864	1947	2031	2114	2205	2288	2372	
.14	\$ 1572	1655	1745	1829	1912	2003	2086	2170	2253	2344	2427	2511	
.16	\$ 1711	1794	1885	1968	2052	2142	2225	2309	2392	2483	2566	2650	BALANCE POINT 31 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

s .05	.06	.07	.08	.09	.10	.12	.14	.16
-------	-----	-----	-----	-----	-----	-----	-----	-----

<--ELECTRIC RATE \$/KWH	<--THEORETICAL AIR CONDITIONING COST
-------------------------	--------------------------------------

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 36UHPQB/A36AO-A

HEAT PUMP MODEL: OUTDOOR 36UHPQB INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH(95) 33000 SEER 8.69
 ARI RATED HEATING CAP.: BTUH (47) 33500 COP(47) 2.90, HSPF 6.90 MIN.DRR REG IV
 BTUH (17) 20000 COP(17) 2.20
 FURNACE TYPE PROPANE GAS

HEAT LOSS BTUH	ELEC. COST S/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30	1.40	1.50	1.60
PROPANE GAS COST - \$/GALLON																
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252	1252	--THEORETICAL HEATING COST * FURNACE ONLY			
.05	\$ 549	563	577	598	612	626	646	660	674	709	737	737	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.06	\$ 619	633	646	667	681	695	716	730	744	779	806	806	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.07	\$ 688	702	716	737	751	765	786	799	813	848	876	876	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.08	\$ 765	779	793	813	827	841	862	876	890	925	952	952	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.09	\$ 834	848	862	883	897	911	932	946	959	994	1022	1022	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.10	\$ 904	918	932	952	966	980	1001	1015	1029	1064	1092	1092	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.12	\$ 1043	1057	1071	1092	1106	1119	1140	1154	1168	1203	1231	1231	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.14	\$ 1189	1203	1217	1238	1252	1266	1286	1300	1314	1349	1377	1377	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.16	\$ 1328	1342	1356	1377	1391	1405	1426	1439	1453	1488	1516	1516	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426	--THEORETICAL HEATING COST * FURNACE ONLY			
.05	\$ 619	633	653	674	688	709	723	744	765	799	834	834	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.06	\$ 702	716	737	758	772	793	806	827	848	883	918	918	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.07	\$ 779	793	813	834	848	869	883	904	925	959	994	994	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.08	\$ 855	869	890	911	925	946	959	980	1001	1036	1071	1071	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.09	\$ 939	952	973	994	1008	1029	1043	1064	1085	1119	1154	1154	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.10	\$ 1015	1029	1050	1071	1085	1106	1119	1140	1161	1196	1231	1231	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.12	\$ 1175	1189	1210	1231	1245	1266	1279	1300	1321	1356	1391	1391	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.14	\$ 1335	1349	1370	1391	1405	1426	1439	1460	1481	1516	1551	1551	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.16	\$ 1495	1509	1530	1551	1565	1586	1599	1620	1641	1676	1711	1711	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787	--THEORETICAL HEATING COST * FURNACE ONLY			
.05	\$ 799	834	876	911	946	987	1022	1064	1099	1175	1252	1252	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.06	\$ 869	904	946	980	1015	1057	1092	1133	1168	1245	1321	1321	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.07	\$ 939	973	1015	1050	1085	1126	1161	1203	1238	1314	1391	1391	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.08	\$ 1008	1043	1085	1119	1154	1196	1231	1272	1307	1384	1460	1460	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.09	\$ 1071	1106	1147	1182	1217	1259	1293	1335	1370	1446	1523	1523	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.10	\$ 1140	1175	1217	1252	1286	1328	1363	1405	1439	1516	1592	1592	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.12	\$ 1279	1314	1356	1391	1426	1467	1502	1544	1579	1655	1732	1732	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.14	\$ 1419	1453	1495	1530	1565	1606	1641	1683	1718	1794	1871	1871	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.16	\$ 1558	1592	1634	1669	1704	1745	1780	1822	1857	1933	2010	2010	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142	--THEORETICAL HEATING COST * FURNACE ONLY			
.05	\$ 973	1029	1085	1147	1203	1259	1314	1370	1426	1537	1648	1648	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.06	\$ 1036	1092	1147	1210	1266	1321	1377	1432	1488	1599	1711	1711	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.07	\$ 1099	1154	1210	1272	1328	1384	1439	1495	1551	1662	1773	1773	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.08	\$ 1154	1210	1266	1328	1384	1439	1495	1551	1606	1718	1829	1829	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.09	\$ 1217	1272	1328	1391	1446	1502	1558	1613	1669	1780	1892	1892	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.10	\$ 1279	1335	1391	1453	1509	1565	1620	1676	1732	1843	1954	1954	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.12	\$ 1405	1460	1516	1579	1634	1690	1745	1801	1857	1968	2079	2079	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.14	\$ 1523	1579	1634	1697	1752	1808	1864	1919	1975	2086	2198	2198	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.16	\$ 1648	1704	1759	1822	1878	1933	1989	2045	2100	2212	2323	2323	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504	2504	--THEORETICAL HEATING COST * FURNACE ONLY			
.05	\$ 1126	1196	1259	1328	1391	1453	1523	1586	1648	1780	1912	1912	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.06	\$ 1196	1266	1328	1398	1460	1523	1592	1655	1718	1850	1982	1982	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.07	\$ 1266	1335	1398	1467	1530	1592	1662	1725	1787	1919	2052	2052	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.08	\$ 1335	1405	1467	1537	1599	1662	1732	1794	1857	1989	2121	2121	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.09	\$ 1405	1474	1537	1606	1669	1732	1801	1864	1926	2059	2191	2191	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.10	\$ 1474	1544	1606	1676	1739	1801	1871	1933	1996	2128	2260	2260	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.12	\$ 1613	1683	1745	1815	1878	1940	2010	2072	2135	2267	2399	2399	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.14	\$ 1752	1822	1885	1954	2017	2079	2149	2212	2274	2406	2538	2538	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			
.16	\$ 1892	1961	2024	2093	2156	2219	2288	2351	2413	2545	2678	2678	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR			

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$.75 .91 .106 .121 .136 .151 .182 .212 .243

<-ELECTRIC RATE S/KWH
 <-THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 36UHPQB/A37AO-A
 HEAT PUMP MODEL: OUTDOOR 36UHPQB INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 36000, SEER10.00
 ARI RATED HEATING CAP.: BTUH (47) 36000, COP(47) 3.10, BSPP 7.20 MIN.DHR REG IV
 BTUH (17) 21000, COP(17) 2.20
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH KWH COST
S/KWH

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	S	660	1238
.06	S	793	1488
.07	S	932	1732
.08	S	1057	1982
.09	S	1189	2232
.10	S	1328	2476
.12	S	1592	2977
.14	S	1850	3471
.16	S	2121	3965

BALANCE POINT 15 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	S	848	1544
.06	S	1015	1857
.07	S	1182	2170
.08	S	1356	2476
.09	S	1523	2789
.10	S	1690	3095
.12	S	2031	3721
.14	S	2365	4340
.16	S	2705	4959

BALANCE POINT 21 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	S	1050	1857
.06	S	1259	2232
.07	S	1474	2601
.08	S	1676	2977
.09	S	1892	3345
.10	S	2100	3721
.12	S	2525	4465
.14	S	2942	5210
.16	S	3359	5954

BALANCE POINT 26 DEG.F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	S	1279	2170
.06	S	1537	2601
.07	S	1787	3039
.08	S	2045	3471
.09	S	2295	3902
.10	S	2552	4340
.12	S	3067	5210
.14	S	3575	6079
.16	S	4090	6942

BALANCE POINT 30 DEG.F.

80,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	S	1516	2476
.06	S	1822	2977
.07	S	2128	3471
.08	S	2427	3965
.09	S	2733	4465
.10	S	3039	4959
.12	S	3651	5954
.14	S	4250	6942
.16	S	4862	7936

BALANCE POINT 33 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD SIZED TO MATCH COOL CAPACITY OF HEAT PUMP

S	.05	.06	.07	.08	.09	.10	.12	.14	.16
S	72	86	100	115	129	144	172	201	230

<--ELECTRIC RATE \$/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 36UHPQB INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 36000 SEER10.00
 ARI RATED HEATING CAP.: BTUH(47) 36000 COP(47) 3.10, ESEPF 7.20 MIN.DHR REG IV
 BTUH(17) 21000 COP(17) 2.20
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	KILOCOST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
NATURAL GAS COST - \$/THERM													
35,000	\$ 326	375	424	473	521	563	612	660	709	758	848	946	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 431	445	459	473	486	500	514	528	549	563	591	619	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 493	507	521	535	549	563	577	591	612	626	653	681	S PER YEAR
.07	\$ 556	570	584	598	612	626	639	653	674	688	716	744	
.08	\$ 619	633	646	660	674	688	702	716	737	751	779	806	
.09	\$ 688	702	716	730	744	758	772	786	806	820	848	876	
.10	\$ 751	765	779	793	806	820	834	848	869	883	911	939	
.12	\$ 883	897	911	925	939	952	966	980	1001	1015	1043	1071	
.14	\$ 1008	1022	1036	1050	1064	1078	1092	1106	1126	1140	1168	1196	BALANCE POINT 12 DEG.F.
.16	\$ 1140	1154	1168	1182	1196	1210	1224	1238	1259	1272	1300	1328	
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 479	493	514	528	542	563	577	598	612	626	660	695	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 556	570	591	605	619	639	653	674	688	702	737	772	S PER YEAR
.07	\$ 626	639	660	674	688	709	723	744	758	772	806	841	
.08	\$ 695	709	730	744	758	779	793	813	827	841	876	911	
.09	\$ 772	786	806	820	834	855	869	890	904	918	952	987	
.10	\$ 841	855	876	890	904	925	939	959	973	987	1022	1057	
.12	\$ 987	1001	1022	1036	1050	1071	1085	1106	1119	1133	1168	1203	BALANCE POINT 15 DEG.F.
.14	\$ 1133	1147	1168	1182	1196	1217	1231	1252	1266	1279	1314	1349	
.16	\$ 1279	1293	1314	1328	1342	1363	1377	1398	1412	1426	1460	1495	
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 563	591	619	646	674	695	723	751	779	806	862	911	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 639	667	695	723	751	772	799	827	855	883	939	987	S PER YEAR
.07	\$ 716	744	772	799	827	848	876	904	932	959	1015	1064	
.08	\$ 793	820	848	876	904	925	952	980	1008	1036	1092	1140	
.09	\$ 862	890	918	946	973	994	1022	1050	1078	1106	1161	1210	
.10	\$ 939	966	994	1022	1050	1071	1099	1126	1154	1182	1238	1286	
.12	\$ 1092	1119	1147	1175	1203	1224	1252	1279	1307	1335	1391	1439	BALANCE POINT 21 DEG.F.
.14	\$ 1245	1272	1300	1328	1356	1377	1405	1432	1460	1488	1544	1592	
.16	\$ 1391	1419	1446	1474	1502	1523	1551	1579	1606	1634	1690	1739	
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 639	681	723	765	806	848	890	932	973	1008	1092	1175	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 716	758	799	841	883	925	966	1008	1050	1085	1168	1252	S PER YEAR
.07	\$ 786	827	869	911	952	994	1036	1078	1119	1154	1238	1321	
.08	\$ 855	897	939	980	1022	1064	1106	1147	1189	1224	1307	1391	
.09	\$ 925	966	1008	1050	1092	1133	1175	1217	1259	1293	1377	1460	
.10	\$ 1001	1043	1085	1126	1168	1210	1252	1293	1335	1370	1453	1537	
.12	\$ 1140	1182	1224	1266	1307	1349	1391	1432	1474	1509	1592	1676	BALANCE POINT 26 DEG.F.
.14	\$ 1286	1328	1370	1412	1453	1495	1537	1579	1620	1655	1739	1822	
.16	\$ 1426	1467	1509	1551	1592	1634	1676	1718	1759	1794	1878	1961	
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 723	779	841	897	959	1015	1078	1133	1196	1252	1377	1495	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 786	841	904	959	1015	1078	1140	1196	1259	1314	1439	1558	S PER YEAR
.07	\$ 841	897	959	1015	1078	1133	1196	1252	1314	1370	1495	1613	
.08	\$ 904	959	1022	1078	1140	1196	1259	1314	1377	1432	1558	1676	
.09	\$ 966	1022	1085	1140	1203	1259	1321	1377	1439	1495	1620	1739	
.10	\$ 1029	1085	1147	1203	1266	1321	1384	1439	1502	1558	1683	1801	
.12	\$ 1147	1203	1266	1321	1384	1439	1502	1558	1620	1676	1801	1919	BALANCE POINT 30 DEG.F.
.14	\$ 1272	1328	1391	1446	1509	1565	1627	1683	1745	1801	1926	2045	
.16	\$ 1391	1446	1509	1565	1627	1683	1745	1801	1864	1919	2045	2163	
80,000	\$ 758	862	973	1085	1189	1300	1405	1516	1627	1732	1947	2170	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 799	876	959	1036	1119	1196	1279	1356	1439	1516	1676	1836	THEORETICAL HEATING COST * FURN.+ HEAT PUMP
.06	\$ 848	925	1008	1085	1168	1245	1328	1405	1488	1565	1725	1885	S PER YEAR
.07	\$ 897	973	1057	1133	1217	1293	1453	1537	1613	1773	1933		
.08	\$ 946	1022	1106	1182	1266	1342	1426	1502	1586	1662	1822	1982	
.09	\$ 994	1071	1154	1231	1314	1391	1474	1551	1634	1711	1871	2031	
.10	\$ 1043	1119	1203	1279	1363	1439	1523	1599	1683	1759	1919	2079	
.12	\$ 1133	1210	1293	1370	1453	1530	1613	1690	1773	1850	2010	2170	
.14	\$ 1231	1307	1391	1467	1551	1627	1711	1787	1871	1947	2107	2267	BALANCE POINT 33 DEG.F.
.16	\$ 1328	1405	1488	1565	1648	1725	1808	1885	1968	2045	2205	2365	

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 --ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 36UHPOB INDOOR A37AO-A
ARI RATED COOLING CAP.: BTUH(95) 36000, SEER10.00
ARI RATED HEATING CAP.: BTUH (47) 36000 COP(47) 3.10, HSPF 7.20 MIN.DER REG IV
BTUH (17) 21000, COP(17) 2.20
FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

BTUH	ELEC. COST S/KWH	.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80		
HEATING OIL COST - \$/GALLON															
35,000	\$ 473	542	612	681	751	820	890	952	1022	1092	1161	1231	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 473	493	514	535	556	577	598	619	639	660	681	709			
.06	\$ 535	556	577	598	619	639	660	681	702	723	744	772	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 598	619	639	660	681	702	723	744	765	786	806	834	S PER YEAR		
.08	\$ 660	681	702	723	744	765	786	806	827	848	869	897			
.09	\$ 730	751	772	793	813	834	855	876	897	918	939	966			
.10	\$ 793	813	834	855	876	897	918	939	959	980	1001	1029			
.12	\$ 925	946	966	987	1008	1029	1050	1071	1092	1112	1132	1161			
.14	\$ 1050	1071	1092	1112	1133	1154	1175	1196	1217	1238	1259	1286	BALANCE POINT 12 DEG.F.		
.16	\$ 1182	1203	1224	1245	1266	1286	1307	1328	1349	1370	1391	1419			
40,000	\$ 542	626	702	779	855	939	1015	1092	1168	1252	1328	1405	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 528	556	577	605	626	653	674	695	723	744	772	793			
.06	\$ 605	633	653	681	702	730	751	772	799	820	848	869	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 674	702	723	751	772	799	820	841	869	890	918	939	S PER YEAR		
.08	\$ 744	772	793	820	841	869	890	911	939	959	987	1008			
.09	\$ 820	848	869	897	918	946	966	987	1015	1036	1064	1085			
.10	\$ 890	918	939	966	987	1015	1036	1057	1085	1106	1133	1154			
.12	\$ 1036	1064	1085	1112	1133	1161	1182	1203	1231	1252	1279	1300	BALANCE POINT 15 DEG.F.		
.14	\$ 1182	1210	1231	1259	1279	1307	1328	1349	1377	1398	1426	1446			
.16	\$ 1328	1356	1377	1405	1426	1453	1474	1495	1523	1544	1572	1592			
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 646	688	723	765	799	841	883	918	959	994	1036	1071			
.06	\$ 723	765	799	841	876	918	959	994	1036	1071	1112	1147	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 799	841	876	918	952	994	1036	1071	1112	1147	1189	1224	S PER YEAR		
.08	\$ 876	918	952	994	1029	1071	1112	1147	1189	1224	1266	1300			
.09	\$ 946	987	1022	1064	1099	1140	1182	1217	1259	1293	1335	1370			
.10	\$ 1022	1064	1099	1140	1175	1217	1259	1293	1335	1370	1412	1446			
.12	\$ 1175	1217	1252	1293	1328	1370	1412	1446	1488	1523	1565	1599	BALANCE POINT 21 DEG.F.		
.14	\$ 1328	1370	1405	1446	1481	1523	1565	1599	1641	1676	1718	1752			
.16	\$ 1474	1516	1551	1592	1627	1669	1711	1745	1787	1822	1864	1899			
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2107	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 772	827	890	946	1008	1064	1126	1182	1245	1300	1363	1419			
.06	\$ 848	904	966	1022	1085	1140	1203	1259	1321	1377	1439	1495	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 918	973	1036	1092	1152	1210	1272	1328	1391	1446	1509	1565	S PER YEAR		
.08	\$ 987	1043	1106	1161	1224	1279	1342	1398	1460	1516	1579	1634			
.09	\$ 1057	1112	1175	1231	1293	1349	1412	1467	1530	1586	1648	1704			
.10	\$ 1133	1189	1252	1307	1370	1426	1488	1544	1606	1662	1725	1780	BALANCE POINT 26 DEG.F.		
.12	\$ 1272	1328	1391	1446	1509	1565	1627	1683	1745	1801	1864	1919			
.14	\$ 1419	1474	1537	1592	1655	1711	1773	1829	1892	1947	2010	2065			
.16	\$ 1558	1613	1676	1732	1794	1850	1912	1968	2031	2086	2149	2205			
70,000	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 904	987	1078	1161	1245	1335	1419	1502	1586	1676	1759	1843			
.06	\$ 966	1050	1140	1224	1307	1398	1481	1565	1648	1739	1822	1905	THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 1022	1106	1196	1279	1363	1453	1537	1620	1704	1794	1878	1961	S PER YEAR		
.08	\$ 1085	1168	1259	1342	1426	1516	1599	1683	1766	1857	1940	2024			
.09	\$ 1147	1231	1321	1405	1488	1579	1662	1745	1829	1919	2003	2086			
.10	\$ 1210	1293	1384	1467	1551	1641	1725	1808	1892	1982	2065	2149			
.12	\$ 1328	1412	1502	1586	1669	1759	1843	1926	2010	2100	2184	2267	BALANCE POINT 30 DEG.F.		
.14	\$ 1453	1537	1627	1711	1794	1885	1968	2052	2135	2225	2309	2392			
.16	\$ 1572	1655	1745	1829	1912	2003	2086	2170	2253	2344	2427	2511			
80,000	\$ 1092	1252	1405	1565	1718	1878	2031	2191	2344	2504	2657	2817	--THEORETICAL HEATING COST * FURNACE ONLY		
.05	\$ 1043	1161	1272	1391	1509	1620	1739	1857	1968	2086	2198	2316			
.06	\$ 1092	1231	1439	1558	1669	1787	1905	2017	2135	2246	2365		THEORETICAL HEATING COST * FURN.+ HEAT PUMP		
.07	\$ 1140	1370	1488	1606	1718	1836	1954	2065	2184	2295	2413		S PER YEAR		
.08	\$ 1189	1219	1537	1655	1766	1885	2003	2114	2232	2344	2462				
.09	\$ 1238	1467	1586	1704	1815	1933	2052	2163	2281	2392	2511				
.10	\$ 1286	1416	1634	1752	1864	1982	2100	2212	2330	2441	2559				
.12	\$ 1377	1506	1725	1843	1954	2072	2191	2302	2420	2532	2650		BALANCE POINT 33 DEG.F.		
.14	\$ 1474	1516	1704	1822	1940	2052	2170	2288	2399	2518	2629	2747			
.16	\$ 1572	1690	1801	1919	2038	2149	2267	2385	2497	2615	2726	2845			

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 **--ELECTRIC RATE \$/KWH**

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 36UHP0B 36UHP0B INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 36000 SEER10.00
 ARI RATED HEATING CAP.: BTUH (47) 36000 COP(47) 3.10, HSPF 7.20 MIN.DR REG IV
 BTUH (17) 21000, COP(17) 2.20
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON									
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10
35,000	\$ 626	674	730	779	834	883	939	987	1043	1147	1252 1252
	-.05	\$ 521	535	549	570	584	598	619	633	646	681 709
	.06	\$ 584	598	612	633	646	660	681	695	709	744 772
	.07	\$ 646	660	674	695	709	723	744	758	772	806 834
	.08	\$ 709	723	737	758	772	806	820	834	857	897 897
	.09	\$ 779	793	806	827	841	855	876	890	904	939 966
	.10	\$ 841	855	869	890	904	918	939	952	966	1001 1029
	.12	\$ 973	987	1001	1022	1036	1050	1071	1085	1099	1133 1161
	.14	\$ 1099	1112	1126	1147	1161	1175	1196	1210	1224	1259 1286
	.16	\$ 1231	1245	1259	1279	1293	1307	1328	1342	1356	1391 1419
											BALANCE POINT 12 DEG.F.
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426 1426
	.05	\$ 584	598	619	639	653	674	688	709	730	765 799
	.06	\$ 660	674	695	716	730	751	765	786	806	841 876
	.07	\$ 730	744	765	786	799	820	834	855	876	911 946
	.08	\$ 799	813	834	855	869	890	904	925	946	980 1015
	.09	\$ 876	890	911	932	946	966	980	1001	1022	1057 1092
	.10	\$ 946	959	980	1001	1015	1036	1050	1071	1092	1126 1161
	.12	\$ 1092	1106	1126	1147	1161	1182	1196	1217	1238	1272 1307
	.14	\$ 1238	1252	1272	1293	1307	1328	1342	1363	1384	1419 1453
	.16	\$ 1384	1398	1419	1439	1453	1474	1488	1509	1530	1565 1599
											BALANCE POINT 15 DEG.F.
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787 1787
	.05	\$ 730	758	793	820	848	876	911	939	966	1029 1085
	.06	\$ 806	834	869	897	925	952	987	1015	1043	1106 1161
	.07	\$ 883	911	946	973	1001	1029	1064	1092	1119	1182 1238
	.08	\$ 959	987	1022	1050	1078	1106	1140	1168	1196	1259 1314
	.09	\$ 1029	1057	1092	1119	1147	1175	1210	1238	1266	1328 1384
	.10	\$ 1106	1133	1168	1196	1224	1252	1286	1314	1342	1405 1460
	.12	\$ 1259	1286	1321	1349	1377	1405	1439	1467	1495	1558 1613
	.14	\$ 1412	1439	1474	1502	1530	1558	1592	1620	1648	1711 1766
	.16	\$ 1558	1586	1620	1648	1676	1704	1739	1766	1794	1857 1912
											BALANCE POINT 21 DEG.F.
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142 2142
	.05	\$ 897	939	987	1029	1078	1119	1168	1210	1259	1349 1439
	.06	\$ 973	1015	1064	1106	1154	1196	1245	1286	1335	1426 1516
	.07	\$ 1043	1085	1133	1175	1224	1266	1314	1356	1405	1495 1586
	.08	\$ 1112	1154	1203	1245	1293	1335	1384	1426	1474	1565 1655
	.09	\$ 1182	1224	1272	1314	1363	1405	1453	1495	1544	1634 1725
	.10	\$ 1259	1300	1349	1391	1439	1481	1530	1572	1620	1711 1801
	.12	\$ 1398	1439	1488	1530	1579	1620	1669	1711	1759	1850 1940
	.14	\$ 1544	1586	1634	1676	1725	1766	1815	1857	1905	1996 2086
	.16	\$ 1683	1725	1773	1815	1864	1905	1954	1996	2045	2135 2225
											BALANCE POINT 26 DEG.F.
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504 2504
	.05	\$ 1085	1154	1217	1286	1349	1412	1481	1544	1606	1739 1871
	.06	\$ 1147	1217	1279	1349	1412	1474	1544	1606	1669	1801 1933
	.07	\$ 1203	1272	1335	1405	1467	1530	1599	1662	1725	1857 1989
	.08	\$ 1266	1335	1398	1467	1530	1592	1662	1725	1787	1919 2052
	.09	\$ 1328	1398	1460	1530	1592	1655	1725	1787	1850	1982 2114
	.10	\$ 1391	1460	1523	1592	1655	1718	1787	1850	1912	2045 2177
	.12	\$ 1509	1579	1641	1711	1773	1836	1905	1968	2031	2163 2295
	.14	\$ 1634	1704	1766	1836	1899	1961	2031	2093	2156	2288 2420
	.16	\$ 1752	1822	1885	1954	2017	2079	2149	2212	2274	2406 2538
											BALANCE POINT 30 DEG.F.
80,000	\$ 1426	1551	1669	1787	1905	2024	2142	2260	2385	2622	2858 2858
	.05	\$ 1293	1384	1467	1558	1648	1732	1822	1912	1996	2170 2351
	.06	\$ 1342	1432	1516	1606	1697	1780	1871	1961	2045	2219 2399
	.07	\$ 1391	1481	1565	1655	1745	1829	1919	2010	2093	2267 2448
	.08	\$ 1439	1530	1613	1704	1794	1878	1968	2059	2142	2316 2497
	.09	\$ 1488	1579	1662	1752	1843	1926	2017	2107	2191	2365 2545
	.10	\$ 1537	1627	1711	1801	1892	1975	2065	2156	2239	2413 2594
	.12	\$ 1627	1718	1801	1892	1982	2065	2156	2246	2330	2504 2685
	.14	\$ 1725	1815	1899	1989	2079	2163	2253	2344	2427	2601 2782
	.16	\$ 1822	1912	1996	2086	2177	2260	2351	2441	2525	2698 2879
											BALANCE POINT 33 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16

<--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

REGION 5
 HEAT PUMP MODEL: OUTDOOR 42UHPOA INDOOR A61AQ-A
 ARI RATED COOLING CAP.: BTUH(95) 43500 SEER11.30
 ARI RATED HEATING CAP.: BTUH (47) 41000 COP(47) 3.40, ESSP 7.60 MIN.DHR REG IV
 BTUH (17) 25000 COP(17) 2.20
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH KILO COST
 \$/KWH

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	841	1544
.06	\$	1001	1857
.07	\$	1168	2170
.08	\$	1335	2476
.09	\$	1509	2789
.10	\$	1676	3095
.12	\$	2010	3721
.14	\$	2351	4340
.16	\$	2678	4959

BALANCE POINT 16 DEG. F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1022	1857
.06	\$	1231	2232
.07	\$	1439	2601
.08	\$	1634	2977
.09	\$	1843	3345
.10	\$	2052	3721
.12	\$	2462	4465
.14	\$	2872	5210
.16	\$	3283	5954

BALANCE POINT 22 DEG. F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1231	2170
.06	\$	1481	2601
.07	\$	1725	3039
.08	\$	1968	3471
.09	\$	2225	3902
.10	\$	2469	4340
.12	\$	2963	5210
.14	\$	3450	6079
.16	\$	3951	6942

BALANCE POINT 26 DEG. F.

80,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1460	2476
.06	\$	1759	2977
.07	\$	2045	3471
.08	\$	2337	3965
.09	\$	2636	4465
.10	\$	2921	4959
.12	\$	3505	5954
.14	\$	4097	6942
.16	\$	4681	7936

BALANCE POINT 30 DEG. F.

90,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1704	2789
.06	\$	2038	3345
.07	\$	2385	3902
.08	\$	2726	4465
.09	\$	3060	5022
.10	\$	3408	5578
.12	\$	4083	6698
.14	\$	4764	7811
.16	\$	5446	8931

BALANCE POINT 33 DEG. F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05	.06	.07	.08	.09	.10	.12	.14	.16
76	92	107	123	138	153	184	215	246

-->ELECTRIC RATE \$/KWH
 -->THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

REGION 5		42UHPOA/A61AO-A														
HEAT PUMP MODEL: OUTDOOR 42UHPOA INDOOR A61AO-A		ARI RATED COOLING CAP.: BTUH(95) 43500, SEER11.30														
ARI RATED HEATING CAP.: BTUH (47) 41000, COP(47) 3.40, BHP 7.60 MIN. OBR REG IV		BTUH (17) 25000, COP(17) 2.20														
FURNACE TYPE NATURAL GAS		FURNACE EFFICIENCY 78.00 % AFUE														
HEAT LOSS BTUH	KWH COST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00			
40,000	\$ 375	431	486	542	591	646	702	758	813	862	973	1085	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 514	528	542	549	563	577	591	598	612	626	646	674				
	.06 \$ 605	619	633	639	653	667	681	688	702	716	737	765	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 688	702	716	723	737	751	765	772	786	799	820	848				
	.08 \$ 779	793	806	813	827	841	855	862	876	890	911	939				
	.09 \$ 862	876	890	897	911	925	939	946	959	973	994	1022				
	.10 \$ 952	966	980	987	1001	1015	1029	1036	1050	1064	1085	1112				
	.12 \$ 1126	1140	1154	1161	1175	1189	1203	1210	1224	1238	1259	1286				
	.14 \$ 1293	1307	1321	1328	1342	1356	1370	1377	1391	1405	1426	1453	BALANCE POINT 11 DEG.F.			
	.16 \$ 1467	1481	1495	1502	1516	1530	1544	1551	1565	1579	1599	1627				
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 605	626	646	667	688	709	730	751	772	793	834	876				
	.06 \$ 695	716	737	758	779	799	820	841	862	883	925	966	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 793	813	834	855	876	897	918	939	959	980	1022	1064				
	.08 \$ 883	904	925	946	966	987	1008	1022	1050	1071	1112	1154				
	.09 \$ 973	994	1015	1036	1057	1078	1099	1119	1140	1161	1203	1245				
	.10 \$ 1064	1085	1106	1126	1147	1168	1189	1210	1231	1252	1293	1335				
	.12 \$ 1252	1272	1293	1314	1335	1356	1377	1398	1419	1439	1481	1523	BALANCE POINT 16 DEG.F.			
	.14 \$ 1432	1453	1474	1495	1516	1537	1558	1579	1599	1620	1662	1704				
	.16 \$ 1620	1641	1662	1683	1704	1725	1745	1766	1787	1808	1850	1892				
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 660	702	744	786	827	869	911	952	994	1029	1112	1196				
	.06 \$ 737	779	820	862	904	946	987	1029	1071	1106	1189	1272	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 813	855	897	939	980	1022	1064	1106	1147	1182	1266	1349				
	.08 \$ 890	932	973	1015	1057	1099	1140	1182	1224	1259	1342	1426				
	.09 \$ 966	1008	1050	1092	1133	1175	1217	1259	1300	1335	1419	1502				
	.10 \$ 1043	1085	1126	1168	1210	1252	1293	1335	1377	1412	1495	1579	BALANCE POINT 22 DEG.F.			
	.12 \$ 1189	1231	1272	1314	1356	1398	1439	1481	1523	1558	1641	1725				
	.14 \$ 1342	1384	1426	1467	1509	1551	1592	1634	1676	1711	1794	1878				
	.16 \$ 1495	1537	1579	1620	1662	1704	1745	1787	1829	1864	1947	2031				
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 765	813	862	911	959	1008	1050	1099	1147	1196	1293	1391				
	.06 \$ 848	897	946	994	1043	1092	1133	1182	1231	1279	1377	1474	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 939	987	1036	1085	1133	1182	1224	1272	1321	1370	1467	1565				
	.08 \$ 1022	1071	1119	1168	1217	1266	1307	1356	1405	1453	1551	1648				
	.09 \$ 1106	1154	1203	1252	1300	1349	1391	1439	1488	1537	1634	1732	BALANCE POINT 26 DEG.F.			
	.10 \$ 1196	1245	1293	1342	1391	1439	1481	1530	1579	1627	1725	1822				
	.12 \$ 1363	1412	1460	1509	1558	1606	1648	1697	1745	1794	1892	1989				
	.14 \$ 1537	1586	1634	1683	1732	1780	1822	1871	1919	1968	2065	2163				
	.16 \$ 1711	1759	1808	1857	1905	1954	1996	2045	2093	2142	2239	2337				
80,000	\$ 758	862	973	1085	1189	1300	1405	1516	1627	1732	1947	2170	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 834	904	973	1036	1106	1175	1245	1307	1377	1446	1579	1718				
	.06 \$ 904	973	1043	1106	1175	1245	1314	1377	1446	1516	1648	1787	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 973	1043	1112	1175	1245	1314	1384	1446	1516	1584	1718	1857				
	.08 \$ 1050	1119	1189	1252	1321	1391	1460	1530	1592	1662	1732	1864	2003			
	.09 \$ 1119	1189	1259	1321	1391	1460	1530	1592	1662	1732	1801	1933	BALANCE POINT 30 DEG.F.			
	.10 \$ 1189	1259	1328	1391	1460	1530	1599	1662	1732	1801	1933	2072				
	.12 \$ 1335	1405	1474	1537	1606	1676	1745	1808	1878	1947	2079	2219				
	.14 \$ 1481	1551	1620	1683	1752	1822	1892	1954	2024	2093	2225	2365				
	.16 \$ 1620	1690	1759	1822	1892	1961	2031	2093	2163	2232	2365	2504				
90,000	\$ 848	973	1099	1217	1342	1460	1586	1704	1829	1947	2198	2441	--THEORETICAL HEATING COST * FURNACE ONLY			
	.05 \$ 904	994	1085	1175	1266	1356	1439	1530	1620	1711	1892	2072				
	.06 \$ 959	1050	1140	1231	1321	1412	1495	1586	1676	1766	1947	2128	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR			
	.07 \$ 1015	1106	1196	1286	1377	1467	1551	1641	1732	1822	2003	2184				
	.08 \$ 1071	1161	1252	1342	1432	1523	1606	1697	1787	1878	2059	2239				
	.09 \$ 1119	1210	1300	1391	1481	1572	1655	1745	1836	1926	2107	2288				
	.10 \$ 1175	1266	1356	1446	1537	1627	1711	1801	1892	1982	2163	2344	BALANCE POINT 33 DEG.F.			
	.12 \$ 1286	1377	1467	1558	1648	1739	1822	1912	2003	2093	2274	2455				
	.14 \$ 1398	1488	1579	1669	1759	1850	1933	2024	2114	2205	2385	2566				
	.16 \$ 1502	1592	1683	1773	1864	1954	2038	2128	2219	2309	2490	2671				

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 --ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 42UHPOA INDOOR A61AO-A
BTUH (95) 43500 SEER11.30
BTUH (47) 41000 COP(47) 3.40, ESPP 7.60 MIN.DER REG IV
BTUH (17) 25000, COP(17) 2.20
FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON														
40,000	\$.70 .80 .90 1.00 1.10 1.20 1.30 1.40 1.50 1.60 1.70 1.80															
.05	\$ 542 626 702 779 855 939 1015 1092 1168 1252 1328 1405	<-THEORETICAL HEATING COST * FURNACE ONLY														
.06	\$ 556 630 591 605 626 639 660 674 695 709 730 744	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 646 660 681 695 716 730 751 765 786 799 820 834															
.08	\$ 730 744 765 779 799 813 834 848 869 883 904 918															
.09	\$ 820 834 855 869 890 904 925 939 959 973 994 1008															
.10	\$ 904 918 939 952 973 987 1008 1022 1043 1057 1078 1092															
.12	\$ 994 1008 1029 1043 1064 1078 1099 1112 1133 1147 1168 1182															
.14	\$ 1158 1182 1203 1217 1238 1252 1272 1286 1307 1321 1342 1356															
.16	\$ 1335 1349 1370 1384 1405 1419 1439 1453 1474 1488 1509 1523															BALANCE POINT 11 DEG.F.
	\$ 1509 1523 1544 1558 1579 1592 1613 1627 1648 1662 1683 1697															
50,000	\$ 681 779 876 973 1071 1168 1266 1363 1467 1565 1662 1759	<-THEORETICAL HEATING COST * FURNACE ONLY														
.05	\$ 667 702 730 758 793 820 848 883 911 939 973 1001															
.06	\$ 758 793 820 848 883 911 939 973 1001 1029 1064 1092	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 855 890 918 946 980 1008 1036 1071 1099 1126 1161 1189															
.08	\$ 946 980 1008 1036 1071 1099 1126 1161 1189 1217 1252 1279															
.09	\$ 1036 1071 1099 1126 1161 1189 1217 1252 1279 1307 1342 1370															
.10	\$ 1126 1161 1189 1217 1252 1279 1307 1342 1370 1398 1432 1460															
.12	\$ 1314 1349 1377 1405 1439 1467 1495 1530 1558 1586 1620 1648															
.14	\$ 1495 1530 1558 1586 1620 1648 1676 1711 1739 1766 1801 1829															BALANCE POINT 16 DEG.F.
.16	\$ 1683 1718 1745 1773 1808 1836 1864 1899 1926 1954 1989 2017															
60,000	\$ 820 939 1050 1168 1286 1405 1523 1641 1759 1878 1996 2107	<-THEORETICAL HEATING COST * FURNACE ONLY														
.05	\$ 793 848 911 966 1029 1085 1147 1203 1266 1321 1384 1439															
.06	\$ 869 925 987 1043 1106 1161 1224 1279 1342 1398 1460 1516	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 946 1001 1064 1119 1182 1238 1300 1356 1419 1474 1537 1592															
.08	\$ 1022 1078 1140 1196 1259 1314 1377 1432 1495 1551 1613 1669															
.09	\$ 1099 1154 1217 1272 1335 1391 1453 1509 1572 1627 1690 1745															
.10	\$ 1175 1231 1293 1349 1412 1467 1530 1586 1648 1704 1766 1822															
.12	\$ 1321 1377 1439 1495 1558 1613 1676 1732 1794 1850 1912 1968															
.14	\$ 1474 1530 1592 1648 1711 1766 1829 1885 1947 2003 2065 2121															BALANCE POINT 22 DEG.F.
.16	\$ 1627 1683 1745 1801 1864 1919 1982 2038 2100 2156 2219 2274															
70,000	\$ 952 1092 1231 1363 1502 1641 1780 1912 2052 2191 2323 2462	<-THEORETICAL HEATING COST * FURNACE ONLY														
.05	\$ 911 980 1050 1119 1189 1259 1328 1398 1467 1537 1606 1676															
.06	\$ 994 1064 1133 1202 1271 1342 1412 1481 1551 1620 1690 1759	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 1085 1154 1224 1291 1362 1432 1502 1572 1641 1711 1780 1850															
.08	\$ 1168 1238 1307 1371 1446 1516 1584 1655 1725 1794 1864 1933															
.09	\$ 1252 1321 1391 1460 1530 1599 1669 1739 1808 1878 1947 2017															
.10	\$ 1342 1412 1481 1551 1620 1690 1759 1829 1899 1968 2038 2107															
.12	\$ 1509 1579 1648 1718 1857 1926 1996 2065 2135 2205 2274 2337															BALANCE POINT 26 DEG.F.
.14	\$ 1683 1752 1822 1892 1961 2031 2100 2170 2239 2309 2379 2448															
.16	\$ 1857 1926 2065 2135 2205 2274 2344 2413 2483 2552 2622 2701															
80,000	\$ 1092 1252 1405 1565 1718 1878 2031 2191 2344 2504 2657 2817	<-THEORETICAL HEATING COST * FURNACE ONLY														
.05	\$ 1043 1140 1245 1342 1439 1537 1634 1732 1829 1926 2024 2121															
.06	\$ 1112 1210 1314 1412 1509 1606 1704 1801 1899 1996 2093 2191	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 1182 1279 1384 1481 1579 1676 1773 1871 1968 2065 2163 2260															
.08	\$ 1259 1356 1460 1558 1655 1752 1850 1947 2045 2142 2239 2337															
.09	\$ 1328 1426 1530 1627 1725 1822 1919 2017 2114 2212 2309 2406															
.10	\$ 1398 1495 1599 1697 1794 1892 1989 2086 2184 2281 2379 2476															
.12	\$ 1544 1641 1745 1843 1940 2038 2135 2232 2365 2490 2622 2754															BALANCE POINT 30 DEG.F.
.14	\$ 1690 1787 1892 1989 2086 2184 2281 2379 2476 2573 2671 2768															
.16	\$ 1829 1926 2031 2128 2225 2323 2420 2518 2615 2712 2810 2907															
90,000	\$ 1231 1405 1579 1759 1933 2107 2288 2462 2636 2817 2991 3165	<-THEORETICAL HEATING COST * FURNACE ONLY														
.05	\$ 1182 1307 1439 1572 1704 1829 1961 2093 2219 2351 2483 2608															
.06	\$ 1238 1363 1495 1627 1759 1885 2017 2149 2274 2406 2538 2664	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR														
.07	\$ 1293 1419 1551 1683 1815 1940 2072 2205 2330 2462 2594 2719															
.08	\$ 1349 1474 1606 1739 1871 1996 2128 2260 2385 2518 2650 2775															
.09	\$ 1398 1523 1655 1787 1919 2045 2177 2309 2434 2566 2698 2824															
.10	\$ 1453 1579 1711 1843 2100 2232 2365 2490 2622 2754 2879															
.12	\$ 1665 1690 1822 1954 2086 2212 2344 2476 2601 2733 2865 2991															
.14	\$ 1676 1801 1933 2065 2198 2323 2455 2587 2712 2845 2977 3102															BALANCE POINT 33 DEG.F.
.16	\$ 1780 1905 2038 2170 2302 2427 2559 2692 2817 2949 3081 3206															

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 <-ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 42UHPOA INDOOR A61AO-A
ARI RATED COOLING CAP.: BTUH(95) 43500 SEER11.30
ARI RATED HEATING CAP.: BTUH (47) 41000 COP(47) 3.40, BSPF 7.60 MIN.DHR REG IV
BTUH (17) 25000, COP(17) 2.20
FURNACE TYPE: PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON										
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20
--THEORETICAL HEATING COST * FURNACE ONLY												
40,000	\$ 709	772	834	890	952	1008	1071	1126	1189	1307	1426	1426
.05	\$ 591	605	619	633	646	660	674	681	695	723	751	751
.06	\$ 681	695	709	723	737	751	765	772	786	813	841	841
.07	\$ 765	779	793	806	820	834	848	855	869	897	925	925
.08	\$ 855	869	883	897	911	925	939	946	959	987	1015	1015
.09	\$ 939	952	966	980	994	1008	1022	1029	1043	1071	1099	1099
.10	\$ 1029	1043	1057	1071	1085	1099	1112	1119	1133	1161	1189	1189
.12	\$ 1203	1217	1231	1245	1259	1272	1286	1293	1307	1335	1363	1363
.14	\$ 1370	1384	1398	1412	1426	1439	1453	1460	1474	1502	1530	1530
.16	\$ 1544	1558	1572	1586	1599	1613	1627	1634	1648	1676	1704	1704
BALANCE POINT 11 DEG.F.												
--THEORETICAL HEATING COST * FURNACE ONLY												
50,000	\$ 890	966	1043	1112	1189	1266	1335	1412	1488	1634	1787	1787
.05	\$ 737	758	779	799	827	848	869	887	918	966	1008	1008
.06	\$ 821	848	869	890	918	939	959	987	1008	1057	1099	1099
.07	\$ 925	946	966	987	1011	1036	1057	1085	1106	1154	1196	1196
.08	\$ 1015	1036	1057	1078	1106	1126	1147	1175	1196	1245	1286	1286
.09	\$ 1106	1126	1147	1168	1196	1217	1238	1266	1286	1335	1377	1377
.10	\$ 1196	1217	1238	1259	1286	1307	1328	1356	1377	1426	1467	1467
.12	\$ 1384	1405	1426	1446	1474	1495	1516	1544	1565	1613	1655	1655
.14	\$ 1565	1586	1606	1627	1655	1676	1697	1725	1745	1794	1836	1836
.16	\$ 1752	1773	1794	1815	1843	1864	1885	1912	1933	1982	2024	2024
BALANCE POINT 16 DEG.F.												
--THEORETICAL HEATING COST * FURNACE ONLY												
60,000	\$ 1071	1161	1252	1335	1426	1516	1606	1697	1787	1968	2142	2142
.05	\$ 918	959	1008	1050	1099	1140	1189	1231	1279	1370	1460	1460
.06	\$ 994	1036	1085	1126	1175	1217	1266	1307	1356	1446	1537	1537
.07	\$ 1071	1112	1161	1203	1252	1293	1342	1384	1432	1523	1613	1613
.08	\$ 1147	1189	1238	1279	1328	1370	1419	1460	1509	1595	1690	1690
.09	\$ 1224	1266	1314	1356	1405	1446	1495	1537	1586	1676	1766	1766
.10	\$ 1300	1342	1391	1432	1481	1523	1572	1613	1662	1752	1843	1843
.12	\$ 1446	1488	1537	1579	1627	1669	1718	1759	1808	1899	1989	1989
.14	\$ 1599	1641	1690	1732	1780	1822	1871	1912	1961	2052	2142	2142
.16	\$ 1752	1794	1843	1885	1933	1975	2024	2065	2114	2205	2295	2295
BALANCE POINT 22 DEG.F.												
--THEORETICAL HEATING COST * FURNACE ONLY												
70,000	\$ 1252	1356	1460	1565	1669	1773	1878	1982	2086	2295	2504	2504
.05	\$ 1064	1112	1168	1217	1272	1328	1377	1432	1481	1586	1697	1697
.06	\$ 1147	1196	1252	1300	1356	1412	1460	1516	1565	1669	1780	1780
.07	\$ 1238	1286	1342	1391	1446	1502	1551	1606	1655	1759	1871	1871
.08	\$ 1321	1370	1426	1474	1530	1586	1634	1690	1739	1843	1954	1954
.09	\$ 1405	1453	1509	1558	1613	1669	1718	1773	1822	1926	2038	2038
.10	\$ 1495	1544	1599	1648	1704	1759	1808	1864	1912	2017	2128	2128
.12	\$ 1662	1711	1766	1815	1871	1926	1975	2031	2079	2184	2295	2295
.14	\$ 1836	1885	1940	1989	2045	2100	2149	2205	2253	2358	2469	2469
.16	\$ 2010	2059	2114	2163	2219	2274	2323	2379	2427	2532	2643	2643
BALANCE POINT 26 DEG.F.												
--THEORETICAL HEATING COST * FURNACE ONLY												
80,000	\$ 1426	1551	1669	1787	1905	2024	2142	2260	2385	2622	2858	2858
.05	\$ 1259	1328	1405	1481	1551	1627	1704	1780	1850	2003	2149	2149
.06	\$ 1328	1398	1474	1551	1620	1697	1773	1850	1919	2072	2219	2219
.07	\$ 1398	1467	1544	1620	1690	1766	1843	1919	1989	2142	2288	2288
.08	\$ 1474	1544	1620	1697	1766	1843	1919	1996	2065	2219	2365	2365
.09	\$ 1544	1613	1690	1766	1836	1912	1989	2065	2135	2288	2434	2434
.10	\$ 1613	1683	1753	1836	1905	1982	2059	2135	2209	2358	2504	2504
.12	\$ 1759	1829	1905	1982	2052	2128	2205	2281	2351	2504	2650	2650
.14	\$ 1905	1975	2052	2128	2198	2274	2351	2427	2497	2650	2796	2796
.16	\$ 2045	2114	2191	2267	2337	2413	2490	2566	2636	2789	2935	2935
BALANCE POINT 30 DEG.F.												
--THEORETICAL HEATING COST * FURNACE ONLY												
90,000	\$ 1606	1739	1878	2010	2142	2281	2413	2545	2678	2949	3220	3220
.05	\$ 1460	1558	1655	1759	1857	1954	2052	2156	2253	2448	2650	2650
.06	\$ 1516	1613	1711	1815	1912	2010	2107	2212	2309	2504	2705	2705
.07	\$ 1572	1669	1766	1871	1968	2065	2163	2267	2365	2559	2761	2761
.08	\$ 1627	1725	1822	1926	2024	2121	2219	2323	2420	2615	2817	2817
.09	\$ 1676	1713	1871	1975	2072	2170	2267	2372	2469	2664	2865	2865
.10	\$ 1732	1829	1926	2031	2128	2225	2323	2427	2525	2719	2921	2921
.12	\$ 1843	1940	2038	2142	2239	2337	2434	2538	2636	2831	3032	3032
.14	\$ 1954	2052	2149	2253	2351	2448	2545	2650	2747	2942	3144	3144
.16	\$ 2059	2156	2253	2358	2455	2552	2650	2754	2852	3046	3248	3248
BALANCE POINT 33 DEG.F.												

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 **--ELECTRIC RATE \$/KWH**

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 48UHPOB/A61AO-A
 HEAT PUMP MODEL: OUTDOOR 48UHPOB INDOOR A61AO-A
 ARI RATED COOLING CAP.: BTUH(95) 50000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 48000 COP(47) 3.20, BSPP 7.40 MIN.DR REG IV
 BTUH (17) 29000 COP(17) 2.10
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH ELEC. COST
S/KWH

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1231	2170
.06	\$	1481	2601
.07	\$	1732	3039
.08	\$	1975	3471
.09	\$	2225	3902
.10	\$	2469	4340
.12	\$	2963	5210
.14	\$	3457	6079
.16	\$	3951	6942

BALANCE POINT 22 DEG.F.

80,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1446	2476
.06	\$	1739	2977
.07	\$	2024	3471
.08	\$	2316	3965
.09	\$	2601	4465
.10	\$	2893	4959
.12	\$	3478	5954
.14	\$	4055	6942
.16	\$	4625	7936

BALANCE POINT 26 DEG.F.

90,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1676	2789
.06	\$	2010	3345
.07	\$	2344	3902
.08	\$	2685	4465
.09	\$	3012	5022
.10	\$	3352	5578
.12	\$	4027	6692
.14	\$	4695	78
.16	\$	5363	89

BALANCE POINT 29 DEG.F.

100,000 --- THEORETICAL ANNUAL HEATING ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1912	3095
.06	\$	2295	3721
.07	\$	2678	4340
.08	\$	3060	4959
.09	\$	3443	5578
.10	\$	3825	6197
.12	\$	4591	7443
.14	\$	5349	8681
.16	\$	6121	9926

BALANCE POINT 32 DEG.F.

110,000 --- THEORETICAL ANNUAL HEATING ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	2170	3408
.06	\$	2608	4090
.07	\$	3032	4771
.08	\$	3471	5453
.09	\$	3902	6135
.10	\$	4340	6823
.12	\$	5203	8187
.14	\$	6072	9550
.16	\$	6942	10914

BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16
 \$.95 114 133 152 171 190 228 266 304

<--ELECTRIC RATE S/KWH

<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 48UHP0B INDOOR A61AO-A
ARI RATED COOLING CAP.: BTUH(95°) 50000 SEER10.50
ARI RATED HEATING CAP.: BTUH (47°) 48000 COP(47°) 3.20, BSPF 7.40 MIN.DHR REG IV
FURNACE TYPE: NATURAL GAS **FURNACE EFFICIENCY** 78.00 % AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
50,000	\$ 473	542	605	674	744	813	876	946	1015	1085	1217	1356	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 639	660	681	702	723	744	765	786	806	827	869	911	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 737	758	779	799	820	841	862	883	904	925	966	1008	
.07	\$ 834	855	876	897	918	939	959	980	1001	1022	1064	1106	
.08	\$ 932	952	973	994	1015	1036	1057	1078	1099	1119	1161	1203	
.09	\$ 1029	1050	1071	1092	1112	1133	1154	1175	1196	1217	1259	1300	
.10	\$ 1133	1154	1175	1196	1217	1238	1259	1279	1300	1321	1363	1405	
.12	\$ 1328	1349	1370	1391	1412	1432	1453	1474	1495	1516	1558	1599	
.14	\$ 1523	1544	1565	1586	1606	1627	1648	1669	1690	1711	1752	1794	
.16	\$ 1718	1739	1759	1780	1801	1822	1843	1864	1885	1905	1947	1989	BALANCE POINT 13 DEG.F.
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 730	758	793	820	855	890	918	952	987	1015	1085	1147	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 827	855	890	918	952	987	1015	1050	1085	1112	1182	1245	
.07	\$ 925	952	987	1015	1050	1085	1112	1147	1182	1210	1279	1342	
.08	\$ 1029	1057	1092	1119	1154	1189	1217	1252	1286	1314	1384	1446	
.09	\$ 1126	1154	1189	1217	1252	1286	1314	1349	1384	1412	1481	1544	
.10	\$ 1224	1252	1286	1314	1349	1384	1412	1446	1481	1509	1579	1641	
.12	\$ 1426	1453	1488	1516	1551	1586	1613	1648	1683	1711	1780	1843	
.14	\$ 1620	1648	1683	1711	1745	1780	1808	1843	1878	1905	1975	2038	
.16	\$ 1822	1850	1885	1912	1947	1982	2010	2045	2079	2107	2177	2239	BALANCE POINT 17 DEG.F.
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 793	841	890	939	987	1036	1078	1126	1175	1224	1321	1419	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 890	939	987	1036	1085	1133	1175	1224	1272	1321	1419	1516	
.07	\$ 980	1029	1078	1126	1175	1224	1266	1314	1363	1412	1509	1606	
.08	\$ 1071	1119	1168	1217	1266	1314	1356	1405	1453	1502	1599	1697	
.09	\$ 1168	1217	1266	1314	1363	1412	1453	1502	1551	1599	1697	1794	
.10	\$ 1259	1307	1356	1405	1453	1502	1544	1592	1641	1690	1787	1885	
.12	\$ 1446	1495	1544	1592	1641	1690	1732	1780	1829	1878	1975	2072	
.14	\$ 1627	1676	1725	1773	1822	1871	1912	1961	2010	2059	2156	2253	
.16	\$ 1815	1864	1912	1961	2010	2059	2100	2149	2198	2246	2344	2441	BALANCE POINT 22 DEG.F.
80,000	\$ 758	862	973	1085	1189	1300	1405	1516	1627	1732	1947	2170	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 897	952	1008	1064	1119	1168	1224	1279	1335	1391	1502	1606	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 1001	1057	1112	1168	1224	1272	1328	1384	1439	1495	1606	1711	
.07	\$ 1106	1161	1217	1272	1328	1377	1432	1488	1544	1599	1711	1815	
.08	\$ 1210	1266	1321	1377	1432	1481	1537	1592	1648	1704	1815	1919	
.09	\$ 1314	1370	1426	1481	1537	1586	1641	1697	1752	1808	1919	2024	
.10	\$ 1419	1474	1530	1586	1641	1690	1745	1801	1857	1912	2024	2128	
.12	\$ 1627	1683	1739	1794	1850	1899	1954	2010	2065	2121	2233	2337	
.14	\$ 1829	1885	1940	1996	2052	2100	2156	2212	2267	2323	2434	2538	
.16	\$ 2038	2093	2149	2205	2260	2309	2365	2420	2476	2532	2643	2747	BALANCE POINT 26 DEG.F.
90,000	\$ 848	973	1099	1217	1342	1460	1586	1704	1829	1947	2198	2441	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 966	1043	1119	1196	1272	1349	1426	1502	1572	1648	1801	1954	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 1050	1126	1203	1279	1356	1432	1509	1586	1655	1732	1885	2038	
.07	\$ 1133	1210	1286	1363	1439	1515	1592	1669	1739	1815	1968	2121	
.08	\$ 1217	1293	1370	1446	1523	1599	1676	1752	1822	1899	2052	2205	
.09	\$ 1307	1384	1460	1537	1613	1690	1766	1843	1912	1989	2142	2295	
.10	\$ 1391	1467	1544	1620	1697	1773	1850	1926	1996	2072	2225	2379	
.12	\$ 1565	1641	1718	1794	1871	1947	2024	2100	2170	2246	2399	2552	
.14	\$ 1732	1808	1885	1961	2038	2114	2191	2267	2337	2413	2566	2719	
.16	\$ 1905	1982	2059	2135	2212	2288	2365	2441	2511	2587	2740	2893	BALANCE POINT 29 DEG.F.
100,000	\$ 946	1085	1217	1356	1488	1627	1759	1899	2031	2170	2441	2712	--THEORETICAL HEATING COST * FURNACE ONLY
.05	\$ 1022	1119	1224	1321	1419	1523	1620	1725	1822	1919	2121	2323	THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR
.06	\$ 1085	1182	1286	1384	1481	1586	1683	1787	1885	1982	2184	2385	
.07	\$ 1154	1252	1356	1453	1551	1655	1752	1857	1954	2052	2253	2455	
.08	\$ 1217	1314	1419	1516	1613	1718	1815	1919	2017	2114	2316	2518	
.09	\$ 1279	1377	1481	1579	1676	1780	1878	1982	2079	2177	2379	2580	
.10	\$ 1342	1439	1544	1641	1739	1843	1940	2045	2142	2239	2441	2643	
.12	\$ 1474	1572	1676	1773	1871	1975	2072	2177	2274	2372	2573	2775	
.14	\$ 1599	1697	1801	1899	1996	2100	2198	2302	2399	2497	2698	2900	
.16	\$ 1725	1822	1926	2024	2121	2225	2323	2427	2525	2622	2824	3025	BALANCE POINT 32 DEG.F.

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 48UHPQB INDOOR A61AO-A
 ARI RATED COOLING CAP.: BTUH(95) 50000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 48000 COP(47) 3.20, BSPF 7.40 MIN.DR REG IV
 BTUH (17) 29000, COP(17) 2.10
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC COST \$/KWB	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80
50,000	\$ 681	779	876	973	1071	1168	1266	1363	1467	1565	1662	1759	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 702	737	765	793	827	855	883	918	946	973	1008	1036
	.06	\$ 799	834	862	890	925	952	980	1015	1043	1071	1106	1133
	.07	\$ 897	932	959	987	1022	1050	1078	1112	1140	1168	1203	1231
	.08	\$ 994	1029	1057	1085	1119	1147	1175	1210	1238	1265	1300	1328
	.09	\$ 1092	1126	1154	1182	1217	1245	1272	1307	1335	1363	1398	1426
	.10	\$ 1196	1231	1259	1286	1321	1349	1377	1412	1439	1467	1502	1530
	.12	\$ 1391	1426	1453	1481	1516	1544	1572	1606	1634	1662	1697	1725
	.14	\$ 1586	1620	1648	1676	1711	1739	1766	1801	1829	1857	1892	1919
	.16	\$ 1780	1815	1843	1871	1905	1933	1961	1996	2024	2052	2086	2114
													BALANCE POINT 13 DEG.F.
60,000	\$ 820	939	1050	1168	1286	1405	1523	1641	1759	1878	1996	2	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 827	876	918	966	1015	1057	1106	1154	1196	1245	1293	1342
	.06	\$ 925	973	1015	1064	1112	1154	1203	1252	1293	1342	1391	1439
	.07	\$ 1022	1071	1112	1161	1210	1252	1300	1349	1391	1439	1488	1537
	.08	\$ 1126	1175	1217	1266	1314	1356	1405	1453	1495	1544	1592	1641
	.09	\$ 1224	1271	1314	1363	1412	1453	1502	1551	1592	1641	1690	1739
	.10	\$ 1321	1370	1412	1460	1509	1551	1599	1648	1690	1739	1787	1836
	.12	\$ 1523	1572	1613	1662	1711	1752	1801	1850	1892	1940	1989	2038
	.14	\$ 1718	1766	1808	1857	1905	1947	1996	2045	2086	2135	2184	2232
	.16	\$ 1919	1968	2010	2059	2107	2149	2198	2246	2288	2337	2385	2434
													BALANCE POINT 17 DEG.F.
70,000	\$ 952	1092	1231	1363	1502	1641	1780	1912	2052	2191	2323	2462	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 939	1008	1078	1147	1217	1286	1356	1426	1495	1565	1634	1704
	.06	\$ 1036	1106	1175	1245	1314	1384	1453	1523	1592	1662	1732	1801
	.07	\$ 1126	1196	1266	1335	1405	1474	1544	1613	1683	1752	1822	1892
	.08	\$ 1217	1286	1356	1426	1495	1565	1634	1704	1773	1843	1912	1982
	.09	\$ 1314	1384	1453	1523	1592	1662	1732	1801	1871	1940	2010	2079
	.10	\$ 1405	1474	1544	1613	1683	1752	1822	1892	1961	2031	2100	2170
	.12	\$ 1592	1662	1732	1801	1871	1940	2010	2079	2149	2219	2288	2358
	.14	\$ 1713	1843	1912	1982	2052	2121	2191	2260	2330	2399	2469	2538
	.16	\$ 1961	2031	2100	2170	2239	2309	2379	2448	2518	2587	2657	2726
													BALANCE POINT 22 DEG.F.
80,000	\$ 1092	1252	1405	1565	1718	1878	2031	2191	2344	2504	2657	2817	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 1064	1147	1224	1300	1384	1460	1537	1620	1697	1780	1857	1933
	.06	\$ 1168	1252	1328	1405	1488	1565	1641	1725	1801	1885	1961	2038
	.07	\$ 1272	1356	1432	1509	1592	1669	1745	1829	1905	1989	2065	2142
	.08	\$ 1377	1460	1537	1613	1697	1773	1850	1933	2010	2093	2170	2246
	.09	\$ 1481	1565	1641	1718	1801	1878	1954	2038	2114	2198	2274	2351
	.10	\$ 1586	1669	1745	1822	1905	1982	2059	2142	2219	2302	2379	2455
	.12	\$ 1794	1878	1954	2031	2114	2191	2267	2351	2421	2511	2587	2664
	.14	\$ 1996	2079	2156	2232	2316	2392	2469	2552	2629	2712	2789	2865
	.16	\$ 2205	2288	2365	2441	2525	2601	2678	2761	2838	2921	2998	3074
													BALANCE POINT 26 DEG.F.
90,000	\$ 1231	1405	1579	1759	1933	2107	2288	2462	2636	2817	2991	3165	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 1203	1314	1419	1530	1641	1752	1864	1968	2079	2191	2302	2413
	.06	\$ 1286	1398	1502	1613	1725	1836	1947	2052	2163	2274	2385	2497
	.07	\$ 1370	1481	1586	1697	1808	1919	2031	2135	2246	2358	2469	2580
	.08	\$ 1453	1565	1669	1780	1892	2003	2114	2219	2330	2441	2552	2664
	.09	\$ 1544	1655	1759	1871	1982	2093	2205	2309	2420	2532	2643	2754
	.10	\$ 1627	1739	1843	1954	2065	2177	2288	2392	2504	2615	2726	2838
	.12	\$ 1801	1912	2017	2128	2239	2351	2462	2566	2678	2789	2900	3012
	.14	\$ 1968	2079	2184	2295	2406	2518	2629	2733	2845	2956	3067	3178
	.16	\$ 2142	2253	2358	2469	2580	2692	2803	2907	3018	3130	3241	3352
													BALANCE POINT 29 DEG.F.
100,000	\$ 1363	1565	1759	1954	2149	2344	2538	2733	2935	3130	3325	3519	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 1328	1474	1620	1766	1905	2052	2198	2344	2483	2629	2775	2921
	.06	\$ 1391	1537	1683	1829	1968	2114	2260	2406	2545	2692	2838	2984
	.07	\$ 1460	1606	1752	1899	2038	2184	2330	2476	2615	2761	2907	3053
	.08	\$ 1523	1669	1815	1961	2100	2246	2392	2538	2678	2824	2970	3116
	.09	\$ 1586	1732	1878	2024	2163	2309	2455	2601	2740	2886	3032	3178
	.10	\$ 1648	1794	1940	2086	2225	2372	2518	2664	2803	2949	3095	3241
	.12	\$ 1780	1926	2072	2219	2358	2504	2650	2796	2935	3081	3227	3373
	.14	\$ 1905	2052	2198	2344	2483	2629	2775	2921	3060	3206	3352	3498
	.16	\$ 2031	2177	2323	2469	2608	2754	2900	3046	3185	3332	3478	3624
													BALANCE POINT 32 DEG.F.

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 48UHPOB INDOOR A61AO-A
 ARI RATED COOLING CAP.: BTUH (95°) 50000 SEER 10.50
 ARI RATED HEATING CAP.: BTUH (47°) 48000 COP (47°) 3.20, RSPF 7.40 MIN.DRR REG IV
 BTUH (17°) 29000, COP (17°) 2.10
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC COST \$/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	1.90	2.00	2.10	2.20	2.30	2.40	2.50	2.60	2.70	2.80	2.90	3.00	3.10	3.20	3.30	3.40	3.50	3.60	3.70	3.80	3.90	4.00	4.10	4.20	4.30	4.40	4.50	4.60	4.70	4.80	4.90	5.00	5.10	5.20	5.30	5.40	5.50	5.60	5.70	5.80	5.90	6.00	6.10	6.20	6.30	6.40	6.50	6.60	6.70	6.80	6.90	7.00	7.10	7.20	7.30	7.40	7.50	7.60	7.70	7.80	7.90	8.00	8.10	8.20	8.30	8.40	8.50	8.60	8.70	8.80	8.90	9.00	9.10	9.20	9.30	9.40	9.50	9.60	9.70	9.80	9.90	10.00
50,000	\$ 890	966	1043	1112	1189	1																																																																																														

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
 HEAT PUMP MODEL: OUTDOOR 60UHPOB INDOOR A61AO-A
 ARI RATED COOLING CAP.: BTUH(95) 58000 SEER10.70
 ARI RATED HEATING CAP.: BTUH (47) 61000 COP(47) 3.20, HSPF 7.50 MIN.DHR REG IV
 BTUH (17) 35500 COP(17) 2.20
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
BTUH ELEC.
COST
S/KWH

80,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1363	2476
.06	\$	1634	2977
.07	\$	1905	3471
.08	\$	2177	3965
.09	\$	2448	4465
.10	\$	2719	4959
.12	\$	3269	5954
.14	\$	3811	6942
.16	\$	4361	7936

BALANCE POINT 19 DEG.F.

90,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1558	2789
.06	\$	1871	3345
.07	\$	2177	3902
.08	\$	2490	4465
.09	\$	2803	5022
.10	\$	3116	5578
.12	\$	3742	6698
.14	\$	4361	7811
.16	\$	4987	8931

BALANCE POINT 23 DEG.F.

100,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1766	3095
.06	\$	2121	3721
.07	\$	2476	4340
.08	\$	2831	4959
.09	\$	3178	5578
.10	\$	3533	6197
.12	\$	4243	7443
.14	\$	4952	8681
.16	\$	5655	9926

BALANCE POINT 25 DEG.F.

110,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	1989	3408
.06	\$	2385	4090
.07	\$	2782	4771
.08	\$	3185	5453
.09	\$	3582	6135
.10	\$	3978	6823
.12	\$	4771	8187
.14	\$	5571	9550
.16	\$	6364	10914

BALANCE POINT 28 DEG.F.

130,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.05	\$	2455	4027
.06	\$	2942	4834
.07	\$	3443	5641
.08	\$	3930	6448
.09	\$	4424	7255
.10	\$	4911	8062
.12	\$	5898	9676
.14	\$	6879	11289
.16	\$	7860	12903

BALANCE POINT 32 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

s .05 .06 .07 .08 .09 .10 .12 .14 .16
 s 108 130 151 173 195 216 260 303 346

<--ELECTRIC RATE S/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 HEAT PUMP MODEL: OUTDOOR 60UHPQB INDOOR A61AO-A													
ARI RATED COOLING CAP.: BTUH(95°) 58000 SEER10.70 ARI RATED HEATING CAP.: BTUH (47°) 61000 COP(47°) 3.20, HSPF 7.50 MIN.DHR REG IV BTUH (17°) 35500, COP(17°) 2.20 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE													
HITR LOSS BTUH	ELRC COST \$/KWH	.35	.40	.45	.50	.55	.60	.65	.70	.75	.80	.90	1.00
60,000	\$ 563	646	730	813	890	973	1057	1133	1217	1300	1460	1627	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 737	765	786	813	841	862	890	911	939	966	1015	1064
	.06	\$ 848	876	897	925	952	973	1001	1022	1050	1078	1126	1175
	.07	\$ 959	987	1008	1036	1064	1085	1112	1133	1161	1189	1238	1286
	.08	\$ 1078	1106	1126	1154	1182	1203	1231	1252	1279	1307	1356	1405
	.09	\$ 1189	1217	1236	1266	1293	1314	1342	1363	1391	1419	1467	1516
	.10	\$ 1300	1328	1349	1377	1405	1426	1453	1474	1502	1530	1579	1627
	.12	\$ 1523	1551	1572	1599	1627	1648	1676	1697	1725	1752	1801	1850
	.14	\$ 1752	1780	1801	1829	1857	1878	1905	1926	1954	1982	2031	2079
	.16	\$ 1975	2003	2024	2052	2079	2100	2128	2149	2177	2205	2253	2302
													BALANCE POINT 12 DEG.F.
70,000	\$ 660	758	848	946	1043	1133	1231	1328	1419	1516	1704	1899	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 848	883	911	939	966	994	1029	1057	1085	1112	1175	1231
	.06	\$ 973	1008	1036	1064	1092	1119	1154	1182	1210	1238	1300	1356
	.07	\$ 1106	1140	1168	1196	1224	1252	1286	1314	1342	1370	1432	1488
	.08	\$ 1231	1266	1293	1321	1349	1377	1412	1439	1467	1495	1558	1613
	.09	\$ 1363	1398	1426	1453	1481	1509	1544	1572	1599	1627	1690	1745
	.10	\$ 1488	1523	1551	1579	1606	1634	1669	1697	1725	1752	1815	1871
	.12	\$ 1745	1780	1808	1836	1864	1892	1926	1954	1982	2010	2072	2128
	.14	\$ 2003	2038	2065	2093	2121	2149	2184	2212	2239	2267	2330	2385
	.16	\$ 2260	2295	2323	2351	2379	2406	2441	2469	2497	2525	2587	2643
													BALANCE POINT 16 DEG.F.
80,000	\$ 758	862	973	1085	1189	1300	1405	1516	1627	1732	1947	2170	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 925	973	1015	1057	1099	1140	1182	1231	1272	1314	1398	1488
	.06	\$ 1043	1092	1133	1175	1217	1259	1300	1349	1391	1432	1516	1606
	.07	\$ 1168	1217	1259	1300	1342	1384	1426	1474	1516	1558	1641	1732
	.08	\$ 1293	1342	1384	1426	1467	1509	1551	1599	1641	1683	1766	1857
	.09	\$ 1419	1467	1509	1551	1592	1634	1676	1725	1766	1808	1892	1982
	.10	\$ 1544	1592	1634	1676	1718	1759	1801	1850	1892	1933	2017	2107
	.12	\$ 1794	1843	1885	1926	1968	2010	2052	2100	2142	2184	2267	2358
	.14	\$ 2045	2093	2135	2177	2219	2260	2302	2351	2392	2434	2518	2608
	.16	\$ 2288	2337	2379	2420	2462	2504	2545	2594	2636	2678	2761	2852
													BALANCE POINT 19 DEG.F.
90,000	\$ 848	973	1099	1217	1342	1460	1586	1704	1829	1947	2198	2441	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 994	1057	1119	1182	1238	1300	1363	1426	1488	1551	1669	1794
	.06	\$ 1106	1168	1231	1293	1349	1412	1474	1537	1599	1662	1780	1905
	.07	\$ 1217	1279	1342	1405	1460	1523	1586	1648	1711	1773	1892	2017
	.08	\$ 1328	1391	1453	1516	1572	1634	1697	1759	1822	1885	2003	2128
	.09	\$ 1439	1502	1565	1627	1683	1745	1808	1871	1933	1996	2114	2239
	.10	\$ 1551	1613	1676	1739	1794	1857	1919	1982	2045	2107	2225	2351
	.12	\$ 1773	1836	1899	1961	2017	2079	2142	2205	2330	2448	2573	
	.14	\$ 2003	2065	2128	2191	2246	2309	2372	2434	2497	2559	2678	2803
	.16	\$ 2225	2288	2351	2413	2469	2532	2594	2657	2719	2782	2900	3025
													BALANCE POINT 23 DEG.F.
100,000	\$ 946	1085	1217	1356	1488	1627	1759	1899	2031	2170	2441	2712	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 1092	1161	1231	1293	1363	1432	1502	1572	1641	1704	1843	1982
	.06	\$ 1217	1286	1356	1419	1488	1558	1627	1697	1766	1829	1968	2107
	.07	\$ 1335	1405	1474	1537	1606	1676	1745	1815	1885	1947	2085	2225
	.08	\$ 1460	1530	1599	1662	1732	1801	1871	1940	2010	2072	2212	2351
	.09	\$ 1586	1655	1725	1787	1857	1926	1996	2065	2135	2198	2337	2476
	.10	\$ 1704	1773	1843	1905	1975	2045	2114	2184	2253	2316	2455	2594
	.12	\$ 1954	2024	2093	2156	2225	2295	2365	2434	2504	2566	2705	2845
	.14	\$ 2198	2267	2337	2399	2469	2538	2608	2678	2747	2810	2949	3088
	.16	\$ 2441	2511	2580	2643	2712	2782	2852	2921	2991	3053	3192	3332
													BALANCE POINT 25 DEG.F.
110,000	\$ 1043	1189	1342	1488	1641	1787	1940	2086	2232	2385	2685	2984	--THEORETICAL HEATING COST * FURNACE ONLY
	.05	\$ 1154	1245	1342	1432	1523	1620	1711	1808	1899	1989	2177	2365
	.06	\$ 1252	1342	1439	1530	1620	1718	1808	1905	1996	2086	2274	2462
	.07	\$ 1349	1439	1537	1627	1718	1815	1905	2003	2093	2184	2372	2559
	.08	\$ 1453	1544	1641	1732	1822	1919	2010	2107	2198	2288	2476	2664
	.09	\$ 1551	1641	1739	1829	1919	2017	2107	2205	2295	2385	2573	2761
	.10	\$ 1648	1739	1836	1926	2017	2114	2205	2302	2392	2483	2671	2858
	.12	\$ 1850	1940	2038	2128	2191	2316	2406	2504	2594	2685	2872	3060
	.14	\$ 2052	2142	2239	2330	2420	2518	2608	2705	2796	2886	3074	3262
	.16	\$ 2246	2337	2434	2525	2615	2712	2803	2900	2991	3081	3269	3457
													BALANCE POINT 28 DEG.F.

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5
HEAT PUMP MODEL: OUTDOOR 60UHPQB INDOOR A61AO-A
ARI RATED COOLING CAP.: BTUH(95°) 58000 **SEER10.70**
ARI RATED HEATING CAP.: BTUH (47°) 61000 **COP(47°)** 3.20, **HSPF** 7.50 **MIN.DHR REG IV**
BTUH (17°) 35500, **COP(17°)** 2.20
FURNACE TYPE FUEL OIL **FURNACE EFFICIENCY** **78.00 % AFUE**

HEAT LOSS BTUH	ELPC. \$/KWH	HEATING OIL COST - \$/GALLON											
		.70	.80	.90	1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80

60,000 \$ 820 939 1050 1168 1286 1405 1523 1641 1759 1878 1996 2107 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 813	855	890	925	959	994	1036	1071	1106	1140	1175	1210	
.06	\$ 925	966	1001	1036	1071	1106	1147	1182	1217	1252	1286	1321	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1036	1078	1112	1147	1182	1217	1259	1293	1328	1363	1398	1432	
.08	\$ 1154	1196	1231	1266	1300	1335	1377	1412	1446	1481	1516	1551	
.09	\$ 1266	1307	1342	1377	1412	1446	1488	1523	1558	1592	1627	1662	
.10	\$ 1377	1419	1453	1488	1523	1558	1599	1634	1669	1704	1739	1773	
.12	\$ 1599	1641	1676	1711	1745	1780	1822	1857	1892	1926	1961	1996	
.14	\$ 1829	1871	1905	1940	1975	2010	2052	2086	2121	2156	2191	2225	
.16	\$ 2052	2093	2128	2163	2198	2232	2274	2309	2344	2379	2413	2448	BALANCE POINT 12 DEG.F.

70,000 \$ 952 1092 1231 1363 1502 1641 1780 1912 2052 2191 2323 2462 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 939	980	1029	1071	1112	1154	1196	1238	1279	1321	1363	1405	
.06	\$ 1064	1106	1154	1196	1238	1279	1321	1363	1405	1446	1488	1530	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1196	1238	1286	1328	1370	1412	1453	1495	1537	1579	1620	1662	
.08	\$ 1321	1363	1412	1453	1495	1537	1579	1620	1662	1704	1745	1787	
.09	\$ 1453	1495	1548	1586	1627	1669	1711	1752	1794	1836	1878	1919	
.10	\$ 1579	1620	1669	1711	1752	1794	1836	1878	1919	1961	2003	2045	
.12	\$ 1836	1878	1926	1968	2010	2052	2093	2135	2177	2219	2260	2302	
.14	\$ 2093	2135	2184	2225	2267	2309	2351	2392	2434	2476	2518	2559	
.16	\$ 2351	2392	2441	2483	2525	2566	2608	2650	2692	2733	2775	2817	BALANCE POINT 16 DEG.F.

80,000 \$ 1092 1252 1405 1565 1718 1878 2031 2191 2344 2504 2657 2817 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1057	1119	1182	1245	1307	1370	1432	1495	1558	1620	1683	1745	
.06	\$ 1175	1238	1300	1363	1426	1488	1551	1613	1676	1739	1801	1864	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1300	1363	1426	1488	1551	1613	1676	1739	1801	1864	1926	1989	
.08	\$ 1426	1488	1551	1613	1676	1739	1801	1864	1926	1989	2052	2114	
.09	\$ 1551	1613	1676	1739	1801	1864	1926	1989	2052	2114	2177	2239	
.10	\$ 1676	1739	1801	1864	1926	1989	2052	2114	2177	2239	2302	2365	
.12	\$ 1926	1989	2052	2114	2177	2239	2302	2365	2427	2490	2552	2615	
.14	\$ 2177	2239	2302	2365	2427	2490	2552	2615	2678	2740	2803	2865	
.16	\$ 2420	2483	2545	2608	2671	2733	2796	2858	2921	2984	3046	3109	BALANCE POINT 19 DEG.F.

90,000 \$ 1231 1405 1579 1759 1933 2107 2288 2462 2636 2817 2991 3165 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1182	1272	1363	1453	1537	1627	1718	1808	1892	1982	2072	2163	
.06	\$ 1293	1384	1474	1565	1648	1739	1829	1919	2003	2093	2184	2274	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1405	1495	1586	1676	1759	1850	1940	2031	2114	2205	2295	2385	
.08	\$ 1516	1606	1697	1787	1871	1961	2052	2142	2225	2316	2406	2497	
.09	\$ 1627	1718	1808	1899	2012	2163	2253	2337	2427	2518	2608		
.10	\$ 1739	1829	1919	2010	2093	2184	2274	2365	2448	2538	2629	2719	
.12	\$ 1961	2052	2142	2232	2316	2406	2497	2587	2671	2761	2852	2942	
.14	\$ 2191	2281	2372	2462	2545	2636	2726	2817	2900	2991	3081	3172	
.16	\$ 2413	2504	2594	2685	2768	2858	2949	3039	3123	3213	3304	3394	BALANCE POINT 23 DEG.F.

100,000 \$ 1363 1565 1759 1954 2149 2344 2538 2733 2935 3130 3325 3519 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1300	1398	1502	1599	1697	1794	1892	1996	2093	2191	2288	2385	
.06	\$ 1426	1523	1627	1725	1822	1919	2017	2121	2219	2316	2413	2511	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1544	1641	1745	1843	1940	2038	2135	2239	2337	2434	2532	2629	
.08	\$ 1669	1766	1871	1968	2065	2163	2260	2365	2462	2559	2657	2754	
.09	\$ 1794	1892	1966	2093	2191	2288	2385	2490	2587	2685	2782	2879	
.10	\$ 1912	2010	2114	2212	2309	2406	2504	2608	2705	2803	2900	2998	
.12	\$ 2163	2260	2365	2462	2559	2657	2754	2858	2956	3053	3151	3248	
.14	\$ 2406	2504	2608	2705	2803	2900	2998	3102	3199	3297	3394	3491	
.16	\$ 2650	2747	2852	2949	3046	3144	3241	3345	3443	3540	3638	3735	BALANCE POINT 25 DEG.F.

110,000 \$ 1502 1718 1933 2149 2365 2580 2796 3012 3227 3443 3658 3874 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1439	1579	1711	1843	1982	2114	2246	2385	2518	2650	2789	2921	
.06	\$ 1531	1676	1808	1940	2079	2212	2344	2483	2615	2747	2886	3018	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1634	1773	1905	2038	2177	2309	2441	2580	2712	2845	2984	3116	
.08	\$ 1739	1878	2010	2142	2281	2413	2545	2685	2817	2949	3088	3220	
.09	\$ 1836	1975	2107	2239	2379	2511	2643	2782	2914	3046	3185	3318	
.10	\$ 1933	2072	2205	2337	2476	2608	2740	2879	3012	3144	3283	3415	
.12	\$ 2135	2274	2406	2538	2678	2810	2942	3081	3213	3345	3485	3617	
.14	\$ 2337	2476	2608	2740	2879	3012	3144	3283	3415	3547	3686	3818	BALANCE POINT 28 DEG.F.
.16	\$ 2532	2671	2803	2935	3074	3206	3338	3478	3610	3742	3881	4013	

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 5 60UHPQB/A61AO-A
HEAT PUMP MODEL: OUTDOOR 60UHPQB INDOOR A61AO-A
ARI RATED COOLING CAP.: BTUH(95) 58000 SEER10.70
ARI RATED HEATING CAP.: BTUH(47) 61000 COP(47) 3.20, ESEPF 7.50 MIN.DHR REG IV
BTUH (17) 35500 COP(17) 2.20
FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

HEAT LOSS BTUH	ELRIC COST \$/KWH	.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.20
		PROPANE GAS COST - \$/GALLON											

60,000 \$ 1071 1161 1252 1335 1426 1516 1606 1697 1787 1968 2142 2142 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 890	918	946	973	1001	1029	1057	1085	1112	1168	1224	1224	
.06	\$ 1001	1029	1057	1085	1112	1140	1168	1196	1224	1279	1335	1335	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1112	1140	1168	1196	1224	1252	1279	1307	1335	1391	1446	1446	
.08	\$ 1231	1259	1286	1314	1342	1370	1398	1426	1453	1509	1565	1565	
.09	\$ 1342	1370	1398	1426	1453	1481	1509	1537	1565	1620	1676	1676	
.10	\$ 1453	1481	1509	1537	1565	1592	1620	1648	1676	1732	1787	1787	
.12	\$ 1676	1704	1732	1759	1787	1815	1843	1871	1899	1954	2010	2010	
.14	\$ 1905	1933	1961	1989	2017	2045	2072	2100	2128	2184	2239	2239	
.16	\$ 2128	2156	2184	2212	2239	2267	2295	2323	2351	2406	2462	2462	BALANCE POINT 12 DEG.F.

70,000 \$ 1252 1356 1460 1565 1669 1773 1878 1982 2086 2295 2504 2504 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1029	1064	1099	1126	1161	1189	1224	1259	1286	1356	1419	1419	
.06	\$ 1154	1189	1224	1252	1286	1314	1349	1384	1412	1481	1544	1544	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1286	1321	1356	1384	1419	1446	1481	1515	1544	1613	1676	1676	
.08	\$ 1412	1446	1481	1509	1544	1572	1606	1641	1669	1739	1801	1801	
.09	\$ 1544	1579	1613	1641	1676	1704	1739	1773	1801	1871	1933	1933	
.10	\$ 1669	1704	1739	1766	1801	1829	1864	1899	1926	1996	2059	2059	
.12	\$ 1926	1961	1996	2024	2059	2086	2121	2156	2184	2253	2316	2316	
.14	\$ 2184	2219	2253	2281	2316	2344	2379	2413	2441	2511	2573	2573	
.16	\$ 2441	2476	2511	2538	2573	2601	2636	2671	2698	2768	2831	2831	BALANCE POINT 16 DEG.F.

80,000 \$ 1426 1551 1669 1787 1905 2024 2142 2260 2385 2622 2858 2858 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1196	1238	1286	1335	1384	1432	1474	1523	1572	1669	1759	1759	
.06	\$ 1314	1356	1405	1453	1502	1551	1592	1641	1690	1787	1878	1878	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1439	1481	1530	1579	1627	1676	1718	1766	1815	1912	2003	2003	
.08	\$ 1565	1606	1655	1704	1752	1801	1843	1892	1940	2038	2128	2128	
.09	\$ 1690	1732	1780	1829	1878	1926	1968	2017	2065	2163	2253	2253	
.10	\$ 1815	1857	1905	1954	2003	2052	2093	2142	2191	2288	2379	2379	
.12	\$ 2065	2107	2156	2205	2253	2302	2344	2392	2441	2538	2629	2629	
.14	\$ 2316	2358	2406	2455	2504	2552	2594	2643	2692	2789	2879	2879	
.16	\$ 2559	2601	2650	2698	2747	2796	2838	2886	2935	3032	3123	3123	BALANCE POINT 19 DEG.F.

90,000 \$ 1606 1739 1878 2010 2142 2281 2413 2545 2678 2949 3220 3220 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1377	1439	1509	1579	1648	1711	1780	1850	1919	2052	2184	2184	
.06	\$ 1488	1551	1620	1690	1759	1822	1892	1961	2031	2163	2295	2295	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1599	1662	1732	1801	1871	1933	2003	2072	2142	2274	2406	2406	
.08	\$ 1711	1773	1843	1912	1982	2045	2114	2184	2253	2385	2518	2518	
.09	\$ 1822	1885	1954	2024	2093	2156	2225	2295	2365	2497	2629	2629	
.10	\$ 1933	1996	2065	2135	2205	2267	2337	2406	2476	2608	2740	2740	
.12	\$ 2156	2219	2282	2358	2427	2490	2559	2629	2698	2831	2963	2963	
.14	\$ 2385	2448	2518	2587	2657	2719	2789	2858	2928	3060	3192	3192	
.16	\$ 2608	2671	2740	2810	2879	2942	3012	3081	3151	3283	3415	3415	BALANCE POINT 23 DEG.F.

100,000 \$ 1787 1933 2086 2232 2385 2532 2678 2831 2977 3276 3575 3575 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1516	1586	1662	1739	1815	1892	1968	2038	2114	2267	2413	2413	
.06	\$ 1641	1711	1787	1864	1940	2017	2093	2163	2239	2392	2538	2538	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1759	1829	1905	1982	2059	2135	2212	2281	2358	2511	2657	2657	
.08	\$ 1885	1954	2031	2107	2184	2260	2337	2406	2483	2636	2782	2782	
.09	\$ 2010	2079	2156	2232	2309	2385	2462	2532	2608	2761	2907	2907	
.10	\$ 2128	2198	2274	2351	2427	2504	2580	2650	2726	2879	3025	3025	
.12	\$ 2379	2448	2525	2601	2678	2754	2831	2900	2977	3130	3276	3276	
.14	\$ 2622	2692	2768	2845	2921	2998	3074	3144	3220	3373	3519	3519	
.16	\$ 2865	2935	3012	3088	3165	3241	3318	3387	3464	3617	3763	3763	BALANCE POINT 25 DEG.F.

110,000 \$ 1968 2128 2295 2455 2622 2782 2949 3116 3276 3603 3937 3937 --THEORETICAL HEATING COST * FURNACE ONLY

.05	\$ 1732	1829	1933	2038	2142	2239	2344	2448	2552	2754	2956	2956	
.06	\$ 1829	1926	2031	2135	2239	2337	2441	2545	2650	2852	3053	3053	THEORETICAL HEATING COST * FURN.+ HEAT PUMP S PER YEAR
.07	\$ 1926	2024	2128	2232	2337	2434	2538	2643	2747	2949	3151	3151	
.08	\$ 2031	2128	2232	2337	2441	2538	2643	2747	2852	3053	3255	3255	
.09	\$ 2128	2225	2330	2434	2538	2636	2740	2845	2949	3151	3352	3352	
.10	\$ 2225	2323	2427	2532	2636	2733	2838	2942	3046	3248	3450	3450	
.12	\$ 2427	2525	2629	2733	2838	2935	3039	3144	3248	3450	3651	3651	
.14	\$ 2629	2726	2831	2935	3039	3137	3241	3345	3450	3651	3853	3853	
.16	\$ 2824	2921	3025	3130	3234	3332	3436	3540	3645	3846	4048	4048	BALANCE POINT 28 DEG.F.

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.