
INSTALLATION INSTRUCTIONS

ELECTRIC HEAT PACKAGES

Models:

EHWA02-AXD EHWH02-AXD
EHWA02-AXH EHWH30-AXD
EHWA03-AXH EHWH30-AXH
EHWA03-AXK EHWH30-AXK
EHWA05-AXH EHWH36-AXD
EHWA05-AXK EHWH36-AXH
EHWH36-AXK
EHWH04-AXH
EHWH04-AXK
EHWH05-AXH
EHWH05-AXK

**FOR USE WITH WA AND WH SERIES
WALL MOUNTED AIR CONDITIONERS
AND HEAT PUMPS**

SEE TABLE 1 FOR MODEL USAGE



Bard Manufacturing Company, Inc.
Bryan, Ohio 43506
Since 1914...Moving ahead, just as planned.

Manual: 2100-415C
Supersedes: 2100-415B
File: Volume III, Tab 18
Date: 11-10-05

CONTENTS

General Information

Nomenclature 3
Description of Equipment 3
Important 3
Shipping Damage 3
Unpacking Electric Heat Package 3
Wiring Main Power 5

Installation

Installation of Heater Package 7

Tables


Table 1 Heater Usage by Model Matrix 4
Table 2 Electrical Data 6
Table 3 Terminal and Screw Mounting 10

Figures

Figure 1 Electrical Connections 5
Figure 2 Installation of Heater Package 8
WA24, WA30, WA36 Models and
WH24, WH30, WH36 Models
Figure 2A Installation of Heater Package 9
WA42, WA48, WA60 Models and
WH42, WH48, WH60 Models
Figure 3 Rod Support and Screw Mounting .. 10
Figure 4A-4C Terminal Identification 11
Figure 5 Wiring Directions 12
WA24, WA30, WA36 Models and
WH24, WH30, WH36 Models
Figure 5A Wiring Directions 13
WA42, WA48, WA60 Models and
WH42, WH48, WH60 Models
Figure 6 Marking Serial Plate 14

GENERAL INFORMATION

NOMENCLATURE



DESCRIPTION OF EQUIPMENT

The EHWA and EHWH series electric heater packages are field installable heater packages suitable for use with Bard wall mount hi boy air conditioners and heat pumps. The packages consist of the electric heat strip, the heater control base which includes the heat contactors, and circuit breaker of pull disconnects, installation instructions and wiring diagrams. See Table 1 for nominal electrical data and BTU output. Before installation, check unit serial plate to insure the heater package model that you intend to install is listed as a heater package that is suitable for use with the Bard wall mount hi boy unit. See Figure 6.

IMPORTANT

The equipment covered in this manual is to be installed by trained, experienced service and installation technicians.

SHIPPING DAMAGE

Upon receipt of equipment, the carton should be checked for external signs of shipping damage. If damage is found, the receiving party must contact the last carrier immediately, preferably in writing, requesting inspection by the carrier's agent.

UNPACKING ELECTRIC HEAT PACKAGE

Remove the heat package from the shipping carton. The heat package must consist of the following:

1. Basic heater.
2. Electric heat control base and wiring.
3. Installation instructions.
4. Wiring diagram (2), one to be applied to unit.
5. Adhesive label to remark serial plate to indicate new model number. This is attached to the front of these instructions.

**TABLE 1
HEATER USAGE BY MODEL MATRIX**

	WA182-A	WA242-A	WA253-A	WA302-A	WA361-A	WA372-A	WA423-A	WA484-A	WA602-A	WH184-A	WH242-A	WH301-A	WH361-A	WH421-A	WH483-A	WH602-A
EHWA02-AXD	X	X	X													
EHWA02-AXH	X	X	X													
EHWA03-AXH				X	X	X										
EHWA03-AXK				X	X	X										
EHWA05-AXH							X	X	X							
EHWA05-AXK							X	X	X							
EHWH02-AXD										X	X					
EHWH30-AXD												X				
EHWH30-AXH												X				
EHWH30-AXK												X				
EHWH36-AXD													X			
EHWH36-AXH													X			
EHWH36-AXK													X			
EHWH04-AXH														X	X	
EHWH04-AXK														X	X	
EHWH05-AXH																X
EHWH05-AXK																X

 **WARNING**

ONLY USE FACTORY PROVIDED HEATERS IN APPROVED COMBINATIONS OF HEATER MODELS TO UNIT MODELS AS SHOWN ON THIS TABLE. FAILURE TO USE APPROVED COMBINATIONS AS SHOWN OR MODIFICATION TO HEATERS, COULD RESULT IN FIRE CAUSING DAMAGE, BODILY INJURY OR DEATH.

WIRING MAIN POWER

1. On all installations, size unit power supply wiring for the minimum circuit ampacity requirement for the unit and heater package combination listed on the unit serial plate.

For existing installations, addition or upgrading of a heater package may require that larger supply wires be run to the unit. Resize all power supply wires for the minimum circuit ampacity rating listed on the unit serial plate that is applicable for your combination of unit and heater package.

⚠ WARNING

INSTALL PROPERLY SIZED POWER SUPPLY LEADS FOR THE UNIT/HEATER COMBINATION MINIMUM CIRCUIT AMPACITY AS LISTED ON THE UNIT SERIAL PLATE. HAZARD OF FIRE. FAILURE TO INSTALL PROPERLY SIZED CONDUCTORS COULD RESULT IN FIRE.


2. All heater packages covered by this manual are factory wired for a single supply circuit. The following heater packages are field convertible to a dual supply circuit if required or desired.

EHWA05-AXK	EHWA03-AXK
EHWH30-AXK	EHWH36-AXK
EHWH04-AXK	EHWH05-AXK

3. To convert the above heater packages to dual circuit configuration before installation, loosen 4 screws holding jumper bar in place. Remove jumper bar. Circuit A + B are now identified on the heater package. See Figure 1.

Wire should be sized to the minimum circuit ampacity as specified on the serial plates of units that accept these heater packages for circuits A + B.

**FIGURE 1
ELECTRICAL CONNECTIONS**




MIS-365

**TABLE 2
ELECTRICAL DATA AND BTU OUTPUT**

Heater Package Model	Volts	Phase	Nominal KW	Nominal BTU
EHWA02-AXD	240/208	1	5 / 3.75	17,065 / 12,800
EHWA02-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWA03-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWA03-AXK	240/208	1	15 / 11.25	51,200 / 38,400
EHWA05-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWA05-AXK	240/208	1	15 / 11.25	51,200 / 38,400
EHWH02-AXD	240/208	1	5 / 3.75	17,065 / 12,800
EHWH30-AXD	240/208	1	5 / 3.75	17,065 / 12,800
EHWH30-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWH30-AXK	240/208	1	15 / 11.25	51,200 / 38,400
EHWH36-AXD	240/208	1	5 / 3.75	17,065 / 12,800
EHWH36-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWH36-AXK	240/208	1	15 / 11.25	51,200 / 38,400
EHWH04-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWH04-AXK	240/208	1	15 / 11.25	51,200 / 38,400
EHWH05-AXH	240/208	1	10 / 7.5	34,130 / 25,600
EHWH05-AXK	240/208	1	15 / 11.25	51,200 / 38,400


INSTALLATION OF HEATER PACKAGE

1. Disconnect all power to unit before installation.

 WARNING
DISCONNECT ALL POWER TO UNIT BEFORE INSTALLING HEATER PACKAGE. HAZARD OF ELECTRICAL SHOCK. FAILURE TO DISCONNECT POWER COULD RESULT IN INJURY OR DEATH.

2. Before installation, check unit serial plate to insure that the heater package model that you intend to install is listed as a heater package suitable for use with the unit.

Under no circumstances shall a heater package be installed in a unit if the model number of the heater package does not appear on the unit serial plate.


 WARNING
INSTALL ONLY HEATER PACKAGES LISTED ON UNIT SERIAL PLATE. HAZARD OF FIRE OR ELECTRICAL SHOCK. FAILURE TO INSTALL LISTED HEATER PACKAGE COULD RESULT IN FIRE, INJURY OR DEATH.

3. Remove electric heater access panel and control panel cover, both inner and outer. See Figure 2 or 2A.
4. All heaters are installed with the line break limits positioned to the top of the unit. Install heat strip(s) through heater access opening. Position heat strip support rod in heater support hole 1, 2, or 3 as indicated in Table 1 and Figure 3. Secure in place with 2 sheet metal screws in mounting holes as indicated in Table 1 and Figure 3.

On heater packages with 2 heat strips 10KW heater first in position closest to the outlet air frame. See Figures 4C.


5. Install heater control base into top of control panel as shown in Figure 5. Secure with 4 sheet metal screws provided.
6. Plug male 6 pin connector into mating connector mounted in control panel. See Figure 5.
7. Connect red compressor supply lead to L1 of terminal block. Connect black compressor supply lead to L2 of terminal block. See Figure 5 or 5A and wiring diagram.
8. Route wires from heater control base up through raceway or grommet in top right corner of control panel to the heaters. See Figure 5 or 5A.
9. Wire heater package per wiring diagram supplied with this heater package. All wires are stamped with wire numbers that correspond with terminal numbers on the wiring diagram and stamped numbers on the heat strip. Limit switch wires are terminated with insulated quick connect terminals. See Figure 4.
10. Attach adhesive wiring diagram directly above unit wiring diagram on inner control panel cover.
11. Recheck all wiring. Break out appropriate circuit breaker tabs on inner control panel cover to allow trip lever to protrude. Replace control panel and heater access panels
12. Resupply power to the unit and check for proper operation.
13. Remark serial plate with self-adhesive label attached to the front of this manual. See Figure 6.

FIGURE 2
INSTALLATION OF HEATER PACKAGE
WA24, WA30 AND WA36 MODELS AND
WH24, WH30 AND WH36 MODELS



MIS-361

**FIGURE 2A
INSTALLATION OF HEATER PACKAGE
WA421, WA481 AND WA601 MODELS AND
WH42, WH48 AND WH60 MODELS**




MIS-419

TABLE 3
REFER TO FIGURES 3 AND 4

	Heater Package Model Number	Figure 4 Heater Terminal Identification Drawing	Figure 3 Rod Support and Screw Mounting Position
1	EHWA02-AXD	4A	1 + 1
2	EHWA02-AXH	4B	1 + 1
3	EHWA05-AXH	4B	1 + 1
4	EHWA05-AXK	4C	2 + 2
5	EHWA03-AXH	4B	1 + 1
6	EHWA03-AXK	4C	2 + 2
7	EHWH02-AXD	4A	1 + 1
8	EHWH30-AXD	4A	1 + 1
9	EHWH30-AXH	4B	1 + 1
10	EHWH30-AXK	4C	2 + 2
11	EHWH36-AXD	4A	1 + 1
12	EHWH36-AXH	4B	1 + 1
13	EHWH36-AXK	4C	2 + 2
14	EHWH04-AXH	4B	1 + 1
15	EHWH04-AXK	4C	2 + 2
16	EHWH05-AXH	4B	1 + 1
17	EHWH05-AXK	4C	2 + 2


FIGURE 3
ROD SUPPORT AND
SCREW MOUNTING POSITIONS



MIS-358


**FIGURES 4A - 4C
HEATER TERMINAL IDENTIFICATION DRAWINGS**

FIGURE 4 A




EHWA02-AXD
 EHHW02-AXD
 EHHW30-AXD
 EHHW36-AXD

FIGURE 4 B



EHWA02-AXH
 EHWA03-AXH
 EHWA05-AXH
 EHHW30-AXH
 EHHW36-AXH
 EHHW04-AXH
 EHHW05-AXH

FIGURE 4 C




EHWA03-AXK
 EHHW30-AXK
 EHHW36-AXK
 EHHW04-AXK
 EHHW05-AXK
 EHWA05-AXK
 EHHW05-AXK

NOTE: LIMIT DEVICES TO BE AT
 TOP OF AIR FRAME WHEN INSTALLING.


MIS-1902

FIGURE 5
WIRING DIRECTIONS
WA24, WA30 AND WA36 MODELS
WH24, WH30 AND WH36 MODELS



MIS-1741

FIGURE 5A
WIRING DIRECTIONS
WA42, WA48 AND WA60 MODELS
WH42, WH48 AND WH60 MODELS



MIS-1742

**FIGURE 6
MARKING SERIAL PLATE LABEL**

BARD MANUFACTURING COMPANY, 1914 RANDOLPH DRIVE

(X)	()	()	()	()	()
()	(X)	()	()	()	()
()	()	(X)	()	()	()
()	()	()	(X)	()	()
()	()	()	()	()	(X)

MODEL APPROVED
HEATER
PACKAGE

() JWA361-A0012345 NONE 230/208 60
 () IWA361-A0512345 EHWAO3-A05 230/208 60
 () IWA361-A0812345 EHWAO3-A08 230/208 60
 (X) IWA361-AXH EHWAO3-AXH 230/208 60
 () JWA361-AXK EHWAO3-AXK 230/208 60

ASSURE THAT SERIAL PLATE IS CLEAN AND DRY, REMOVE APPROPRIATE LABEL STRIP FOR KW REQUIRED AND REMARK SERIAL PLATE AS SHOWN FOR THE HEATER PACKAGE THAT IS INSTALLED

BRANCH CIRCUIT SELECT CURRENT 17 OPERATION

SERIAL NUMBER 125H920711193-01 UL FILE NO.

SUITABLE FOR OUTDOOR USE

COMPELLOR MOTOR VAC HZ HP
 OUTDOOR MOTOR 230/208 60 1
 INDOOR MOTOR 230/208 60 1
 HEATER PACKAGE KW
 EHWAO3-A05 240/208 60 5/3.75
 EHWAO3-A08 240/208 60 8/6
 EHWAO3-A10, -AXH 240/208 60 10/7.5
 EHWAO3-A15, -AXK 240/208 60 15/11.25

FACTORY CHARGED R22: 68 OZ. DESI
 -- FACTORY
 -- CLEAR

INSTALL ONLY HEATER PACKAGES LISTED HERE